


THOSE PORTIONS OF THIS DRAWING WHICH ARE COLORED CYAN INDICATE THAT THE COLORED ITEM IS SUBJECT TO AGING MANAGEMENT REVIEW

D-40



- NOTES:
- FOR GENERAL NOTES, SEE DRAWING: 33013-2241.
  - THIS DRAWING SUPERSEDES PORTIONS OF DRAWING: 33013-1277, REV. A.
  - EXCEPT WHERE OTHERWISE INDICATED, SAFETY CLASS BREAKS FOR ALL VENT, DRAIN, AND TEST CONNECTIONS SHALL BE AT THE ROOT VALVE IN ACCORDANCE WITH DETAIL "A".
  - ALL SAFETY CLASS LINES ARE SEISMIC CATEGORY 1.
  - MS-600-1 LINE SPEC. APPLIES, BUT SEAMLESS 2 1/4" CR-110, ASME SPEC. SA350, GRADE P22 PIPE IS SUBSTITUTED.
  - EXCEPT WHERE OTHERWISE INDICATED, SAFETY CLASS FOR INSTRUMENT AIR AND NITROGEN LINES AND COMPONENTS IS BASED ON UPSTREAM INSTRUMENT AIR/NITROGEN VALVE. REFER TO INTERFACING AIR/NITROGEN DRAWING FOR SAFETY CLASS.
  - ELECTRICAL SIGNAL IS SAFETY SIGNIFICANT. PRESSURE BOUNDARY IS NON-NUCLEAR SAFETY.
  - WET LAY-UP SYSTEM HOSES TO S/G'S ARE INSTALLED CONNECTED AND OPERATED ONLY WHEN PLANT IS IN MODES 5, 6, OR NO MODE OF OPERATION.
  - WET LAY-UP PUMPS, PIPING, AND VALVES AS IDENTIFIED AS SEISMIC ARE PERMANENTLY MOUNTED IN THE CONTAINMENT.

REVISED PER	DATE	BY	CHKD	DATE
DCR 2001-047	1/2/02			1/3/02
FOR 88-008				1/3/02
				1/4/02
CAD FILE NAME: 3P127701				
CONSTRUCTION				
LIMITED CONSTRUCTION AS NOTED				
PRELIMINARY NOT FOR CONSTRUCTION				
ISSUED FOR CONSTRUCTION				
DATE				
1/4/02				
AS BUILT				
DATE				
1/4/02				
RELEASED FOR				
DATE				
1/4/02				
DRAWN BY				
GINNA, STA.				
CHECKED BY				
NONE				
SCALE				
NONE				
TITLE				
STEAM GENERATOR				
BLOWDOWN				
(SGB)				
P & ID				
JOB NO.				
DRAWING NO.				
REV.				
EWR 3301E				
33013-1277 SHEET 1 OF 2-LR				
CCD 01 CONTROL COPY #				