



NOTES:

- FOR GENERAL NOTES REFER TO DRAWING 33013-2241.
- REVISION "0" OF THIS DRAWING SUPERSEDES PORTIONS OF DRAWING 33013-1272, REV. 6.
- WHERE NOTED, PIPE FITTINGS FOR SMALL BORE PIPING SHALL BE SCH. 10S SEAMLESS, BUTT-WELDED PER ASTM A403 TP304.
- EXCEPT WHERE OTHERWISE INDICATED, SAFETY CLASS BREAKS FOR ALL VENT, DRAIN & TEST CONNECTIONS SHALL BE AT THE ROOT VALVE IN ACCORDANCE WITH DETAIL "A".
- NWD08 AND NWD07 ARE A "WAFFER-TYPE" STRAINER WITH 1/16" HOLD-DIA. RODS WELDED TO IT AND USED TO SUPPORT A SCREEN.
- SUMP PUMP IS INSTALLED IN CHARGING PUMP ROOM FLOOR DRAIN BOX AND DISCHARGES ANY OIL SPILLAGE THRU A 1 1/4" DIA. POLYETHYLENE PIPE THAT IS LOCATED IN THE INSIDE OF THE FLOOR DRAIN PIPING SYSTEM. THE PIPING EXITS THE EXISTING DRAIN SYSTEM AT DRAIN BOX #2 AND TRAVELS OVER THE FLOOR TO THE HATCHWAY OF THE RHR PIT AND EVENTUALLY TO THE AUXILIARY BLDG. SUMP, LOCATED IN THE RHR PIT.
- EXCEPT WHERE OTHERWISE INDICATED, SAFETY CLASS FOR INSTRUMENT AIR AND NITROGEN LINES AND COMPONENTS IS BASED UPON UPSTREAM INSTRUMENT AIR/NITROGEN VALVE. REFER TO INTERFACING AIR/NITROGEN DRAWING FOR SAFETY CLASS.
- ELECTRIC MOTOR CEN'S FOR MECHANICAL EQUIPMENT ARE DEPICTED IN BRACKETS ADJACENT TO MECHANICAL EQUIPMENT AS PER SFWER 1032B.
- THESE DEVICES ARE SAFETY SIGNIFICANT FOR FLOW RESTRICTION AND BACKFLOW PREVENTION QUALITY REQUIREMENTS.

D-35

THOSE PORTIONS OF THIS DRAWING WHICH ARE COLORED CYAN INDICATE THAT THE COLORED ITEM IS SUBJECT TO AGING MANAGEMENT REVIEW

REVISION	DATE	BY	CHKD	APP'D	REV.
001	2/28/02	2/27/02	2/28/02	3/1/02	
CONSTRUCTION					
LIMITED CONSTRUCTION AS NOTED					
PRELIMINARY NOT FOR CONSTRUCTION					
REVISION PURPOSE					
AS BUILT					
DATE	RELEASED FOR	PP	ENGR.		
2/28/02					
WASTE DISPOSAL-LIQUID RC DRAIN TANK (WD) P & ID					
JOB NO.	DRAWING NO.	REV.			
EWR 3391E	33013-1272 SHEET 2 OF 2				
CCD 01	CONTROL COPY #				