



THOSE PORTIONS OF THIS DRAWING WHICH ARE COLORED CYAN INDICATE THAT THE COLORED ITEM IS SUBJECT TO AGING MANAGEMENT REVIEW

D-66

- NOTES:
- FOR GENERAL NOTES SEE DRAWING 33013-2241
  - REVISION "D" OF THIS DRAWING SUPERSEDES PORTIONS OF DRAWING 33013-1240 & 1241.
  - ALL VALVE TAMPER SWITCHES ARE SUPERVISED BY RELAY ROOM SATELLITE STATION (SEE 33013-841)
  - VALVE POSITIONS AT THIS TIME DO NOT REFLECT ALIGNMENT FOR ANY MODE OF OPERATION. THEY ARE SHOWN ONLY TO REPRESENT THE SYSTEM AS-BUILT CONFIGURATION.
  - TAMPER SWITCH V0280T IS NOT CONNECTED ELECTRICALLY.

DESIGNED FOR DCR 87-0217	AND	JEP	JEP	JEP	RMB
DATE	18/14/97	18/28/97	18/28/97	18/28/97	18/28/97
CAD FILE NAME	3P199201				
CONSTRUCTION					
LIMITED CONSTRUCTION AS NOTED					
PRELIMINARY NOT FOR CONSTRUCTION					
ISSUED FOR					
DATE	18/28/97	AS BUILT	JEP		
BY	GINNA STA.	REVISIONS	See & E-Block	Comp.	
SCALE	NONE				
FIRE PROTECTION SYSTEMS					
FIRE SERVICE WATER					
FIRE WATER HEADER					
AUXILIARY BUILDING HEADER					
P&ID					
JOB NO.	DRAWING NO.		REV.		
EWR 3381E	33013-1992-LR		A		
CCD 01	CONTROL COPY #				