



D-71

- NOTES:**
1. FOR GENERAL NOTES SEE DRAWING 33013-2241.
  2. LUBE OIL PIPING ABOVE FLOOR IS LINE SPEC. 150-8 UNLESS INDICATED OTHERWISE. LUBE OIL PIPING BELOW FLOOR IS LINE SPEC. 150-7.
  3. ALL PIPING/TUBING ON THIS DRAWING IS NUCLEAR SAFETY CLASS 3, UNLESS OTHERWISE NOTED.
  4. VENT HOLE ON TOP OF SIGHT GLASS.
  5. AFW PUMPS LUBE OIL PIPING LINE SPEC. 150-8 OR 150-7 WITH THREADED FITTINGS.
  6. AFW PUMPS "A" AND "B" LUBE OIL SKIDS ARE LOCATED IN THE INTERMEDIATE BUILDING, CLEANSIDE BASEMENT WEST END.
  7. ELECTRIC MOTOR EN'S FOR MECHANICAL EQUIPMENT ARE DEPICTED IN BRACKETS ADJACENT TO MECHANICAL EQUIPMENT PER SFWER 10328.
  8. TI-8740, TI-8741, TI-8742, TI-8743, AND TI-8744 ARE STRAIGHT-ON SURFACE CONTACT THERMOMETERS. THESE COMPONENTS ARE NON-NUCLEAR SAFETY CLASS.

DESIGNER	CHKD	REVS	DATE	BY
FOR 2/24/02	1/21/02	2/4/02	2/5/02	2/25/02
CAD FILE NAME	3P228001			
CONSTRUCTION	LIMITED CONSTRUCTION AS NOTED			
PRELIMINARY NOT FOR CONSTRUCTION	BEARING PURPOSES			
DATE	AS BUILT	DATE		
2/5/02				
NAME	RELEASED FOR	DATE		
GINNA STA.	Revisions One & Elements	DATE		
SCALE	NONE	DATE		
MOTOR DRIVEN AND TURBINE DRIVEN AUXILIARY FEEDWATER PUMPS LUBE OIL SKID P & ID				
JOB NO.	DRAWING NO.	REV.		
EWR 3391E	33013-2285-LR	A		
CCD 01	CONTROL COPY #			