



THOSE PORTIONS OF THIS DRAWING WHICH ARE COLORED CYAN INDICATE THAT THE COLORED ITEM IS SUBJECT TO AGING MANAGEMENT REVIEW

D-75

- NOTES:
- FOR GENERAL NOTES SEE DRAWING 33013-2241.
 - ALL PIPING REDUCES TO 3/4" AT SPRINKLER HEADS UNLESS OTHERWISE NOTED.
 - ALL PIPING ON THIS DRAWING IS NON-NUCLEAR SAFETY CLASS.
 - ALL PIPING ON THIS DRAWING IS LINE SPEC. 125-14.

REVISIONS	PER	ADD	DATE	BY	CHK	APP
1	10/2/98	11/16/98	11/16/98	11/16/98		
CONSTRUCTION						
LIMITED CONSTRUCTION AS NOTED						
PRELIMINARY NOT FOR CONSTRUCTION						
ISSUED FOR PERMITS						
DATE	11/16/98	11/16/98	11/16/98	11/16/98		
DATE	11/16/98	11/16/98	11/16/98	11/16/98		
BY	GINNA STA.	ROBINSON	CHIEF	ENGINEER		
SCALE	NONE					
SPRINKLER SYSTEM AT DELUGE VALVE 5233F P & ID						
JOB NO.	33013-2345-LR	DRAWING NO.		REV.		
EWR 3301E						
CCD 01	CONTROL COPY #					

SERVICE BUILDING (NORTHSIDE EL25379)
(S18/13, SERVICE BUILDING SPRINKLER FIRE PROTECTION SYSTEM)