

June 10, 1993

Docket Nos. 50-282
and 50-306

Mr. Roger O. Anderson, Director
Licensing and Management Issues
Northern States Power Company
414 Nicollet Mall
Minneapolis, Minnesota 55401

Dear Mr. Anderson:

SUBJECT: PRAIRIE ISLAND NUCLEAR GENERATING PLANT, UNIT NOS. 1 AND 2 -
CORRECTIONS TO AMENDMENT NOS. 105 AND 98 TO FACILITY OPERATING
LICENSE DPR-42 AND DPR-60 (TAC NOS. M79903 AND M79904)

On May 4, 1993, the Commission issued Amendment No. 105 for Prairie Island
Unit 1 and Amendment No. 98 for Unit 2 in response to your application for
administrative changes dated February 25, 1991, as supplemented February 22,
1993. Erroneously, Technical Specification pages 6.2.1 and 6.7.5, for both
units, were included in the amendments. Enclosed are the correct pages to be
inserted in your Technical Specifications. We regret any inconvenience.

Original signed by

Marsha Gamberoni, Project Manager
Project Directorate III-1
Division of Reactor Projects - III/IV/V
Office of Nuclear Reactor Regulation

Enclosures:

TS page 6.2.1-Unit 1 and 2
TS page 6.7.5-Unit 1 and 2

cc w/enclosures:

See next page

OFFICE	LA:PDIII-1	PM:PDIII-1	(A)PD:PDIII-1
NAME	CJamerson <i>msj</i>	MGamberoni <i>msj</i>	WDean <i>WDean</i>
DATE	6/9/93	6/9/93	6/10/93
COPY	YES/NO	<u>YES</u> /NO	YES/ <u>NO</u>

OFFICIAL RECORD COPY - FILENAME: PI79903.LET

9306150212 930610
PDR ADOCK 05000282
P PDR

WFO
11

Mr. R. Anderson
Northern States Power Company

Prairie Island Nuclear Generating
Plant

cc:

J. E. Silberg, Esquire
Shaw, Pittman, Potts and Trowbridge
2300 N Street, N. W.
Washington DC 20037

Mr. E. L. Watzl, Site General Manager
Prairie Island Nuclear Generating
Plant
Northern States Power Company
Route 2
Welch, Minnesota 55089

Lisa R. Tiegel
Assistant Attorney General
Environmental Protection Division
Suite 200
520 Lafayette Road
St. Paul, Minnesota 55155

U.S. Nuclear Regulatory Commission
Resident Inspector Office
1719 Wakonade Drive
East Welch, Minnesota 55089

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Mr. Jeff Cole, Auditor/Treasurer
Goodhue County Courthouse
Red Wing, Minnesota 55066

Kris Sanda, Commissioner
Director of Public Service
121 Seventh Place East
Suite 200
St. Paul, Minnesota 55101-2145

6.2 Review and Audit

Organizational units for the review and audit of facility operations shall be constituted and have the responsibilities and authorities outlined below:

A. Safety Audit Committee (SAC)

The Safety Audit Committee provides the independent review of plant operations from a nuclear safety standpoint. Audits of plant operation are conducted under the cognizance of the SAC.

1. Membership

- a. The SAC shall consist of at least five (5) persons.
- b. The SAC chairman shall be an NSP representative, not having line responsibility for plant operation, appointed by the Vice President Nuclear Generation. Other SAC members shall be appointed by the Vice President Nuclear Generation or by such other person as he may designate. The Chairman shall appoint a Vice Chairman from the SAC membership to act in his absence.
- c. No more than two members of the SAC shall be from groups holding line responsibility for operation of the plant.
- d. A SAC member may appoint an alternate to serve in his absence, with concurrence of the Chairman. No more than one alternate shall serve on the SAC at any one time. The alternate member shall have voting rights.

2. Qualifications

- a. The SAC members should collectively have the capability required to review activities in the following areas: nuclear power plant operations, nuclear engineering, chemistry and radiochemistry, metallurgy, instrumentation and control, radiological safety, mechanical and electrical engineering, quality assurance practices, and other appropriate fields associated with the unique characteristics of the nuclear power plant.

Prairie Island Unit 1
Prairie Island Unit 2

Amendment No. 13, 49, 6/1, 73
Amendment No. 7, 43, 1/1, 66

XN-NF-77-57 (A), XN-NF-77-57, Supplement 1 (A), "Exxon Nuclear Power Distribution Control for Pressurized Water Reactors Phase II", May, 1981

- c. The core operating limits shall be determined such that all applicable limits (e.g., fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as shutdown margin, and transient and accident analysis limits) of the safety analysis are met.
- d. The CORE OPERATING LIMITS REPORT, including any mid-cycle revisions or supplements thereto, shall be supplied upon issuance, for each reload cycle, to the NRC Document Control Desk with copies to the Regional Administrator and Resident Inspector.

B. REPORTABLE EVENTS

The following actions shall be taken for REPORTABLE EVENTS:

- a. The Commission shall be notified by a report submitted pursuant to the requirements of Section 50.73 to 10 CFR Part 50, and
- b. Each REPORTABLE EVENT shall be reviewed by the Operations Committee and the results of this review shall be submitted to the Safety Audit Committee and the Vice President Nuclear Generation.

6.2 Review and Audit

Organizational units for the review and audit of facility operations shall be constituted and have the responsibilities and authorities outlined below:

A. Safety Audit Committee (SAC)

The Safety Audit Committee provides the independent review of plant operations from a nuclear safety standpoint. Audits of plant operation are conducted under the cognizance of the SAC.

1. Membership

- a. The SAC shall consist of at least five (5) persons.
- b. The SAC chairman shall be an NSP representative, not having line responsibility for plant operation, appointed by the Vice President Nuclear Generation. Other SAC members shall be appointed by the Vice President Nuclear Generation or by such other person as he may designate. The Chairman shall appoint a Vice Chairman from the SAC membership to act in his absence.
- c. No more than two members of the SAC shall be from groups holding line responsibility for operation of the plant.
- d. A SAC member may appoint an alternate to serve in his absence, with concurrence of the Chairman. No more than one alternate shall serve on the SAC at any one time. The alternate member shall have voting rights.

2. Qualifications

- a. The SAC members should collectively have the capability required to review activities in the following areas: nuclear power plant operations, nuclear engineering, chemistry and radiochemistry, metallurgy, instrumentation and control, radiological safety, mechanical and electrical engineering, quality assurance practices, and other appropriate fields associated with the unique characteristics of the nuclear power plant.

Prairie Island Unit 1
Prairie Island Unit 2

Amendment No. 13, 49, 6/1, 73
Amendment No. 7, 43, 1/1, 66

XN-NF-77-57 (A), XN-NF-77-57, Supplement 1 (A), "Exxon Nuclear Power Distribution Control for Pressurized Water Reactors Phase II", May, 1981

- c. The core operating limits shall be determined such that all applicable limits (e.g., fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as shutdown margin, and transient and accident analysis limits) of the safety analysis are met.
- d. The CORE OPERATING LIMITS REPORT, including any mid-cycle revisions or supplements thereto, shall be supplied upon issuance, for each reload cycle, to the NRC Document Control Desk with copies to the Regional Administrator and Resident Inspector.

B. REPORTABLE EVENTS

The following actions shall be taken for REPORTABLE EVENTS:

- a. The Commission shall be notified by a report submitted pursuant to the requirements of Section 50.73 to 10 CFR Part 50, and
- b. Each REPORTABLE EVENT shall be reviewed by the Operations Committee and the results of this review shall be submitted to the Safety Audit Committee and the Vice President Nuclear Generation.

DATED: June 10, 1993

Docket File

NRC & Local PDRs

PDIII-1 Reading

PI Plant File

J. Roe

J. Zwolinski

W. Dean

C. Jamerson

M. Gamberoni

OGC-WF

D. Hagan, (MNBB 3206)

G. Hill (2), P-137

Wanda Jones, (MNBB-3701)

C. Grimes (11/F/23)

M. Biamonte

ACRS (10)

GPA/PA

OC/LFMB

W. Shafer, R-III

cc: Plant Service list