

Lewis Sumner
Vice President
Hatch Project Support

**Southern Nuclear
Operating Company, Inc.**
40 Inverness Parkway
Post Office Box 1295
Birmingham, Alabama 35201

Tel 205.992.7279
Fax 205.992.0341



August 6, 2002

Docket Nos. 50-321
50-366

HL-6285

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

Edwin I. Hatch Nuclear Plant
Monthly Operating Reports

Ladies and Gentlemen:

Enclosed are the July 2002 Monthly Operating Reports for Edwin I. Hatch Nuclear Plant Unit 1, Docket No. 50-321, and Unit 2, Docket No. 50-366. These reports are submitted in accordance with Technical Specifications 5.6.4.

Respectfully submitted,

A handwritten signature in black ink that reads "H. L. Sumner, Jr." in a cursive style.

H. L. Sumner, Jr.

IFL/eb

Enclosures:

1. July Monthly Operating Report for Plant Hatch Unit 1
2. July Monthly Operating Report for Plant Hatch Unit 2

cc: Southern Nuclear Operating Company
Mr. P. H. Wells, Nuclear Plant General Manager
SNC Document Management (R-Type A02.001)

U. S. Nuclear Regulatory Commission, Washington D. C.
Mr. L. N. Olshan, Project Manager - Hatch

U. S. Nuclear Regulatory Commission, Region II
Mr. L. A. Reyes, Regional Administrator
Mr. J. T. Munday, Senior Resident Inspector - Hatch

Utility Data Institute, Inc.
Ms. Barbara Lewis - McGraw-Hill Companies

IE24

Enclosure 1

Plant Hatch Unit 1
Monthly Operating Report
July 2002

Table of Contents

	<u>Page</u>
Operating Data Report	E1-1
Unit Shutdowns and Power Reductions	E1-2

OPERATING DATA REPORT

Docket No.: 50-321
 Unit Name: E. I. Hatch Unit 1
 Date: August 1, 2002
 Completed By: S. B. Rogers
 Telephone: (912) 367-7781 x2279

Operating Status

1. Reporting Period: JULY 2002
 2. Design Electrical Rating (Net MWe): 870
 3. Maximum Dependable Capacity (Net MWe): 856

	<u>This Month</u>	<u>Year To Date</u>	<u>Cumulative</u>
4. Number of Hours Reactor Was Critical:	744.0	4,313.8	186,828.2
5. Hours Generator On Line:	744.0	4,223.6	180,917.2
6. Unit Reserve Shutdown Hours:	0.0	0.0	0.0
7. Net Electrical Energy Generated:	634,762	3,576,602	131,480,739

CHALLENGES TO MAIN STEAM SAFETY / RELIEF VALVES

Date	Tag No.	Event Description
		No challenges this month.

UNIT SHUTDOWNS

Docket No.: 50-321
 Unit Name: E. I. Hatch Unit 1
 Date: August 1, 2002
 Completed By: S. B. Rogers
 Telephone: (912) 367-7781 x2279

Reporting Period: JULY 2002

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason (1)	Method of Shutting Down (2)	Cause/Corrective Actions Comments
						No unit shutdowns occurred this month.

(1) Reason:

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

(2) METHOD

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation
- 5-Other (Explain)

CAUSE/CORRECTIVE ACTION/COMMENTS:

NARRATIVE REPORT

Unit 1 began the month of July operating at rated thermal power. Shift reduced load to approximately 860 GMWe (~2650 CMWT) on 7/6/02 to perform control rod drive exercises. The unit was returned to rated thermal power later the same day. Shift reduced load to approximately 520 GMWe (~1740 CMWT) on 7/12/02 to perform a control rod sequence exchange. Scram time testing, turbine control valve testing, and turbine stop valve testing were also performed while at reduced load. Shift began power ascension on 7/13/02 and the unit attained rated thermal power on 7/14/02. Shift reduced load to approximately 875 GMWe (~2680 CMWT) on 7/17/02 to perform a rod pattern adjustment. The unit was returned to rated thermal power later the same day. Shift reduced load to approximately 860 GMWe (~2705 CMWT) on 7/18/02 due to elevated condensate temperatures and a decrease in main condenser vacuum. The unit was returned to rated thermal power on 7/19/02. Shift reduced load to approximately 855 GMWe (~2650 CMWT) on 7/20/02 to perform control rod drive exercises. The unit was returned to rated thermal power on 7/21/02. Shift reduced load to approximately 855 GMWe (~2645 CMWT) on 7/27/02 to perform control rod drive exercises. The unit was returned to rated thermal power later the same day. Shift maintained unit operation at rated thermal power for the remainder of the month.

Enclosure 2

Plant Hatch Unit 2
Monthly Operating Report
July 2002

Table of Contents

	<u>Page</u>
Operating Data Report	E2-1
Unit Shutdowns and Power Reductions	E2-2

OPERATING DATA REPORT

Docket No.: 50-366
 Unit Name: E. I. Hatch Unit 2
 Date: August 1, 2002
 Completed By: S. B. Rogers
 Telephone: (912) 367-7781 x2279

Operating Status

1. Reporting Period: JULY 2002
 2. Design Electrical Rating (Net MWe): 894
 3. Maximum Dependable Capacity (Net MWe): 870

	<u>This Month</u>	<u>Year To Date</u>	<u>Cumulative</u>
4. Number of Hours Reactor Was Critical:	744.0	4,891.6	162,994.2
5. Hours Generator On Line:	744.0	4,871.8	158,646.9
6. Unit Reserve Shutdown Hours:	0.0	0.0	0.0
7. Net Electrical Energy Generated:	646,387	4,241,676	117,436,292

CHALLENGES TO MAIN STEAM SAFETY / RELIEF VALVES

Date	Tag No.	Event Description
		No challenges this month.

UNIT SHUTDOWNS

Docket No.: 50-366
 Unit Name: E. I. Hatch Unit 2
 Date: August 1, 2002
 Completed By: S. B. Rogers
 Telephone: (912) 367-7781 x2279

Reporting Period: JULY 2002

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason (1)	Method of Shutting Down (2)	Cause/Corrective Actions Comments
						No unit shutdowns occurred this month.

(1) Reason:

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

(2) METHOD

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation
- 5-Other (Explain)

CAUSE/CORRECTIVE ACTION/COMMENTS:

NARRATIVE REPORT

Unit 2 began the month of July operating at rated thermal power. Shift reduced load to approximately 870 GMWe (~2650 CMWT) on 7/7/02 to perform control rod drive exercises. The unit was returned to rated thermal power later the same day. Shift reduced load to approximately 870 GMWe (~2650 CMWT) on 7/14/02 to perform control rod drive exercises. The unit was returned to rated thermal power on 7/15/02. Shift reduced load to approximately 835 GMWe (~2540 CMWT) on 7/21/02 to perform control rod drive exercises. Shift then increased power to approximately 98% of rated thermal and performed turbine stop valve testing. The unit was returned to rated thermal power later the same day. Shift reduced load to approximately 875 GMWe (~2650 CMWT) on 7/28/02 to perform control rod drive exercises. The unit was returned to rated thermal power on 7/29/02. Shift maintained unit operation at rated thermal power for the remainder of the month.