

August 14, 2002

Mr. Alexander Marion, Director
Engineering Department
Nuclear Generator Division
Nuclear Energy Institute
1776 I Street N.W. Suite 400
Washington D.C. 20006-3708

Subject: REQUEST FOR ADDITIONAL INFORMATION REGARDING EXCLUSION OF
FRENCH DATA FROM THE STEAM GENERATOR DEGRADATION SPECIFIC
MANAGEMENT DATABASE

Dear Mr. Marion:

By letter dated July 25, 2002, NEI responded to the NRC staff's questions on excluding the French data from the outside diameter stress corrosion cracking (ODSCC) database.

The NRC staff reviewed NEI's responses and determined that additional analyses are needed to support NEI's proposal to exclude the French data from the database. In particular, analyses demonstrating there is a statistical difference between the French and domestic data are needed. These analyses should include all of the data including the data from the steam generator tubes removed from Beaver Valley Unit 1 and Sequoyah Unit 2. In addition to the above analyses, a discussion on the need to perform periodic confirmatory analyses (including statistical) to confirm that the U.S. data are different than the French data is needed. Such analyses could be provided when the database is updated and would confirm that the two groups of data continue to remain different.

If you have any questions, please contact Louise Lund (301-415-3248) or John Tsao (301-415-2702) of my staff.

Sincerely,

William H. Bateman, Chief */RA/*
Materials and Chemical Engineering Branch
Division of Engineering
Office of Nuclear Reactor Regulation

cc: J. Riley, NEI

Mr. Alexander Marion, Director
Engineering Department
Nuclear Generator Division
Nuclear Energy Institute
1776 I Street N.W. Suite 400
Washington D.C. 20006-3708

Subject: REQUEST FOR ADDITIONAL INFORMATION REGARDING EXCLUSION OF
FRENCH DATA FROM THE STEAM GENERATOR DEGRADATION SPECIFIC
MANAGEMENT DATABASE

Dear Mr. Marion:

By letter dated July 25, 2002, NEI responded to the NRC staff's questions on excluding the French data from the outside diameter stress corrosion cracking (ODSCC) database.

The NRC staff reviewed NEI's responses and determined that additional analyses are needed to support NEI's proposal to exclude the French data from the database. In particular, analyses demonstrating there is a statistical difference between the French and domestic data are needed. These analyses should include all of the data including the data from the steam generator tubes removed from Beaver Valley Unit 1 and Sequoyah Unit 2. In addition to the above analyses, a discussion on the need to perform periodic confirmatory analyses (including statistical) to confirm that the U.S. data are different than the French data is needed. Such analyses could be provided when the database is updated and would confirm that the two groups of data continue to remain different.

If you have any questions, please contact Louise Lund (301-415-3248) or John Tsao (301-415-2702) of my staff.

Sincerely,

William H. Bateman, Chief
Materials and Chemical Engineering Branch
Division of Engineering
Office of Nuclear Reactor Regulation

cc: J. Riley, NEI
Distribution: EMCB RF Kkarwoski EMurphy
ML022260406

INDICATE IN BOX: "C"=COPY W/O ATTACHMENT/ENCLOSURE, "E"=COPY W/ATT/ENCL, "N"=NO COPY

OFFICE	EMCB:DE	EMCB:DE	EMCB:DE
NAME	JTsao:jct	LLund:all	WBateman:whb
DATE	08/13/02	08/13/02	08/14/02

OFFICIAL RECORD COPY