

From: "BYRD, RONALD W" <RBYRD@entergy.com>
To: "twa@nrc.gov" <twa@nrc.gov>
Date: 7/8/02 4:16PM
Subject: Draft response to NRC

Tom,

The below information is provided as a draft response to the question regarding how the operator is informed of LEFM trouble. This information has not been certified nor approved by management.

The LEFM status information is made available to the operator on computer displays in the Control Room. In the event that the LEFM becomes unavailable, a computer trouble message is generated. As a minimum, this message would be observed during core thermal power monitoring which is performed routinely each shift. The operator may then check the computer point information for the LEFM status and confirm that the LEFM is out of service (OOS). There is no immediate action to be taken in response to the LEFM OOS as the allowed outage time for the LEFM is 72 hours and the LEFM being OOS does not cause a change in core thermal power. The computer point information retains the time and date of the LEFM status changes so that the operator could ascertain the time when the OOS condition began and complete the required actions accordingly.

CC: "BURFORD, FRANCIS G" <FBURFOR@entergy.com>

Mail Envelope Properties (3D29F2F4.288 : 2 : 57992)

Subject: Draft response to NRC
Creation Date: 7/8/02 4:15PM
From: "BYRD, RONALD W" <RBYRD@entergy.com>
Created By: RBYRD@entergy.com

Recipients

nrc.gov
owf4_po.OWFN_DO
TWA (Thomas Alexion)

entergy.com
FBURFOR CC (BURFORD, FRANCIS G)

Post Office

owf4_po.OWFN_DO

Route

nrc.gov
entergy.com

Files	Size	Date & Time
MESSAGE	1048	07/08/02 04:15PM
Mime.822	1987	

Options

Expiration Date: None
Priority: Standard
Reply Requested: No
Return Notification: None

Concealed Subject: No
Security: Standard