3.5 LIMITING CONDITION FOR OPERATION	4.5 SURVEILLANCE REQUIREMENT
a. During such 14 days all active components of the HPCI System are operable.	
3. If the requirements of either Specification 3.5.G or Specification 4.5.G.1.c cannot be met, an orderly shutdown shall be initiated and the reactor pressure shall be reduced to ≤ 150 psig within 24 hours.	c. The RCIC System shall deliver at least 400 gpm at normal reactor operating pressure when recirculating to the Condensate Storage Tank.
H. Minimum Core and Containment Cooling System Availability	H. Minimum Core and Containment Cooling System Availability
1. During any period when one of the emergency diesel generators is inoperable, continued reactor operation is permissible only during the succeeding seven days, provided that all of the LPCI, Core Spray and Containment Cooling Subsystems connecting to the operable diesel generator shall be operable. If this requirement cannot be met, an orderly shutdown shall be initiated and the reactor shall be in the cold shutdown condition within 24 hours.	1. When one of the emergency diesel generators is made or found to be inoperable, the remaining diesel generator shall have been or shall be demonstrated to be operable within 24 hours.
2. Any combination of inoperable components in the Core and Containment Cooling Systems shall not defeat the capability of the remaining operable components to fulfill the core and containment cooling functions.	
3. When irradiated fuel is in the reactor vessel and the reactor is in either a refueling or cold shutdown condition, all Core and Containment Cooling Subsystems may be inoperable provided no work is permitted which has the potential for draining the reactor vessel.	