


# Tennessee Valley Authority Browns Ferry Nuclear Plant Units 2 and 3 Extended Power Uprate



TVA/NRC Meeting  
Nuclear Reactor Regulation - Rockville MD  
July 10, 2002

Enclosure 2



# Agenda

---

- ◆ **Introduction/Meeting Objectives**
- ◆ **Background**
- ◆ **Project Overview**
- ◆ **Submittal Content**
- ◆ **Applicability of Methodology to BFN**
- ◆ **Summary and Conclusion**

# Introduction/Meeting Objectives

---

- ♦ **Introduction**
- ♦ **Meeting Objectives**
  - **Describe Submittal Content**
  - **Discuss Other Required Changes to Licensing Basis**
  - **Provide Basis for Applicability of Constant Pressure Power  
Uprate Methodology to BFN**

## **Background**

---


- ♦ **TVA Board of Directors Approved Extended Power Uprate Project for Browns Ferry Units 2 and 3 in March of 2001**
- ♦ **TVA Met with NRC Staff December 5, 2001, to Describe the Extended Power Uprate Project and Schedule**
- ♦ **Submittal in Final Approval**
  - **Uses GE Constant Pressure Power Uprate (CLTR) Methodology**
  - **Incorporates Applicable RAI Questions from Previous Extended Power Uprates**

## **Background (Cont.)**

---

- ♦ **TVA Considered Environmental Impacts of Operation of all 3 BFN Units at 120% of Original Licensed Power for License Renewal Term and Issued Supplemental Environmental Impact Statement (SEIS)**
  - **Public Meetings Held March 6, 2001 and January 17, 2002**
  - **Draft SEIS Published in Federal Register December 14, 2001**
  - **TVA Board Record of Decision Published in Federal Register June 18, 2002**

# Project Overview



Ed Hartwig

## Submittal Content

---

- ♦ **Consistent with Content and Level of Detail of GE Licensing Topical Report for Constant Pressure Power Uprate**
  - **Will Justify Exclusion of Large Transient Testing**
  - **Will Request Credit for Containment Overpressure for ECCS Suction NPSH**
- ♦ **Other Changes to Licensing Basis**
  - **Revised P/T Curves (Separate Submittal)**
  - **Alternative Source Term (Separate Submittal)**

## **Applicability Of Methodology to BFN**

---

- ♦ **BFN Analysis Supports Uprate to 3952 MWt**
- ♦ **Industry Experience in 1970s**
  - **Little Large Plant Experience**
  - **Rapid Plant Growth**
    - **BWR2 - 640 MWe (1969)**
    - **BWR3 - 850 MWe (1971)**
    - **BWR4 - 1100 MWe (1974)**
    - **BWR5 - 1150 MWe (planned)**
    - **BWR6 - 1500 MWe (planned)**
  - **Planned Plants Exceeded Rotating Equipment Experience Base**



## **Applicability Of Methodology to BFN (Cont)**

- ♦ **NRC Reg Guide 1.49 Revision 0 - May 1973**
  - **Construction Permit Applications Limited to 3800 MWt**
  - **Ultimate Power Level Limited to 4100 MWt**
  - **Limitation Applies Until Sufficient Experience Gained with Design, Construction, and Operation of Larger Plants**

## **Applicability Of Methodology to BFN (Cont)**

- ♦ **NRC Reg Guide 1.49 Revision 1 - December 1973.**
  - **Construction Permit Applications Limited to 3800 MWt Until January 1, 1979, at Earliest**
  - **2% Allowance in Power Level Adequate for Instrument Errors (Maximum of 3876 MWt)**
  - **Radiological Analyses Limited to 4100 MWt**
  - **Acceptability to Increase Maximum Licensed Power Level to be Carefully Reviewed**

## **Applicability Of Methodology to BFN (Cont)**

---



- ♦ **Operating Experience Supports Power Uprates up to 20%**
- ♦ **Power Urate Methodology Approved**
  - **ELTR (February 1996)**
  - **CLTR (June 2002)**
- ♦ **After Power Uprates, Large Plants Will Exceed 3800 MWt**
- ♦ **Operating Experience Base**
  - **Numerous Plants Licensed Power > 3200 MWt**
    - **About 30 Years of Operation at the Oldest Facilities**
    - **No Safety or Operational Problems Attributed to Plant Size**
    - **Plants are Currently Licensed and Operating at a Higher Power Density than Browns Ferry After EPU**

## **Applicability Of Methodology to BFN (Cont)**

---



- ♦ **Browns Ferry Uprate Power Density = 60.3 kw/l**
- ♦ **Currently Licensed Power Density (GE14 Fuel)**
  - **BWR3 = 42.2 kw/l**
  - **BWR4 = 60.9 kw/l**
  - **BWR6 = 64.9 kw/l**
- ♦ **Maximum Operating = 65.6 kw/l (Foreign Plant)**
- ♦ **GE Analysis Methodology**
  - **Methods Used Documented in PUSAR**
  - **Code Limitations and Restrictions Observed**
  - **Appropriate Use Confirmed**
  - **Power Uprate Audits Performed by NRC**
- ♦ **No LTR or SER Limitations on Core Power Level**
- ♦ **Methodology LTRs or SERs Specify Limits on Range of Applicability for Correlations**

## **Applicability Of Methodology to BFN (Cont)**

---

- ♦ **GE Analysis Methodology**
  - **Safety Analyses Consistent with 102% Power Requirement**
  - **Increase in Power Does Not Significantly Change Plant Response**
  - **Increase in Decay Heat Well Defined**
  - **Thermal-Hydraulic Conditions (Pressures, Temperatures, Flows, Void Fractions) Remain Within Experience Base**
  - **Thermal-Hydraulic Conditions Controlled by GEXL Correlation**
    - **NRC Approved**
    - **Not Changed for Changes in Core Power Level**
  - **Limitations on Bundle Power (MAPLHGR, LHGR and MCPR) Constrain Plant Operation**

## **Applicability Of Methodology to BFN (Cont)**

---

- ♦ **Reg Guide 1.49 Constrains Construction Permit Applications**
- ♦ **Substantial Body of Safe and Reliable Operation of Large Plants**
- ♦ **Analysis Methodology Applicable Above 3800 MWt**
- ♦ **Fuel Operating Limitations Appropriate**
- ♦ **No Technical Limitations Identified**
- ♦ **License Submittal Provides Comprehensive Evaluations**

# Summary and Conclusion

---