



Entergy Nuclear Northeast

Entergy Nuclear Operations, Inc.
Vermont Yankee
322 Governor Hunt Rd.
P.O. Box 157
Vernon, VT 05354
Tel 802-257-7711

August 08, 2002
BVY-02-58

United States Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Reference: (a) License No. DPR-28 (Docket No. 50-271)

In accordance with section 6.6.B of the Vermont Yankee Technical Specifications,
submitted herewith is the Monthly Statistical Report for the Vermont Yankee Nuclear
Power Station for the month of July, 2002.

Sincerely,

A handwritten signature in cursive script that reads "Kevin H. Bronson".

Kevin H. Bronson
General Manager, Plant Operations

cc: USNRC Region I Administrator
USNRC Resident Inspector
USNRC Project Manager

IE-24

VERMONT YANKEE NUCLEAR POWER STATION

MONTHLY STATISTICAL REPORT 02-07

FOR THE MONTH OF JULY 2002

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-271
 UNIT Vermont Yankee
 DATE 020808
 COMPLETED BY G.A. WALLIN
 TELEPHONE (802)258-5414

MONTH July

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1.	420	17.	508
2.	508	18.	494
3.	512	19.	502
4.	509	20.	506
5.	505	21.	509
6.	506	22.	506
7.	506	23.	508
8.	505	24.	504
9.	507	25.	503
10.	507	26.	505
11.	508	27.	495
12.	508	28.	479
13.	506	29.	499
14.	501	30.	502
15.	504	31.	497
16.	505		

INSTRUCTIONS:

On this format, list the average daily unit power level in MWE-Net for each day in the reporting month. Compute to the nearest whole megawatt.

VYDPF 0411.02 (Sample)
 DP 0411 Rev. 8
 Page 1 of 1
 RT No. 13.F01.18V

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH JULY

DOCKET NO 50-271
 UNIT NAME Vermont Yankee
 DATE 020808
 COMPLETED BY G.A. Wallin
 TELEPHONE (802)258-5414

No.	Date	1 Type	Duration (hours)	2 Reason	3 Method of Shutting Down Reactor	License Event Report #	4 System Code	5 Component Code	Cause and Corrective Action to Prevent Recurrence
(None)									

1 F: Forced
 S: Scheduled

2 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training and
 License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-(Explain)

3 Method:
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Other (Explain)

4 Exhibit G- Instructions
 for Preparation of Data
 Entry Sheets for License
 Event Report (LER) File
 (NUREG 0161)

5 Exhibit I - Same Source

DOCKET NO. 50-271
DATE 020808
COMPLETED BY G.A. WALLIN
TELEPHONE (802)258-5414

REPORT MONTH July

SUMMARY OF OPERATING EXPERIENCES

Highlights

Vermont Yankee operated at 99.1 of rated thermal power for the month. Gross electrical generation was 395,046 MWh or 97.2% design electrical capacity.

Operating Summary

The following is a chronological description of plant operations including other pertinent items of interest for the month:

At the beginning of the reporting period the plant was operating at 82.2% of rated thermal power.

There were no items of interest to report for this month.

At the end of the reporting period the plant was operating at 99.9% of rated thermal power.

VYDPF 0411.04 (Sample)
DP 0411 Rev. 8
Page 1 of 1
RT No. 13.F01.18X