

SEP 7 1982

Docket No: 50-361

Mr. Robert Dietch  
Vice President  
Southern California Edison Company  
2244 Walnut Grove Avenue  
Post Office Box 800  
Rosemead, California 91770

Mr. Gary D. Cotton  
Mr. Louis Bernath  
San Diego Gas & Electric Company  
101 Ash Street  
Post Office Box 1831  
San Diego, California 92112

Gentlemen:

Subject: Issuance of Amendment No. 7 to Facility Operating License NPF-10  
San Onofre Nuclear Generating Station, Unit 2

The Nuclear Regulatory Commission has issued Amendment No. 7 to Facility Operating License NPF-10 for the San Onofre Nuclear Station, Unit 2, located in San Diego County, California.

This amendment authorizes operation at power levels up to 100 percent of full rated power, 3390 thermal megawatts. This amendment also contains changes to the license and the Appendix A Technical Specifications which (1) modify the operability requirements for fire detection instrumentation (as requested by your letters of July 9 and July 12, 1982), (2) extend the implementation date for the environmental qualification surveillance program, (3) add emergency preparedness conditions, (4) require performance of a study of rapid depressurization and decay heat removal, and (5) impose a requirement on qualification of auxiliary feedwater pump motor bearings.

A copy of Amendment No. 7 is enclosed. Also enclosed are copies of the safety evaluation supporting Amendment No. 7 to Facility Operating License NPF-10 and the related notice which has been forwarded to the Office of the Federal Register for publication. Appendices B and C to the original license remain unchanged, and are not included with this Amendment.

Sincerely,

Original Signed By:

Darrell G. Eisenhut, Director  
Division of Licensing

Enclosures:

1. Amendment No. 7
2. Safety Evaluation
3. Federal Register Notice

cc w/enclosure:

8209100078 820907  
PDR ADDCK 05000361  
P PDR

NO04