

Lewis Sumner
Vice President
Hatch Project Support

**Southern Nuclear
Operating Company, Inc.**
40 Inverness Parkway
Post Office Box 1295
Birmingham, Alabama 35201

Tel 205.992.7279
Fax 205.992.0341



August 9, 2002

Docket Nos. 50-321
50-366

HL-6281

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Edwin I. Hatch Nuclear Plant
Emergency Implementing Procedure Revision

Ladies and Gentlemen:

In accordance with 10 CFR 50, Appendix E, Section V, Southern Nuclear Operating Company hereby submits the following revision to the Plant Hatch Emergency Implementing Procedure (EIP):

<u>EIP No.</u>	<u>Version</u>	<u>Effective Date</u>
73EP-EIP-022-0	3.0	07/12/02

This revision incorporates comments identified during our review of the interim compensatory measures (ICMs) and other editorial changes.

By copy of this letter, Mr. L. A. Reyes, NRC Region II Administrator, will receive two copies of the revised procedure.

Should you have any questions in this regard, please contact this office.

Respectfully submitted,

A handwritten signature in black ink, appearing to read "H. L. Sumner, Jr.", written in a cursive style.

H. L. Sumner, Jr.

CKB/eb

Enclosure: 73EP-EIP-022-0, Alternate Emergency Operations Facility (EOF) Activation

A045

U.S. Nuclear Regulatory Commission

Page 2

August 9, 2002

cc: Southern Nuclear Operating Company (w/o)
Mr. P. H. Wells, Nuclear Plant General Manager
SNC Document Management (R-Type A02.001)

U.S. Nuclear Regulatory Commission, Washington, D.C. (w/o)
Mr. L. N. Olshan, Project Manager - Hatch

U.S. Nuclear Regulatory Commission, Region II
Mr. L. A. Reyes, Regional Administrator (with 2 copies)
Mr. J. T. Munday, Senior Resident Inspector – Hatch (w/o)

SOUTHERN NUCLEAR PLANT E.I. HATCH		DOCUMENT TYPE: EMERGENCY PREPAREDNESS PROCEDURE	PAGE 1 OF 4
DOCUMENT TITLE: ALTERNATE EMERGENCY OPERATIONS FACILITY (EOF) ACTIVATION		DOCUMENT NUMBER: 73EP-EIP-022-0	REVISION/VERSION NO: 3.0
EXPIRATION DATE:	APPROVALS: DEPARTMENT MANAGER J. C. Lewis DATE 7/23/2002		EFFECTIVE DATE: 7/30/2002
N/A	NPGM/POAGM/PSAGM J. A. Betsill DATE 7/26/2002		

1.0 **OBJECTIVE**

This procedure addresses AND delineates the actions required to bring the alternate EOF to a state of functional readiness and provides guidelines for staffing the facility. The alternate EOF will be activated in the event either the primary EOF must be relocated and/or the primary EOF can not be activated. Plant Management may determine it necessary to activate this facility, as appropriate, to communicate with the plant to monitor plant activities, as needed.

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
2.0	APPLICABILITY	1
3.0	REFERENCES	1
4.0	REQUIREMENTS	2
5.0	PRECAUTIONS/LIMITATIONS	2
6.0	PREREQUISITES	3
7.0	PROCEDURE	3

2.0 **APPLICABILITY**

This procedure is applicable to personnel AND activities regarding activation AND operation of the Alternate EOF during an emergency condition, drill AND/OR exercise. Frequency of use will be as necessary.

3.0 **REFERENCES**

- 3.1 NUREG 0737, Supplement I, "Requirements for Emergency Response Capability"
- 3.2 10AC-MGR-006-0, Hatch Emergency Plan
- 3.3 Edwin I. Hatch Unit 1 and Unit 2 Emergency Plan
- 3.4 73EP-EIP-015-0, Offsite Dose Assessment

DOCUMENT TITLE:
ALTERNATE EMERGENCY OPERATIONS FACILITY
(EOF) ACTIVATION

DOCUMENT NUMBER:
73EP-EIP-022-0

REVISION/VERSION
NO:
3.0

3.5 FULL SIZE FORMS

- TRN-0016, Alternate EOF Communications Checks
- TRN-0072, Plant Parameters
- TRN-0073, Major Events/Inop Equipment
- TRN-0085, Field Team Data
- TRN-0086, Meteorological/Radiological Data
- TRN-0153, Emergency Response Facility Sign-In Sheet
- TRN-0154, Protective Action Status

4.0 REQUIREMENTS

4.1 PERSONNEL REQUIREMENTS

- 4.1.1 Qualified Emergency Response personnel who normally activate the primary EOF are required to perform this procedure.
- 4.1.2 The EOF Manager or designee will be responsible for ensuring completion of this procedure.
- 4.1.3 The Emergency Director may operate from the Control Room, the TSC, or the EOF at his discretion. Emergency Director duties may be transferred to the Alternate EOF as deemed appropriate by plant management.

4.2 MATERIALS AND EQUIPMENT

N/A – Not applicable to this procedure

4.3 SPECIAL REQUIREMENTS

The Alternate EOF is located in Vidalia, Ga. at the Emergency News Center Complex as shown in Attachment 1. This facility will be activated as necessary in the event either the primary EOF must be relocated and/or the primary EOF can not be activated. Plant Management may determine it necessary to activate this facility, as appropriate, to communicate with the plant to monitor plant activities, as needed.

5.0 PRECAUTIONS/LIMITATIONS

N/A – Not applicable to this procedure

SOUTHERN NUCLEAR PLANT E.I. HATCH		PAGE 3 OF 4
DOCUMENT TITLE: ALTERNATE EMERGENCY OPERATIONS FACILITY (EOF) ACTIVATION	DOCUMENT NUMBER: 73EP-EIP-022-0	REVISION/VERSION NO: 3.0

6.0 PREREQUISITES

Facility Management will determine resources needed for the alternate EOF to perform its intended function prior to activation.

REFERENCE

NOTE:

This procedure is intended to be used as guidance for activating the alternate EOF, as necessary, in emergency situations. Deviations from the listed sequence are permitted WHEN conditions warrant a more expedient order of completion.

7.0 PROCEDURE

- 7.1 Upon arrival at the Emergency News Center (ENC) complex, emergency response personnel will take the following actions to establish alternate EOF activation:
 - 7.1.1 Establish access control and personnel sign-in at the ENC entrance.
 - 7.1.2 Set up the alternate EOF, referring to the posted typical layout of the facility.
 - 7.1.3 Facility Management will determine applicable emergency response personnel needed to provide support to the alternate EOF.
 - 7.1.4 Perform a communications check utilizing form TRN-0016, Alternate EOF Communication check.
 - 7.1.5 Prepare to assume offsite notification activities as directed by the Emergency Director.
 - 7.1.6 Set-up the Dose Assessment computer in accordance with 73EP-EIP-015-0, Dose Assessment, and establish its operability. Prepare to assume dose assessment activities as directed by the Emergency Director.
 - 7.1.7 Establish radiological monitoring of all incoming personnel, as directed by the Dose Assessment Manager.
 - 7.1.8 Synchronize facility clocks with the Control Room.
 - 7.1.9 Establish communications with the TSC, Control Room, and State and local authorities, as appropriate. Inform all parties when the Alternate EOF is activated.

DOCUMENT TITLE:
ALTERNATE EMERGENCY OPERATIONS FACILITY
(EOF) ACTIVATION

DOCUMENT NUMBER:
73EP-EIP-022-0

Rev/Ver No:
3.0

ATTACHMENT 1

TITLE: DIRECTIONS TO THE ALTERNATE EOF

Att. Pg.
1 of 1

