

OCT 15 1984

MEMORANDUM FOR: James R. Miller, Chief
Operating Reactors Branch No. 3
Division of Licensing

FROM: George W. Knighton, Chief
Licensing Branch No. 3
Division of Licensing

SUBJECT: REQUEST FOR PUBLICATION IN MONTHLY FR NOTICE - NOTICE OF
ISSUANCE OF AMENDMENTS TO FACILITY OPERATING LICENSE

Southern California Edison Company, et al, Docket Nos. 50-361 and 50-362,
San Onofre Nuclear Generating Station, Units 2 and 3, San Diego County,
California

Date of application for amendment: July 23, August 16 and December 17, 1982;
January 28, 1983; January 25 and April 13, 1984

Brief description of amendment: Modification to change the maximum surveillance
interval for 23 ESFAS subgroup relays from 6 months to 18 months.

Date of issuance: September 24, 1984

Amendment Nos.: 24 and 13

Facility Operating License No. NPF-10 and NPF-15: Amendment revised the
Technical Specifications.

Date of initial notice in Federal Register: June 20, 1984 (49 F. R. 25375)

The Commission's related evaluation of the amendment is contained in a Safety
Evaluation dated September 24, 1984. No significant hazards consideration
comments were received.

8411020159 841015
PDR ADOCK 05000361
P PDR

Local Public Document Room Location: San Clemente Library, 242 Avenida Del
Mar, San Clemente, California.

George W. Knighton, Chief
Licensing Branch No. 3
Division of Licensing

cc: P. Kreutzer

DISTRIBUTION

Docket File 50-361/362

NRC PDR

LPDR

PRC System

NSIC

HDenton

DEisenhut

HRood

JLee (2)

DL:LB#3
JLee/yt
9/5/84

DL:LB#3
HRood
9/25/84

OELD
LChandler
9/14/84

DL:LB#3
GWKnighton
9/24/84