

SEP 21 1984

MEMORANDUM FOR: James R. Miller, Chief
Operating Reactors Branch No. 3
Division of Licensing

FROM: George W. Knighton, Chief
Licensing Branch No. 3
Division of Licensing

SUBJECT: REQUEST FOR PUBLICATION IN MONTHLY FR NOTICE - NOTICE OF
ISSUANCE OF AMENDMENTS TO FACILITY OPERATING LICENSE

Southern California Edison Company, et al. Docket Nos. 50-361 and 50-362,
San Onofre Nuclear Generating Station, Units 2 and 3, San Diego County,
California

Dates of application for amendments: December 1, 1982, January 6, January 25,
April 15, August 1 and December 5, 1983

Brief description of amendments: The amendments modify the Technical Specifications to (1) change certain ESFAS response times for Units 2 and 3, (2) temporarily suspend specification 3.0.4 to allow Unit 2 to be heated up prior to the hot setting of the pressurizer code safety valve, (3) reflect the installation of additional fire protection equipment for Unit 2 and (4) correct an error in the Technical Specifications for Units 2 and 3 relating to the groups and individuals required to review revisions and modifications to the Monthly Operating Report, Offsite Dose Calculations Manual, Process Control Program and Major Changes to Radioactive Waste Treatment Systems by the Onsite Review Committee.

8410260243 840921
PDR ADOCK 05000361
PDR

Date of issuance: September 21, 1984

Amendment Nos.: 25 and 14

Facility Operating License Nos. NPF-10 and NPF-15: Amendment revised the Technical Specifications.

Dates of initial notices in Federal Register: April 25, 1984 (49 F.R. 17874) and February 24, 1984 (49 F.R. 7043). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated September 21, 1984. No significant hazards consideration comments were received.

Local Public Document Room Location: San Clemente Library, 242 Avenida Del Mar, San Clemente, California.

151

George W. Knighton, Chief
Licensing Branch No. 3
Division of Licensing

cc: P. Kreutzer

DISTRIBUTION

Docket File 50-361/362

- NRC PDR
- Local PDR
- PRC System
- NSIC
- LB#3 Reading
- HDenton
- DGEisenhut
- HRood
- JLee (2)

DL:LB#3
JLee/yt
6/21/84

HR
DL:LB#3
HRood
9/12/84

On approval of change of notice
OELD
7/9/84

DL:LB#3
GWRKnighton
7/18/84