

Docket Nos.: 50-361
50-362

Mr. Kenneth P. Baskin
Vice President
Southern California Edison Company
2244 Walnut Grove Avenue
Post Office Box 800
Rosemead, California 91770

Mr. James C. Holcombe
Vice President - Power Supply
San Diego Gas & Electric Company
101 Ash Street
Post Office Box 1831
San Diego, California 92112

Gentlemen:

Subject: Issuance of Amendment No.35 to Facility Operating License NPF-10
and Amendment No. 24 to Facility Operating License NPF-15
San Onofre Nuclear Generating Station, Units 2 and 3

The Nuclear Regulatory Commission (the Commission) has issued the enclosed Amendment No. 35 to Facility Operating License No. NPF-10 and Amendment No. 24 to Facility Operating License No. NPF-15 for the San Onofre Nuclear Generating Station, Units 2 and 3, located in San Diego County, California. The amendments modify the Technical Specification 3.2.6, "Reactor Coolant Cold Leg Temperature," concerning cold leg temperature limits at power levels less than 70%.

These amendments were requested by your letter of October 11, 1984 and are covered by Proposed Change Number PCN-149.

A copy of the Safety Evaluation supporting the amendments is also enclosed.






Sincerely,

George W. Knighton, Chief
Licensing Branch No. 3
Division of Licensing

Enclosure:

1. Amendment No. 35 to NPF-10
2. Amendment No. 24 to NPF-15
3. Safety Evaluation

cc w/enclosures: See next page

 LB#3/DL JLee 8/19/85	 LB#3/DL HRood:dh 8/19/85	 OELD 8/19/85	 LB#3/DL GKnighton 8/19/85	 AD/1/DL TMNoyak 8/24/85
---	---	--	--	---

Mr. Kenneth P. Baskin
Southern California Edison Company

San Onofre Nuclear Generating Station
Units 2 and 3

cc:

Mr. James C. Holcombe
Vice President - Power Supply
San Diego Gas & Electric Company
101 Ash Street
Post Office Box 1831
San Diego, California 92112

Mr. Hans Kaspar, Executive Director
Marine Review Committee, Inc.
531 Encinitas Boulevard, Suite 105
Encinitas, California 92024

Charles R. Kocher, Esq.
James A. Beoletto, Esq.
Southern California Edison Company
2244 Walnut Grove Avenue
P. O. Box 800
Rosemead, California 91770

Mr. Mark Medford
Southern California Edison Company
2244 Walnut Grove Avenue
P. O. Box 800
Rosemead, California 91770

Orrick, Herrington & Sutcliffe
ATTN: David R. Pigott, Esq.
600 Montgomery Street
San Francisco, California 94111

Dr. L. Bernath
Manager, Nuclear Department
San Diego Gas & Electric Company
P. O. Box 1831
San Diego, California 92112

Alan R. Watts, Esq.
Rourke & Woodruff
Suite 1020
1055 North Main Street
Santa Ana, California, 92701

Richard J. Wharton, Esq.
University of San Diego School of
Law
Environmental Law Clinic
San Diego, California 92110

Mr. V. C. Hall
Combustion Engineering, Inc.
1000 Prospect Hill Road
Windsor, Connecticut 06095

Charles E. McClung, Jr., Esq.
Attorney at Law
24012 Calle de la Plaza/Suite 330
Laguna Hills, California 92653

Mr. S. McClusky
Bechtel Power Corporation
P. O. Box 60860, Terminal Annex
Los Angeles, California 90060

Regional Administrator, Region V
U.S. Nuclear Regulatory Commission
1450 Maria Lane/Suite 210
Walnut Creek, California 94596

Mr. C. B. Brinkman
Combustion Engineering, Inc.
7910 Woodmont Avenue
Bethesda, Maryland 20814

Resident Inspector, San Onofre NPS
c/o U. S. Nuclear Regulatory Commission
Post Office Box 4329
San Clemente, California 92672

Mr. Dennis F. Kirsh
U.S. Nuclear Regulatory Commission - Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596

Southern California Edison Company - 2 - San Onofre 2/3

cc:

California State Library
Government Publications Section
Library & Courts Building
Sacramento, CA 95841
ATTN: Ms. Mary Schnell

Mayor, City of San Clemente
San Clemente, CA 92672

Chairman, Board Supervisors
San Diego County
1600 Pacific Highway, Room 335
San Diego, CA 92101

California Department of Health
ATTN: Chief, Environmental
Radiation Control Unit
Radiological Health Section
714 P Street, Room 498
Sacramento, CA 95814

Mr. Joseph O. Ward, Chief
Radiological Health Branch
State Department of Health Services
714 P Street, Building #8
Sacramento, California 95814



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SOUTHERN CALIFORNIA EDISON COMPANY

SAN DIEGO GAS AND ELECTRIC COMPANY

THE CITY OF RIVERSIDE, CALIFORNIA

THE CITY OF ANAHEIM, CALIFORNIA

DOCKET NO. 50-361

SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 35
License No. NPF-10

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the license for San Onofre Nuclear Generating Station, Unit 2 (the facility) filed by the Southern California Edison Company on behalf of itself and San Diego Gas and Electric Company, The City of Riverside and the City of Anaheim, California (licensees) dated October 11, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public;
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. NPF-10 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 35, are hereby incorporated in the license. SCE shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This amendment is effective immediately and is to be fully implemented within 30 days of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



George W. Knighton, Chief
Licensing Branch No. 3
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: September 25, 1985

ATTACHMENT TO LICENSE AMENDMENT NO. 35

FACILITY OPERATING LICENSE NO. NPF-10

DOCKET NO. 50-361

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. Also to be replaced are the following overleaf pages to the amended pages.

Amendment Pages

3/4 2-10

Overleaf Pages

3/4 2-9

POWER DISTRIBUTION LIMITS

3/4.2.5 RCS FLOW RATE

LIMITING CONDITION FOR OPERATION

3.2.5 The actual Reactor Coolant System total flow rate shall be greater than or equal to 148×10^6 lbm/hr, and less than or equal to 177.6×10^6 lbm/hr.

APPLICABILITY: MODE 1.

ACTION:

With the actual Reactor Coolant System total flow rate determined to be outside the above limits, reduce THERMAL POWER to less than 5% of RATED THERMAL POWER within the next 4 hours.

SURVEILLANCE REQUIREMENTS

4.2.5 The actual Reactor Coolant System total flow rate shall be determined to be within its limit at least once per 12 hours.

POWER DISTRIBUTION LIMITS

REACTOR COOLANT COLD LEG TEMPERATURE

LIMITING CONDITION FOR OPERATION

3.2.6 The Reactor Coolant Cold Leg Temperature (T_c) shall be maintained within:

- a) $535^{\circ}\text{F} \leq T_c \leq 558^{\circ}\text{F}$ for less than or equal to 70% of RATED THERMAL POWER
- b) $544^{\circ}\text{F} \leq T_c \leq 558^{\circ}\text{F}$ for greater than 70% RATED THERMAL POWER.

APPLICABILITY: MODE 1 above 30% of RATED THERMAL POWER.

ACTION:

With the Reactor Coolant Cold Leg Temperature exceeding its limit, restore the temperature to within its limit within 2 hours or reduce THERMAL POWER to less than 30% of RATED THERMAL POWER within the next 4 hours.

SURVEILLANCE REQUIREMENTS

4.2.6 The Reactor Coolant Cold Leg Temperature shall be determined to be within its limit at least once per 12 hours.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SOUTHERN CALIFORNIA EDISON COMPANY

SAN DIEGO GAS AND ELECTRIC COMPANY

THE CITY OF RIVERSIDE, CALIFORNIA

THE CITY OF ANAHEIM, CALIFORNIA

DOCKET NO. 50-362

SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 24
License No. NPF-15

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the license for San Onofre Nuclear Generating Station, Unit 3 (the facility) filed by the Southern California Edison Company on behalf of itself and San Diego Gas and Electric Company, The City of Riverside and the City of Anaheim, California (licensees), dated October 11, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public;
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. NPF-15 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 24, are hereby incorporated in the license. SCE shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This amendment is effective immediately and is to be fully implemented within 30 days of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



George W. Knighton, Chief
Licensing Branch No. 3
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: September 25, 1985

- 3 -

ATTACHMENT TO LICENSE AMENDMENT NO. 24

FACILITY OPERATING LICENSE NO. NPF-15

DOCKET NO. 50-362

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. Also to be replaced are the following overleaf pages to the amended pages.

Amendment Pages

3/4 2-10

Overleaf Pages

3/4 2-9

POWER DISTRIBUTION LIMITS

3/4.2.5 RCS FLOW RATE

LIMITING CONDITION FOR OPERATION

3.2.5 The actual Reactor Coolant System total flow rate shall be greater than or equal to 148×10^6 lbm/hr, and less than or equal to 177.6×10^6 lbm/hr.

APPLICABILITY: MODE 1.

ACTION:

With the actual Reactor Coolant System total flow rate determined to be outside the above limits, reduce THERMAL POWER to less than 5% of RATED THERMAL POWER within the next 4 hours.

SURVEILLANCE REQUIREMENTS

4.2.5 The actual Reactor Coolant System total flow rate shall be determined to be within its limit at least once per 12 hours.

POWER DISTRIBUTION LIMITS

REACTOR COOLANT COLD LEG TEMPERATURE

LIMITING CONDITION FOR OPERATION

- 3.2.6 The Reactor Coolant Cold Leg Temperature (T_c) shall be maintained within:
- a) $535^{\circ}\text{F} \leq T_c \leq 558^{\circ}\text{F}$ for less than or equal to 70% of RATED THERMAL POWER
 - b) $544^{\circ}\text{F} \leq T_c \leq 558^{\circ}\text{F}$ for greater than 70% RATED THERMAL POWER.

APPLICABILITY: MODE 1 above 30% of RATED THERMAL POWER.

ACTION:

With the Reactor Coolant Cold Leg Temperature exceeding its limit, restore the temperature to within its limit within 2 hours or reduce THERMAL POWER to less than 30% of RATED THERMAL POWER within the next 4 hours.

SURVEILLANCE REQUIREMENTS

4.2.6 The Reactor Coolant Cold Leg Temperature shall be determined to be within its limit at least once per 12 hours.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION

AMENDMENT NO. 35 TO NPF-10

AMENDMENT NO. 24 TO NPF-15

SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 & 3

DOCKET NOS. 50-361 AND 50-362

Introduction

Southern California Edison Company (SCE), on behalf of itself and the other licensees, San Diego Gas and Electric Company, the City of Riverside, California, and The City of Anaheim, California, has submitted several applications for license amendments for San Onofre Nuclear Generating Station, Units 2 and 3.

One such request, Proposed Change Number 149, or PCN-149, dated October 11, 1984, involves changes to Technical Specification (T.S.) 3.2.6, "Reactor Coolant Cold Leg Temperature - Limiting Condition for Operation."

This T.S. requires that the reactor coolant cold leg temperature (T_c) be maintained between 544°F and 558°F when in Mode 1, above 30% of rated thermal power. This limiting condition for operation ensures that the cold leg temperature is maintained within the limits assumed in the accident analyses. The proposed change would reduce the lower limit on cold leg temperature from 544°F to 535°F for power levels greater than 30% and less than or equal to 70% of rated thermal power. The proposed change provides additional operational flexibility for plant maneuvering.

Evaluation

The licensee has reevaluated the San Onofre 2 and 3 accident analyses in light of the proposed change. Reducing the cold leg temperature was determined to adversely affect the consequences of loss of heat sink and large break LOCA. Upon reevaluation, the licensee determined that the reduced power level and core stored energy at 70% power operation and below more than compensated for the effect of the lowered cold leg temperature. The staff concludes that the licensee's proposed revision is acceptable, because the limiting accidents remain within the acceptance criteria of Section 15 of the Standard Review Plan (NUREG-0800).

Contact With State Official

The NRC staff has advised the Chief of the Radiological Health Branch, State Department of Health Services, State of California, of the proposed determinations of no significant hazards consideration. No comments were received.

8510110268 850924
PDR ADOCK 05000361
P PDR

Environmental Consideration

These amendments involve changes in the installation or use of facility components located within the restricted area. The staff has determined that the amendments involve no significant increase in the amounts of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupation radiation exposure. The Commission has previously issued proposed findings that the amendments involve no significant hazards consideration, and there has been no public comment on such findings. Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR Sec. 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need to be prepared in connection with the issuance of these amendments.

Conclusion

Based upon our evaluation of the proposed changes to the San Onofre Units 2 and 3 Technical Specifications, we have concluded that: there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner and such activities will be conducted in compliance with the Commission's regulations and the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public. We, therefore, conclude that the proposed changes are acceptable, and are hereby incorporated into the San Onofre 2 and 3 Technical Specifications.

Dated: September 25, 1985