



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555
August 12, 1986

MEMORANDUM FOR: Sholly Coordinator
Office of Nuclear Reactor Regulation

FROM: George W. Knighton, Director
PWR Project Directorate No. 7
Division of PWR Licensing-B

SUBJECT: REQUEST FOR PUBLICATION IN MONTHLY FR NOTICE - NOTICE
ISSUANCE OF AMENDMENTS TO FACILITY OPERATING LICENSE

Southern California Edison Company, et al. Docket Nos. 50-361 and 50-362,
San Onofre Nuclear Generating Station, Units 2 and 3, San Diego County,
California

Dates of application for amendments: February 7, 1986

Brief description of amendments: The amendments change the technical specifications to require the use of trisodium phosphate rather than NaOH to control the pH of the containment sump following containment spray actuation.

Date of Issuance: August 11, 1986

Effective Date: Upon first entry into Mode 3 following installation of the TSP storage baskets.

Amendment Nos.: 51 and 40

Facility Operating License Nos. NPF-10 and NPF-15: Amendments revised the Technical Specifications.

Date of Initial Notice in Federal Register: June 4, 1986 (51 F.R. 20376).

The Commission's related evaluation of the amendments is contained in a

8608200098 860812
PDR ADOCK 05000361
P PDR

Safety Evaluation dated August 11, 1986.

No significant hazards consideration comments were received: No.

Local Public Document Location: General Library, University of California at Irvine, Irvine, California 92713.

151

George W. Knighton, Director
PWR Project Directorate No. 7
Division of PWR Licensing-B

Distribution:
Docket File
PDR Local PDR
PRC System
PD7 Reading
HRood
JLee (5)
OELD

PBD7
HRood/es
8/8/86

~~PBD7~~
JLee
6/13/86

~~D: PBD7~~
GWNrighton
8/11/86

OELD
George W. Knighton
6/20/86