
SYSTEM DATA
DESIGN DATA
VALVE NUMBERING
HYDROSTATIC TEST TEMP. 60°F
TO FUTURE UNIT
AUX. BOILER
EVAPORATOR
FEED PREHEATER
AUX. BOILER FEEDWATER TRANSFER PUMPS
AUX BOILER DEAERATOR FEED PUMP PACKAGE (2-100% PUMPS)
DEAERATOR
CONTINUOUS BLOWDOWN
PURIFIER DRAIN
WASTE EVAP. PACKAGE
RECYCLE EVAP. PACKAGE
AUX. BOILER FD FAN
AUX. BOILER BD TK.
VENT TO ATMOSPHERE
VENT THRU ROOF
DETAIL LEVEL INSTRUMENTATION
NOTES:
1. ALL GAI PIPING TO BE 3/4" EXCEPT AS NOTED.
2. ALARMS TO LOCAL CONTROL PANEL.
3. THE EQUIPMENT MANUFACTURER WILL BE RESPONSIBLE FOR ALL PIPING SHOWN LIGHT & GAI PIPING SHOWN HEAVY.
4. VALVES 280-AS AND 273-AS ARE TO BE SEISMICALLY SUPPORTED. THESE VALVES ARE ACTIVE NUCLEAR SAFETY CLASS 3.
5. ALL STEAM PIPE AND SUPPORTS ARE QR PER TRP 13 FOR PIPE BREAK PURPOSES.
6. INTERNALS REMOVED
THIS IS A NUCLEAR SAFETY RELATED DOCUMENT. NO DEVIATION SHALL BE INITIATED OR PERFORMED WITHOUT PRIOR DOCUMENTATION AND WRITTEN APPROVAL
D-61
DRAWING LEGIBILITY CLASS 1
SCE&G CAD ENHANCED
PLEX Drawing TR00160-003
SOUTH CAROLINA ELECTRIC & GAS COMPANY
VIRGIL C. SUMMER NUCLEAR STATION
PIPING SYSTEM FLOW DIAGRAM
AUXILIARY STEAM
DESIGN ENGINEERING
V.C. SUMMER NUCLEAR STATION JOHNSONVILLE, S.C.
ACI | MGR | JMG
D-302-051 | 29
REVISED PER CGSS-97-0370 MGR WFO
REVISED PER MR-22410 MGR CCB
REVISED PER MR-22410 MGR CCB
REVISED PER CGSS-99-0356 MGR WFO
REVISED PER CGSS-99-0048 MGR WFO
REVISED PER CGSS-97-0381 LEK WFO
REVISION
1/4"=1'-0"