



Entergy Nuclear Northeast  
Entergy Nuclear Operations, Inc.  
James A. Fitzpatrick NPP  
P.O. Box 110  
Lycoming, NY 13093  
Tel 315 349 6024 Fax 315 349 6480

August 12, 2002  
JAFP-02-0164

T.A. Sullivan  
Vice President, Operations-JAF

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Station O-P1-17  
Washington, D. C. 20555

SUBJECT: James A. FitzPatrick Nuclear Power Plant  
Docket No. 50-333  
**Monthly Operating Report**

Dear Sir:

Enclosed is the Monthly Operating Report for the James A. FitzPatrick Nuclear Power Plant for the month of July 2002.

If there are any questions concerning this report, please contact Sherard Anderson, Thermal Performance Engineer, (315) 349-6558.

Very truly yours,

A handwritten signature in black ink, appearing to read "TASullivan".

T. A. SULLIVAN

TAS:BO:SB:SA:tmb  
Enclosure

IE24

Cc: Regional Administrator  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Office of the Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 136  
Lycoming, NY 13093

Mr. Guy Vissing, Project Manager  
Project Directorate I  
Division of Licensing Project Management  
U.S. Nuclear Regulatory Commission  
Mail stop OWFN 8C2  
Washington, DC 20555

Mr. R. Toole  
ENN BWR SRC Operations Subcommittee Chairman  
605 West Horner Street  
Ebensburg, PA 15931

JENG JAFP Files  
RMS (JAF)  
RMS (WPO)



**ENTERGY NUCLEAR NORTHEAST  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
OPERATING DATA REPORT**

**REPORT MONTH: JULY 2002**

Docket No.:	50-333
Unit Name:	FitzPatrick
Date:	August 8, 2002
Completed By:	S. Anderson
Telephone:	(315)349-6558

<b>DAY</b>	<b>NET AVERAGE DAILY POWER LEVEL</b>	<b>DAY</b>	<b>NET AVERAGE DAILY POWER LEVEL</b>
1	824	17	816
2	823	18	814
3	821	19	813
4	814	20	813
5	816	21	816
6	816	22	813
7	816	23	813
8	816	24	823
9	817	25	834
10	816	26	831
11	816	27	823
12	815	28	822
13	818	29	818
14	818	30	817
15	817	31	815
16	819		

**REPORT MONTH: JULY 2002**

Docket No.:	50-333
Unit Name:	FitzPatrick
Date:	August 8, 2002
Completed By:	S. Anderson
Telephone:	(315)349-6558

NO.	DATE	TYPE	DURATION HOURS	REASON	METHOD OF SHUTTING DOWN THE REACTOR	LICENSEE EVENT REPORT NO.	SYSTEM CODE	COMPONENT CODE	CAUSE and CORRECTIVE ACTION TO PREVENT RECURRENCE

F: FORCED  
S: SCHEDULED

**REASON:**  
 A. Equipment failure (explain)  
 B. Maintenance or Test  
 C. Refueling  
 D. Regulatory Restriction  
 E. Operator training and license examination  
 F. Administrative  
 G. Operational error (explain)  
 H. Other (explain)

**METHOD:**  
 1. Manual  
 2. Manual Scram  
 3. Automatic Scram  
 4. Continued  
 5. Reduced load  
 9. Other

**EXHIBIT G:** Instructions for preparation of data entry sheets for Licensee Event Report (LER) file (NUREG-0161)

**REPORT MONTH: JULY 2002**

Docket No.:	50-333
Unit Name:	FitzPatrick
Date:	August 8, 2002
Completed By:	S. Anderson
Telephone:	(315)349-6558

**OPERATIONAL SUMMARY**

The FitzPatrick plant - with the exception of minor derates for rod adjustments - operated at or near rated power for the duration of the month of July 2002.