

MAY 1 1984

DISTRIBUTION
Docket File 50-275
PRC System
NRC PDR
Local PDR
NSIC
HDenton
DEisenhut
HSchierling
JLee (2)
LB#3 Reading

MEMORANDUM FOR: James R. Miller, Chief
Operating Reactor Branch No. 3
Division of Licensing

FROM: George W. Knighton, Chief
Licensing Branch No. 3
Division of Licensing

SUBJECT: REQUEST FOR PUBLICATION IN MONTHLY FR - NOTICE OF
CONSIDERATION OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE

Pacific Gas and Electric Company, Docket No. 50-275, Diablo Canyon Nuclear
Power Plant, Unit 1, San Luis Obispo, California

Date of amendment request: July 1, 1983

Brief description of amendment: The change would require certain actions to
be taken if the ocean water temperature exceeds 64°F to ensure adequate
ultimate heat sink capacity.

Date of issuance: April 13, 1984

Effective date: April 13, 1984

Amendment No.: 8

Facility Operating License No. DPR-76: Amendment revised the Technical
Specification.

Date of initial notice in Federal Register: October 17, 1983 (48 F.R. 47077).

The Commission's related evaluation of the amendment is contained in a Safety

Evaluation dated April 13, 1983. No significant hazards consideration comments received.

Local Public Document Room location: California Polytechnic State University Library, Documents and Maps Department, San Luis Obispo, California 93407.

ORIGINAL SIGNED BY

George W. Knighton, Chief
Licensing Branch No. 3
Division of Licensing

cc: H. Schierling
J. Lee
P. Kruetzer

DL LB #3
JLee/yt
4/12/84

DL LB #3
BBuckley
4/18/84

OELD
LChandler
4/19/84

DL LB #3
GWKnighton
4/30/84