
SYSTEM DATA
| lbs/hr | PSIG | °F | REMARKS
1 | 32,000 | 135 | 365
2 | 29,543 | -2.7 | 282
3 | 1,700 | 4 | 328
4 | 1,170 | 4 | 378
5 | 6,100 | -2.7 | 282
TO CROSS AROUND (BY G.E.)
H.P. TURBINE
L.P. TURBINE
L.P. TURBINE
G.E. PANEL DWG. 173-8-9960 GAI DWG. IMS-27-149
STEAM SEAL REGULATOR STATION. SEE GE DWG. NO. 824E582; GAI DWG. IMS-27-057.
STEAM SEAL HEADER (2.5 TO 4.5 PSIG)
STEAM PACKING CONDENSER XCN-4-CO
LOOP SEAL FILL
DRAIN
TO ATMOSPHERE
ORIFICE
FEED PUMP TURBINE "A" (TPP-22A FW)
FEED PUMP TURBINE "B" (TPP-22B FW)
FEED PUMP TURBINE "C" (TPP-22C FW)
AUXILIARY CONDENSER "A" XCN-3A-CW
AUXILIARY CONDENSER "B" XCN-3B-CW
AUXILIARY CONDENSER "C" XCN-3C-CW
L.P CONDENSER "A" XCN-1-CW
NOTES:
1. REF. G.E. DWG. #824E582, GAI DWG. IMS-27-057
2. ALL GAI PIPING TO BE 151X.
3. FOR NOTES SEE GE DWG. 824E558, GAI DWG. IMS-27-004 AND GE DWG. 254A3997 GAI DWG. IMS-27-143.
4. 1" NPT CONNECTION FOR PERFORMANCE TEST INSTRUMENT (FORWARD-REVERSE TUBE).
HYDROSTATIC TEST TEMP. = 620°F
DESIGN DATA
D-67
PLEX Drawing TR00160-003
SOUTH CAROLINA ELECTRIC & GAS COMPANY
VIRGIL C. SUMMER NUCLEAR STATION
PIPING
SYSTEM FLOW DIAGRAM
TURBINE GLAND STEAM
DESIGN ENGINEERING
BHL
PS
PJS
D-302-141
15
DRAWING LEGIBILITY CLASS 1
SCE&G CAD ENHANCED
15 | 8/08/08 | AMR | CADD ENHANCED PER ECR-50230 | MGR | RHM
14 | 6/4/08 | JTS | REVISED PER CR98-8877/CDI-98706 | MGR | RCS
13 | 8/9/97 | DDJ | REVISED PER CCSS-97-0302 | LEK | MGR
12 | 8/9/96 | ANN | REVISED PER MFF-90162 | DJL | DVM
11 | 8/9/95 | DHL | REVISED PER CCSS-9503-DE | PS | PJS
NO. | DATE | BY | REVISION | CHKD. BY | APPROVED
×3020056