



**Duke Power**  
526 South Church Street  
P.O. Box 1006  
Charlotte, NC 28201-1006

August 14, 2002

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Subject: Duke Energy Corporation  
Oconee Nuclear Station, Units 1, 2, and 3  
Docket Numbers 50-269, 50-270 and 50-287  
Monthly Performance and Operation Status-July, 2002

Please find attached information concerning the performance and operation status of the Oconee Nuclear Station for the month of July, 2002.

Any questions or comments may be directed to Roger A. Williams at (704) 382-5346.

Sincerely,

*Terry Dimmery by David Peth*

Terry Dimmery, Manager  
Nuclear Business Support

Attachment  
XC:

L. A. Reyes, Regional Administrator  
USNRC, Region II

Dave LaBarge, Project Manager  
USNRC, ONRR

INPO Records Center

Ms. Margaret Aucoin  
Nuclear Assurance Corporation

Dottie Sherman, ANI Library  
American Nuclear Insurers

Oconee NRC Inspector

*JE24*

Document Control Desk  
U.S. NRC - Oconee

bxc:

L. E. Nicholson (ON03RC)  
RGC Site Licensing File  
ELL (EC050)

# Operating Data Report

Docket No.	<u>50-269</u>
Date	<u>August 14, 2002</u>
Completed By	<u>Roger Williams</u>
Telephone	<u>704-382-5346</u>

## Operating Status

1. Unit Name: Oconee 1
2. Reporting Period: July 1, 2002 - July 31, 2002
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net Mwe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

**Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.**

- 
9. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_
  10. Reason for Restrictions, If any: \_\_\_\_\_
- 

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	5087.0	254592.0
12. Number of Hours Reactor was Critical	744.0	4222.6	199936.1
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	744.0	4184.3	196455.4
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1908743	10673429	485992369
17. Gross Electrical Energy Generated (MWH)	658910	3729443	168066215
18. Net Electrical Energy Generated (MWH)	630506	3565303	159831892
19. Unit Service Factor	100.0	82.3	77.2
20. Unit Availability Factor	100.0	82.3	77.2
21. Unit Capacity Factor (Using MDC Net)	100.2	82.8	73.5
22. Unit Capacity Factor (Using DER Net)	95.6	79.1	70.9
23. Unit Forced Outage Rate	0.0	0.4	9.4
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup
26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:  
 1 037 937 KVA x 0.90 Pf=934 MW

**UNIT SHUTDOWNS**

**DOCKET NO.** 50-269

**UNIT NAME:** Oconee 1

**DATE:** August 14, 2002

**COMPLETED BY:** Roger Williams

**TELEPHONE:** 704-382-5346

**REPORT MONTH:** July, 2002

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			<b>No</b>	<b>Outages</b>	<b>for the Month</b>		

**Summary:**

**(1) Reason**

- A - Equipment failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory restriction

- E - Operator Training/License Examination
- F - Administrative
- G - Operator Error (Explain)
- H - Other (Explain)

**(2) Method**

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 1
2. Scheduled next refueling shutdown: September 2003
3. Scheduled restart following refueling: November 2003

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies  
(a) in the core: 177  
(b) in the spent fuel pool: 866\*  
(c) in the ISFSI: 1680\*\*\*\*
8. Present licensed fuel pool capacity: 1312  
Size of requested or planned increase: \*\*
9. Projected date of last refueling which can be accommodated by present capacity: January 2005\*\*\*

DUKE POWER COMPANY

DATE: August 14, 2002

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

\* Represents the combined total for Units 1 and 2

\*\* On March 29, 1990, received a site specific license for ISFSI which will store 2112 assemblies (88 modules). Forty (40) site specific modules were constructed and loaded.

\*\*\* In 1999 Oconee transitioned to its general license. Forty-four (44) general license modules were installed and 30 modules have now been loaded.  
Additional modules will be installed on an as-needed basis.

\*\*\*\* Represents the combined total for Units 1, 2, and 3

# Operating Data Report

Docket No.	50-270
Date	<u>August 14, 2002</u>
Completed By	<u>Roger Williams</u>
Telephone	<u>704-382-5346</u>

## Operating Status

1. Unit Name: Oconee 2
2. Reporting Period: July 1, 2002 - July 31, 2002
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

**Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.**

- 
9. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_
  10. Reason for Restrictions, If any: \_\_\_\_\_
- 

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	5087.0	244512.0
12. Number of Hours Reactor was Critical	744.0	5087.0	198402.4
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	744.0	5087.0	195849.8
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1906894	23733866	494478280
17. Gross Electrical Energy Generated (MWH)	658680	4567913	166313038
18. Net Electrical Energy Generated (MWH)	630886	4379297	158494501
19. Unit Service Factor	100.0	100.0	80.1
20. Unit Availability Factor	100.0	100.0	80.1
21. Unit Capacity Factor (Using MDC Net)	100.2	101.8	75.9
22. Unit Capacity Factor (Using DER Net)	95.7	97.2	73.2
23. Unit Forced Outage Rate	0.0	0.0	8.7
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup
26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:  
 1 037 937 KVA x 0.90 Pf=934 MW

### UNIT SHUTDOWNS

**DOCKET NO.** 50-270  
**UNIT NAME:** Oconee 2  
**DATE:** August 14, 2002  
**COMPLETED BY:** Roger Williams  
**TELEPHONE:** 704-382-5346

**REPORT MONTH:** July, 2002

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			<b>No</b>	<b>Outages</b>	<b>for the Month</b>		

**Summary:**

**(1) Reason**

- A - Equipment failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operator Error (Explain)
- H - Other (Explain)

**(2) Method**

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 2
2. Scheduled next refueling shutdown: October, 2002
3. Scheduled restart following refueling: November, 2002

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies  
(a) in the core: 177  
(b) in the spent fuel pool: 866\*  
(c) in the ISFSI: See unit 1 \*\*\*\*
8. Present licensed fuel pool capacity: 1312  
Size of requested or planned increase: \*\*
9. Projected date of last refueling which can be accommodated by present capacity: January 2005\*\*\*

DUKE POWER COMPANY

DATE: August 14, 2002

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

\* Represents the combined total for Units 1 and 2

\*\* See footnote on Unit 1

\*\*\* In 1999 Oconee transitioned to its general license. Forty-four (44) general license modules were installed and 30 modules have now been loaded.  
Additional modules will be installed on an as-needed basis.

\*\*\*\* See footnote on Unit 1



# Operating Data Report

Docket No.	<u>50-287</u>
Date	<u>August 14, 2002</u>
Completed By	<u>Roger Williams</u>
Telephone	<u>704-382-5346</u>

## Operating Status

- |   |                              |
|---|------------------------------|
| 1. Unit Name:   | Oconee 3                     |
| 2. Reporting Period:  | July 1, 2002 - July 31, 2002 |
| 3. Licensed Thermal Power (MWt):  | 2568                         |
| 4. Nameplate Rating (Gross MWe):  | 934                          |
| 5. Design Electrical Rating (Net Mwe):  | 886                          |
| 6. Maximum Dependable Capacity (Gross MWe):   | 886                          |
| 7. Maximum Dependable Capacity(Net MWe):  | 846                          |
| 8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons: |                              |

**Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.**

9. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

10. Reason for Restrictions, If any: \_\_\_\_\_

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	5087.0	242159.0
12. Number of Hours Reactor was Critical	744.0	5087.0	191444.8
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	744.0	5087.0	188805.2
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1909976	36782594	495792485
17. Gross Electrical Energy Generated (MWH)	662256	4582022	163335933
18. Net Electrical Energy Generated (MWH)	634209	4393173	155827297
19. Unit Service Factor	100.0	100.0	78.0
20. Unit Availability Factor	100.0	100.0	78.0
21. Unit Capacity Factor (Using MDC Net)	100.8	102.1	75.4
22. Unit Capacity Factor (Using DER Net)	96.2	97.5	72.6
23. Unit Forced Outage Rate	0.0	0.0	9.2
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:

1 037 937 KVA x 0.90 Pf=934 MW

**UNIT SHUTDOWNS**

**DOCKET NO.** 50-287

**UNIT NAME:** Oconee 3

**DATE:** August 14, 2002

**COMPLETED BY:** Roger Williams

**TELEPHONE:** 704-382-5346

**REPORT MONTH:** July, 2002

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			<b>No</b>	<b>Outages</b>	<b>for the Month</b>		

**Summary:**

**(1) Reason**

- A - Equipment failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory restriction

- E - Operator Training/License Examination
- F - Administrative
- G - Operator Error (Explain)
- H - Other (Explain)

**(2) Method**

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 3
2. Scheduled next refueling shutdown: April 2003
3. Scheduled restart following refueling: June 2003

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies           (a)     in the core: 177  
   (b)     in the spent fuel pool: 536  
   (c)     in the ISFSI: See Unit 1 \*\*\*\*
8. Present licensed fuel pool capacity: 825  
Size of requested or planned increase: \*\*
9. Projected date of last refueling which can be accommodated by present capacity: January 2005\*\*\*\*

DUKE POWER COMPANY

DATE: August 14, 2002

Name of Contact:           R. A. Williams

Phone: (704) - 382-5346

\*\* See footnote of Unit 1

\*\*\* In 1999 Oconee transitioned to its general license. Forty-four (44) general license modules were installed and 30 modules have now been loaded.  
Additional modules will be installed on an as-needed basis.

\*\*\*\* See footnote on Unit 1

OCONEE NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

JUNE 2002

1. Personnel Exposure -

The total station liquid release for JUNE has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for JUNE has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.