



D-133

CS	18101	18107
TR	17801	17802
CV	CV-1	CV-56

SYSTEM SUFFIX FIRST NO. LAST NO.  
VALVE NUMBERING

HYDROTEST TEMP. 40° F (MIN)

NO.	PSIG	PSIG	PSIG	PSIG	PSIG
15	48	158	158	208	318
14	48	158	248	298	308
13	234	130	248	563	318
12	28	130	298	308	352

DESIGN DATA

HYDROTEST PRESSURES FOR NEW CONSTRUCTION PER ASME CODE SECTION III

FLEX Drawing TR00160-002	
SHEFFER ELECTRIC & GAS COMPANY	
NIBEL C. OWEN NUCLEAR ENGINEER	
SYSTEM FLOOR DIAGRAM	
CHEMICAL AND VOLUME CONTROL	
DESIGN ENGINEERING	
A.V.N. M.G.R. R.S.B.	
E-302-672	