

August 8, 2002

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

**DOCKET 50-255 - LICENSE DPR-20 - PALISADES NUCLEAR PLANT
RISK-INFORMED INSERVICE INSPECTION PROGRAM – RESPONSE TO
REQUEST FOR ADDITIONAL INFORMATION (TAC NO. MB4420)**

By letter dated March 1, 2002, Nuclear Management Company, LLC (NMC) requested approval to implement a risk-informed inservice inspection (ISI) program as an alternative to the American Society of Mechanical Engineers Code, Section XI, ISI requirements for piping at the Palisades Plant. The Nuclear Regulatory Commission (NRC) staff in their review of the subject program has requested additional information by letter dated June 13, 2002. NMC response to the NRC staff's request for additional information is enclosed.

SUMMARY OF COMMITMENTS

This letter contains no new commitments and no revisions to existing commitments.



Paul A. Harden
Director, Engineering

CC Regional Administrator, USNRC, Region III
Project Manager, USNRC, NRR
NRC Resident Inspector - Palisades

Enclosure

A047

ENCLOSURE

**NUCLEAR MANAGEMENT COMPANY
PALISADES NUCLEAR PLANT
DOCKET 50-255**

August 8, 2002

**RISK-INFORMED INSERVICE INSPECTION PROGRAM
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION**

23 Pages follow

REQUEST FOR ADDITIONAL INFORMATION

RISK-INFORMED INSERVICE INSPECTION (RI-ISI) PROGRAM

PALISADES PLANT

NRC REQUEST - INTRODUCTION

1. *In the enclosure to your letter dated March 1, 2002, Table 3.7-1 and the associated notes indicate that, on the basis of their judgement, the expert panel moved 27 piping segments having risk reduction worth (RRW) values greater than 1.005 from being in the category of "high safety significant" (HSS) to "low safety significant" (LSS). The NRC staff recognizes that Topical Report WCAP-14572, Revision 1-NP-A, allows the expert panel to use deterministic information to place segments with RRW values greater than 1.005 into the LSS category, but page 143 of the Topical Report states that HSS "segments should not be classified lower by the expert panel without sufficient justification that is documented as part of the [RI-ISI] program. The expert panel should be focused primarily on adding piping to the higher classification." The expert panel apparently used three factors to move HSS segments to LSS: non-proceduralized operator actions, proceduralized operator actions, and other considerations. Each of these is addressed below:*

1.1 Operator Actions

The notes in Table 3.7-1 indicate that some of the segments were placed in the LSS category based upon the expert panel's judgment that the "with operator action" RRWs are credible and may be used as a basis for the segment classification, while the "without operator action" RRWs are inappropriate and discarded. The "with" and "without" operator action rankings are intended to reduce the impact of the highly uncertain human error evaluation on the categorization to facilitate preparation and review of short, template RI-ISI relief requests. Reducing the safety significant category based upon the expert panel's judgement about the likelihood of successful operator actions weakens this important element in the approved process.

NRC REQUEST

1.1.1 Non-Proceduralized Operator Actions

The notes in Table 3.7-1 indicate that some of the operator actions credited by the expert panel to move HSS segments into the LSS

category are not proceduralized actions. Crediting non-proceduralized operator actions is generally not acceptable in PRA analyses unless they are simple, skill-of-the-craft actions such as manually starting a standby pump following a failure of auto-start. When the expert panel moves a HSS segment into LSS based upon an operator action, the judgement on the incredibility of failure of the operator to perform the required action becomes the dominate contributor to the final disposition of the segment in RI-ISI, and thereby of the inspection requirements in the segment. The actions required to mitigate pipe ruptures must be taken in response to highly unusual and stressful events such as loss of coolant accidents (LOCAs) outside containment. The selection of the "with human action" RRW as the only credible result assumes that the operator will always succeed. This assumption is inconsistent with acceptable probabilistic risk assessment (PRA) methodologies because it assumes the non-proceduralized action will always be successfully performed, and inconsistent with the approved RI-ISI methodology where the RRW values with and without operator action are used to reduce the sensitivity of the results on the highly uncertain human error evaluation. The uncertainties in the evaluation of these actions are further increased due to the non-proceduralized action.

Because discarding the without operator error RRW negates a major element of the approved methodology, and recognizing the greater than normal uncertainty associated with evaluating the likelihood of success of non-proceduralized actions, the NRC staff believes that sufficient justification does not exist for moving HSS segments to LSS based on the judgement of the expert panel about the incredibility of the "without operator action" RRW for non-proceduralized operator actions. Please identify all piping segments placed in the LSS category based upon crediting non-proceduralized actions, place the segments in the category specified in the Topical Report (e.g., HSS if any of the four RRWs is greater than 1.005), and modify your inspection location selection accordingly.

NMC RESPONSE

1.1.1 Non-Proceduralized Operator Actions

The expert panel proposed moving the following 13 shutdown cooling (SDC) piping segments from a High Safety Significance (HSS) categorization (based on Risk Reduction Worth values) to

Low Safety Significance (LSS) based on credit taken for actions not specifically detailed in a procedure:

SDC-002B1	SDC-007A2	SDC-012A1
SDC-002B2	SDC-009	SDC-012A2
SDC-005	SDC-011A1	SDC-012A3
SDC-006	SDC-011A2	
SDC-020	SDC-011A3	

NMC used the WCAP-14572 methodology to credit operator actions for all SDC segments. The Westinghouse delta-risk analysis showed a risk reduction in the SDC system going from the current Section XI program to the RI-ISI program even with the above segments not receiving inspections. The additional documentation requested in this RAI will require significant additional time to prepare. In order to expedite the Staff's program review and thereby support the upcoming refueling outage at Palisades, NMC will leave the thirteen SDC segments in the HSS category and adjust the inspection schedule accordingly.

NRC REQUEST

1.1.2 Proceduralized Operator Actions

The notes in Table 3.7-1 indicate that some of the operator actions credited are proceduralized. Proceduralized actions must be more than credible before the "without operator action" RRWs may be discarded. The failure of proceduralized operator actions are not discarded (i.e., success assumed with a probability of 1.0) in PRA analyses. When the expert panel moves a HSS segment into LSS based upon an operator action, the judgement regarding the likelihood of the action becomes the dominate contributor to the final disposition of the segment in the RI-ISI. Justification and documentation of each of these actions must be of sufficient quality to support this judgement as the final arbitrator of safety-significance. The justification for each action should include:

- *Identification of the procedure containing the required action.*
- *The indications available to the operators to identify the specific action.*
- *The location of the action.*

- *The time available to perform the action.*
- *The time required to perform the action.*
- *Identification and characterization of the performance shaping factors that might influence the ability of the operators to accomplish the task.*
- *An integrated discussion of the above information justifying that the failure of the operator to perform the action is of such a low likelihood that the “without operator action” RRW may be discarded.*

Please identify all piping segments placed in the LSS category based upon crediting proceduralized actions and provide a copy of the justification and documentation developed by the expert panel for each segment. If the original documentation developed by the expert panel does not include the information discussed above, please provide a copy of the original documentation that was developed, and also provide the requested information.

NMC RESPONSE

1.1.2 Proceduralized Operator Actions

The expert panel proposed moving the following 5 non-critical service water (NSW) and critical service water (CSW) piping segments, and 4 chemical and volume control (CVC) piping segments from a HSS categorization to LSS based on credit taken for proceduralized operator actions:

NSW-001	CSW-005B	CVC-030A
NSW-004	CSW-006B	CVC-030B
NSW-005	CVC-025	CVC-030C

Non-Critical and Critical Service Water Segments

NMC used the WCAP-14572 methodology to credit operator actions for all NSW and CSW segments. The Westinghouse delta-risk analysis showed a risk reduction in the NSW and CSW systems going from the current Section XI program to the RI-ISI program even with the above segments not receiving inspections. The additional documentation requested in this RAI will require significant additional time to prepare. In order to expedite the Staff’s program review and thereby support the upcoming refueling

outage at Palisades, NMC will leave the five NSW and CSW segments in the HSS category and adjust the inspection schedule accordingly.

Chemical and Volume Control Segments

Four CVC segments were moved from HSS to LSS based on proceduralized operator actions. The four segments are part of the letdown system and are downstream of the letdown isolation valve but upstream of the letdown orifices. Small break Loss Of Coolant Accident (LOCA) consequences are associated with the segments. Isolation of letdown mitigates all consequences associated with the segments and all four have low "with operator action" RRW values. Expert panel representatives discussed that isolating Primary Coolant System (PCS) leaks, especially the procedurally driven action to isolate letdown very early in the event, are actions trained on frequently by operations personnel. The panel also had confidence in quick control room recognition and response to pipe failures in containment. The combination of the panel's high confidence in the listed actions and the segments low RRW values "with operator action" were the primary basis for the judgment to move the above four CVC segments to LSS.

"..and provide a copy of the justification and documentation developed by the expert panel for each segment."

Expert panel meeting documentation includes meeting minutes recorded during each panel meeting and the "Risk Informed Inspection Expert Panel Evaluation Segment Ranking Worksheets". There was a ranking worksheet reviewed by the panel for each piping segment. The sheets included detailed information about each segment. Included in the sheets were the RRW values for CDF and LERF both with and without operator action, as well as a detailed list of all the consequences associated with the segment. Operator actions associated with segments were also listed on the worksheet. Expert panel members were aware during the discussion that the actions listed on the sheet were ones with both diagnosis and action performed from the control room.

The following information was included on the worksheets for the four CVC segments:

Failure Effects on system (same for all four segments)

Without operator action: Small break LOCA initiating event and loss of letdown

With operator action: Operator could close CV-2001 to isolate letdown and stop leak

Refer to Table 1.1.1-1 below for the RRW values that were presented to the expert panel.

Segment	CDF	CDF w/Operator action	LERF	LERF w/Operator action
CVC-025	1.0087	1.0001	1.0102	1.0000
CVC-030A	1.0083	1.0001	1.0086	1.0000
CVC-030B	1.0087	1.0001	1.0097	1.0000
CVC-030C	1.0083	1.0000	1.0099	1.0000

The following is an excerpt from the expert panel meeting minutes 10/11/2000:

Segments CVC-025, 030A, 030B, and 030C were all initially categorized as high safety significant. All of them were in the low safety significant category when credit was taken for the operator action. Operator actions listed for CVC to isolate Letdown in the event of a pipe failure are credible actions.

"Identification of the procedure containing the required action."

Off Normal Procedure (ONP) 23.1 "PCS Leak"

Step 4.7.d "IF the leak is not isolated, then close CV-2001, Letdown Stop Valve"

Emergency Operating Procedure (EOP) 1.0 "Standard Post Trip Actions"

Instruction step 5 "Determine that PCS Inventory Control acceptance criteria are met"

Contingency step 5.1.b

“Manually operate charging and
letdown”

EOP 4.0 “Loss of Coolant Accident Recovery”

Instruction step 9.b “Ensure closed Letdown Stop Valves
CV-2001 and CV-2009”

*“The indications available to the operators to identify the specific
action.”*

A pipe failure in these segments (a PCS leak in containment) would
have the following symptoms:

- Volume Control Tank level lowering with low level
alarm at 62.5%
- Charging – Letdown mismatch greater than normal
- Increased charging flow
- Variable speed charging pump (P-55A) speed rises
automatically
- Automatic start of backup charging pump
- Containment sump level rising
- Radiation rise in containment atmosphere
- Rising containment humidity
- Pressurizer level decreasing

In crediting postulated operator actions to isolate a CVC piping
failure, Palisades followed the Westinghouse methodology. The
Palisades expert panel determined that a PCS leak would lead the
operators to isolate letdown. It is the opinion of current and past
licensed operators on the expert panel that the slow progression of
the small break LOCA event, the early steps in both Off-Normal
and EOP procedures, and frequent operator training on the event
makes it extremely likely that operators would quickly isolate
letdown during any loss of PCS inventory or LOCA. All the
requested information in the RAI (time available, time required,
performance shaping factors, etc) has not been developed in detail
for the segments in question since the Westinghouse methodology
does not require this level of information. However, the staff at
Palisades believes the expert panel’s judgment is realistic and that
the classification of the four CVC segments as LSS is considered
reasonable.

It is important to note that the RI-ISI process is a risk-informed process and not a risk-based process. There are other important considerations beyond the risk importance measures that are produced as part of the process. NMC agrees that the expert panel should be focused primarily on adding piping segments to the high safety significant (HSS) category; however, per WCAP-14572, piping segments that have been determined by quantitative methods to be HSS can be categorized low safety significant (LSS) with sufficient justification.

Additionally, categorization of segments as LSS by the expert panel is not the final determination of which segments are not included in the RI-ISI inspection program. Systems must meet the criteria identified in the WCAP-14572. The criteria states that the total change in piping risk should be risk neutral or a risk reduction in moving from the current ASME Section XI to RI-ISI program. If a system is not at least risk neutral following expert panel classification, additional segments are identified for inspection. This in fact was the case for five segments that were added to the inspection program for change in risk considerations. The Westinghouse delta-risk analysis for the CVC system showed that there is a risk reduction in going from the current program to the RI-ISI program even with four HSS segments (moved from HSS to LSS by the expert panel) not receiving an inspection.

NRC REQUEST

1.2 Other Considerations

The notes in Table 3.7-1 indicate that a number of piping segments were moved from the HSS category to the LSS category by the expert panel based upon considerations other than the potential for operator actions. The justification should include:

- *The specific weakness in the quantitative evaluation that causes the segment to be inappropriately placed in HSS.*
- *A discussion of the more appropriate assumption that corrects the weakness.*
- *A discussion of the magnitude of the impact of the more appropriate assumption that supports moving the HSS segment into LSS.*

For example, Note 7 states that there are 'no active failure mechanism' in several pressurizer (PRZ) segments and that they "would be subjected to the lowest temperature of all PCS [primary coolant system]/PRZ segments". If the environment in these segments is so benign, why were they HSS according to the RRW values? What is the inappropriate assumption that lead to the HSS categorization? What is the more appropriate assumption and how much does it influence the consequence and/or the frequency of the segments? failure? Please identify each of these segments and provide a copy of the justification developed and documented by the expert panel to move the segment from the HSS to the LSS category. If the original documentation developed by the expert panel does not include the information discussed above, please provide the original documentation that was developed, and also provide the requested information.

NMC RESPONSE

1.2 Other Considerations

Based on considerations other than crediting operator actions, the Palisades Expert panel has proposed moving the following concentrated boric acid (CBA), CSW, main steam system (MSS), fire protection system (FPS), and pressurizer (PZR) segments from HSS to LSS:

CBA-012	MSS-041	PZR-016
CSW-027	FPS-014	PZR-017

NMC moved the above segments from HSS to LSS based on expert panel judgment and other considerations (e.g. conservative PSA modeling assumptions, nonrealistic Win-SRRA inputs, results from past ISI inspections, etc.) other than operator actions. Additionally, the Westinghouse delta-risk analysis showed a risk reduction in the all the above systems going from the current Section XI program to the RI-ISI program even with the above segments not receiving inspections. The additional documentation requested in this RAI will require significant additional time to prepare. In order to expedite the Staff's program review and thereby support the upcoming refueling outage at Palisades, NMC will leave the five CBA, MSS, FPS, and PZR segments in the HSS category and adjust the inspection schedule accordingly.

The analysis of Critical Service Water (CSW) segment CSW-027 as described in the March 1, 2002, RI-ISI submittal conservatively assumed that a failure would cause loss of backup Auxiliary Feedwater (AFW) suction for two AFW pumps. A more realistic consequence is the loss of backup suction to just one AFW pump. The segment in question is only associated with one AFW pump and the initial choice of PSA surrogates for quantification was overly conservative. CDF and LERF values for the segment were evaluated with a loss of backup suction to one electric motor driven AFW pump, and one steam turbine driven AFW pump. A more realistic choice of surrogates would have failed suction to only an electric motor driven AFW pump. With the more realistic surrogate, the CDF would increase by less than 1% above the baseline value. Therefore the expert panel categorization of the segment as LSS is considered acceptable.

NRC REQUEST

2. *In the NRC Staff Evaluation Report (SER) on the Palisades Individual Plant Examination (IPE), dated February 7, 1996, the NRC staff concluded that there were limitations in the Human Reliability Assessment (HRA) approach used by the licensee that could limit the Palisades IPE in future regulatory uses. These limitations include:*

- *Treatment of pre-initiator and post-initiator errors using the Technique for Human Error Rate Prediction which limits the degree of insights about plant-specific factors influencing human performance.*
- *Use of screening values that are significantly lower than values typically used for post-initiator actions and not including dependencies in the initial quantification.*
- *Treatment of diagnosis for post-initiator actions, which is not consistent with most nuclear power plant HRAs.*
- *In one of the two post-initiator actions that was quantified using the Accident Sequence Evaluation Program (ASEP) model, the calculated human error probability (HEP) was the lowest value of all post-initiator HEPs.*

Please explain how these limitations in the HRA have been addressed during the evaluations performed in support of this relief request.

NMC RESPONSE

“Treatment of pre-initiator and post-initiator errors using the Technique for Human Error Rate Prediction which limits the degree of insights about plant-specific factors influencing human performance. “

The THERP methodology was employed for selected mis-calibration and “after maintenance” mis-positioned valve failure modes in the IPE submittal. These modeled malfunctions are referred to as pre-initiator failures. Some seventy pre-initiator errors are still included in the updated model that was used for the RI-ISI analysis. The same failure rate is used for “like” failure modes. For example, instrument mis-calibration errors (high) are assigned the same likelihood regardless of the device. Although this could limit some insight with respect to pre-initiator plant specific processes, there is no effect on the RI-ISI analysis, as post-initiator operator errors were not modeled as separate events but as consequential hardware failures.

Moreover, the Palisades PSA model conservatively over predicts the impact of pre-initiator calibration errors as these same stressors are included in many of the modeled common cause functional groups.

Additionally as part of the Palisades PSA maintenance model process, the post-initiator IPE HEPs (i.e., the “non” above referenced consequential failures) used to support this request were updated using NUREG/CR-4772, “Accident Sequence Evaluation Program (ASEP) Human Reliability Analysis Procedure.” The ASEP methodology provided guidance on how to evaluate pre and post-diagnoses tasks.

“Use of screening values that are significantly lower than values typically used for post-initiator actions and not including dependencies in the initial quantification.”

The IPE submittal originally employed HEP screening values of 1E-02 and 1E-03. The subsequent maintenance update employing the NUREG/CR-4772 methodology used a value of 0.1 for the HEP’s in which a specific human error rate was not developed. The setting of four HEP’s to a screening value of 0.1 was included in the PSA RI-ISI model.

“Treatment of diagnosis for post-initiator actions, which is not consistent with most nuclear power plant HRAs.”

Since the IPE submittal the Palisades post-initiator operator actions have been updated using the ASEP Methodology. The ASEP approach has

two phases, the diagnosis tasks and the post-diagnosis tasks. The diagnosis responsibilities consists of determining what to do when an abnormal event has been recognized and the post-diagnosis task consists of those actions that are logically taken following the correct diagnosis of an abnormal event. Diagnosis requires evaluating the operator's knowledge based behavior and post-diagnosis evaluates the operator's skill and rule based behaviors. In conclusion the Palisades PSA model HEP revision has addressed the above SER issue. This HEP revision was included in the PSA model used to evaluated RI-ISI program.

"In one of the two post-initiator actions that was quantified using the Accident Sequence Evaluation Program (ASEP) model, the calculated human error probability (HEP) was the lowest value of all post-initiator HEPs."

In this instance, the NRC Staff Evaluation Report (SER) is referring to the IPE developed HEP for once-through cooling (OTC). The operator action (~ 8E-05) was re-analyzed again using the ASEP methodology. Both pre and post diagnosis elements were evaluated resulting in a new HEP value of 2.9E-03. This updated value was used in the RI-ISI PSA model.

NRC REQUEST

3. *In the enclosure to your letter dated March 1, 2002, Section 1.2, "PSA Quality," states that the Combustion Engineering Owners Group (CEOG) peer review performed in May 2000 found a weakness in performing a thorough dependency analysis for the operator actions modeled in the PSA. You state that the "weakness related to the appropriateness of the magnitude of human error probabilities used in the model given the possibility that dependent operator actions may not have been adequately considered." In general, omitting the dependencies between multiple operator actions yields lower human error rates for a sequence of actions. Your reported investigation that observed a slight increase in risk after including the dependencies in a number of multiple actions is consistent with this general observation. However, on page 2, you continued that you chose not to "remove further some of the conservatism by assessing more human error combinations...[because]...additional evaluation is not considered necessary due to the already small increase in [core damage frequency] CDF."*

Including dependencies between human actions does not "remove conservatism" -- it removes non-conservatism. The small increase in CDF observed from the completed evaluation does not alone support the conclusion that further evaluation would not yield larger increases.

Please explain how the incomplete review of dependencies could affect the evaluations performed in support of this relief request.

NMC RESPONSE

“Including dependencies between human actions does not “remove conservatism” -- it removes non-conservatism. The small increase in CDF observed from the completed evaluation does not alone support the conclusion that further evaluation would not yield larger increases. “

NMC used the following process to evaluate human action dependencies should resolve this question. Cutsets that were not specifically evaluated for human action dependencies were assumed to have complete dependence, which is conservative. Evaluation of additional combinations can only serve to remove some of that conservatism.

“Please explain how the incomplete review of dependencies could affect the evaluations performed in support of this relief request.”

The following describes the process employed by Palisades to address the CEOG peer review concern regarding human action dependencies.

In May 2000, a CEOG sponsored PSA peer review team reviewed the Palisades PSA. In their evaluation, the team commented that the number of combinations that were considered in the qualitative human error dependency evaluation may not have been sufficient to assure that all risk significant combinations were identified. To alleviate this concern, Palisades performed a thorough investigation on the impact of human error dependency on the baseline CDF.

To address the human action dependency issue with respect to CDF, Palisades developed a systematic approach that investigated a sufficient number of human actions to merit confidence that the impact of these dependencies have been thoroughly assessed and adequately represented in the PSA models. The approach was iterative and methodical. Subsequent prioritization of the impact of potential dependencies on the overall CDF was performed. The analysis began with conservative assumptions regarding conditional probabilities of multiple human errors found in the Palisades cutsets and gradually removed the conservatisms from the combinations of HEPs that were determined to influence the CDF. The iteration terminated when the change in CDF became negligible.

The operator actions of concern are those performed in response to an

initiating event, or post initiating event actions. As noted above, the objective was to assess the potential dependency between post-initiating human actions modeled in the Palisades PSA and evaluate their impact on CDF in a thorough manner.

The method consisted of the steps outlined below. The ASEP [1] and THERP [2] (THERP was used to identify the conditional dependencies in this evaluation, only) human error methodologies to assess and quantify dependent human error probabilities (DHEP) between the errors as shown in Figures 1a and 1b were employed. The human error dependency analysis consisted of the following steps.

1. Identify the post-initiator operator error events modeled in the PSA to be included in the dependency review.
2. Regenerate CDF sequences with human error events set to unity (1.0) to obtain a relatively complete input for the dependency evaluation.
3. Identify all post-initiating event operator error event combinations in the same CDF cutset in the baseline CDF equation.
4. Identify the combinations that are considered independent using the decision trees presented in Figures 1a and 1b.
5. For all other human error combinations, credit only one human error event in the combination. Set the remaining human error events in the combination to 'True' (i.e., assuming they all are completely dependent upon the credited human error event).
6. Select several human error combinations that are not independent in accordance with Figures 1a and 1b and derive conditional values based on Figures 2a and 2b.
7. Separate the CDF cutsets into modules containing the identified combinations of human actions. Determine a Δ CDF between the baseline value for these modules and the value obtained by assuming the human actions are dependent for all the modules.
8. Identify dominant modules containing multiple human error events with respect to the change in CDF and identify the additional dependent actions that contribute to this change.

Derive conditional failure probabilities for these newly identified combinations of human actions.

9. Repeat steps 7 and 8 until Δ CDF due to human error dependency becomes negligible.

The relatively small increase in the overall CDF contributed by the dependency analysis of human actions (Δ CDF increase < 40%) is an indication that dependency between human actions within important accident sequences are low and that the PSA already accounted for any significant dependency among critical actions in the modeling development process. Moreover, the Δ CDF could be further reduced by explicitly modeling additional human error combination dependencies. However, additional evaluation is not considered necessary due to the already small increase in CDF. In summary the Palisades PSA model is considered to satisfactorily address human error dependencies and that it is adequate to evaluate the RRW values of the analyzed segments in support of the RI-ISI relief request.

Figure 1a: Diagnosis Dependency Decision Tree




Figure 1b: Post-Diagnosis Dependency Decision Tree

Failure of the Immediately Preceding Op Action	Same Time Frame As the Preceding Op Action	Any Previous Failed Operator Actions With Similar Goals or Actions	Same Operator As Failed OA?	Workload	Dependency Level
[]	[]	[]	[]	[]	[]




Figure 2a: Dependency Model – 2 Human Error Events





Figure 2b: Dependency Model – 3 Human Error Events



NRC REQUEST

4. *On page 3 of the enclosure to your letter dated March 1, 2002, in the section on "Deviations" you state that four piping segments in the safety injection/refueling water tank and containment sump (SSS) system are in a category of thin-walled piping and have attributes of low pressure, low temperature, low design stress, and low fatigue stress, that are not appropriate for use with the Westinghouse statistical (Perdue) model. These attributes do not appear to be outside the bounds of applicability of the Perdue model listed on page 178 of WCAP-14572. You further state that a 7.5% sample was selected from each of the segments as an alternative to running the Perdue model. Please explain why the Perdue model is not applicable to these four piping segments.*

NMC RESPONSE

Four segments, SSS-001, SSS-002, SSS-002C, and SSS-007 were considered outside of the applicability of the Perdue model. The safety significance of these 4 segments, as determined by the quantitative criteria, is low safety significance since the associated RRW values are less than 1.001. The expert panel categorized these 4 segments as high safety significant based on deterministic reasons. The failure of these segments can lead to loss of the Safety Injection and Refueling Water Tank (SIRWT) and are unisolable from the SIRWT.

Segment failure probabilities are calculated using the SRRA program. The failure probability value associated with large leak and no ISI and no leak detection for each segment is tabulated. If the failure probability is greater than $1E-4$, the segment is placed in a high failure importance (HFI) category. If the failure probability is less than $1E-4$, the segment is placed in the low failure importance (LFI) category. All 4 segments were initially placed in the LFI category.

The Perdue model uses results from the SRRA evaluation to determine if there is a 95% confidence that the probability of the leak rate per year per lot is less than the target leak rate per year per lot. When the probability of a flaw (10% through-wall crack) at the present age of the plant is close to 1.0, and the failure probabilities are of sufficient magnitude, the confidence does not meet the 95% acceptance criteria. The probability of a flaw at the plant's present age has a value close to 1.0 for these thin-walled (schedule 10) piping segments. One of these piping segments did not receive a construction radiograph. This causes the high probability of a flaw in the Perdue model process. Therefore, a very small conditional probability of a leak/year/weld is required to obtain an acceptable (>95%)

confidence that the calculated leak rate will be less than the target leak rate.

Application of the overall process (i.e., risk evaluation, SRRA, and Perdue model) indicates that 100% of the welds in the segments of interest need to be examined in the proposed risk-informed ISI program. This result is judged to be inappropriate by the engineering team for these segments for the following reasons:

- The piping segments operate at low temperatures (<150°F) and low pressures (<100 psi) in this thin-wall piping
- The piping is constructed of 304SS, which is a ductile material with high fracture toughness values
- Leaks have not occurred and unacceptable flaw indications, per the ASME Section XI code, have not been discovered from volumetric and surface examination of these piping segments in more than 29 years of operation
- There are no known active degradation mechanisms existing within these segments

To this end, the engineering team, including Westinghouse, reviewed the Perdue model applicability for segments SSS-001, SSS-002, SSS-002C, and SSS-007. Based on this review, it has been determined that the Perdue model should not be used to establish a statistically relevant inspection sample size to verify the condition of the piping. The following summarizes this rationale:

- Given that pre-service examination using volumetric examination methods was not performed during original construction for segment SSS-007, the probability of having a flaw is more than ten times higher than for a segment that received a pre-service exam.
- Per page 171 of WCAP-14572, Revision 1-NP-A, the Perdue model is based on the probability of a flaw existing (at the current age of the plant) that exceeds an unacceptable flaw defined by ASME Section XI Code. The unacceptable flaw has been defined as $a/t > 0.10$, based on general acceptance standards that are appropriate for reactor piping operating at higher temperatures, pressures, and expected operating and design basis loadings.
- When the large flaw size distribution is combined with the above Perdue model assumption (particularly since thin-wall piping is being evaluated), an unreasonable 100% sample size result is determined.

- The $a/t > 0.10$ Perdue model assumption is inappropriate for the piping segments of interest. The operating temperatures and pressures for these thin-walled piping segments are $< 150^\circ\text{F}$ and < 100 psi, respectively. Given these conditions, along with the fact that the piping is constructed of stainless steel material that is ductile and has an inherently high fracture toughness, piping fracture evaluation experience to date indicates that the unacceptable flaw size would at least have an $a/t > 0.50$ using fracture evaluation methods defined in ASME Section XI.
- If the Perdue model could account for this value, the probability of having a flaw exceeding this value at the current age of the plant would be significantly reduced. A highly reliable piping system would be demonstrated that would reflect a conclusion consistent with the engineering judgment discussed above.

Thus, the statement on page 184 of WCAP-14572, Revision 1-NP-A - "Other situations may exist that warrant considerations beyond the above guidance" - is exercised in the selection of actual inspection locations. The inspection sample selected for the four segments will be kept at the existing Section XI guideline of 7.5%. This 7.5% sample inspection provides adequate assurance to identify random or unknown conditions in these highly reliable segments.

NRC REQUEST

5. *In Section 3.1 on page 4 of the enclosure to your letter dated March 1, 2002, you state that the Reactor Cavity Flood System was excluded from system scope consideration in the RI-ISI program. What is the basis stated in the documentation maintained at the site for excluding this system?*

NMC RESPONSE

The report "Consumers Energy Palisades Scope of Risk-Informed Inservice Inspection Program" Revision 1, was generated during initial program scoping. Justification for Reactor Cavity Flood system exclusion from the program is listed on page 9 of the report in the Comment column of Table 1 "Palisades RI-ISI Scope Definition". The comment states that the system is excluded primarily because it is entirely made up of floor drain piping in containment. Discussion during the scoping process included several other facts to support the system's exclusion:

- Since the piping is embedded in concrete, a weld failure will not

disable the system. If a pipe failure occurs the concrete around the pipe will channel the water to the intended location.

- The system is open to containment atmosphere under normal conditions and has no process fluid (unless containment sprays actuate). Therefore it has no active degradation mechanism to cause a weld failure.
- The system is categorized as Low Safety Significant for Maintenance Rule.

NRC REQUEST

6. *Table 5-1 of the enclosure to your letter dated March 1, 2002, shows that, for the primary coolant system, there are 5 volumetric examinations in the 29 HSS piping segments. Please explain why only 5 volumetric examinations are performed.*

NMC RESPONSE

Of the 29 HSS segments in the PCS system, only 5 of them contain butt welds. There are a total of 20 butt welds associated with the 5 segments.

The number of weld inspections per segment to be inspected was determined using the Westinghouse statistical (Perdue) model as described in section 3.7 of WCAP-14572, Revision 1-NP-A. The remaining 24 segments contain only socket welds. In accordance with section 3.8 of the submittal, the socket welds in these segments cannot be individually examined by any currently available NDE techniques that are appropriate for the degradation mechanism. Therefore, for these segments, a visual (VT-2) examination will be performed during the system pressure test each refueling outage

NRC REQUEST

7. *Will the RI-ISI program be updated every 10 years and submitted to the NRC consistent with the current ASME XI requirements?*

NMC RESPONSE

The RI-ISI program will be a living program that will be updated as required to reflect ISI needs, PSA model changes, and any required WCAP provisions. Following program approval only the inspection plan would be submitted to the NRC in accordance with current ASME Section XI requirements.

NRC REQUEST

8. *Under what conditions would the RI-ISI program be resubmitted to the NRC before the end of any 10-year interval?*

NMC RESPONSE

The RI-ISI program would be resubmitted to the NRC before the end of any 10-year interval if there is an impact to the basis for NRC approval in the plant specific Safety Evaluation.

NRC REQUEST

9. *Since 66% of the scheduled examinations under the RI-ISI program are being examined by the end of the third inspection interval, how will the welds be selected in terms of risk category?*

NMC RESPONSE

In selecting examinations, primary consideration will be given to elements that are in Region 1A of the Structural Element Selection Matrix since these elements are high safety significant and have a high failure importance. For elements in Region 1B and 2, there is no active degradation mechanism; therefore a combination of considerations will be used to determine which elements to examine. These considerations include:

- Dominant contributors to risk
- Selecting elements from various systems and postulated degradation mechanisms
- Radiation exposure
- Accessibility