

An Exelon/British Energy Company

AmerGen Energy Company, LLC Oyster Creek US Route 9 South PO Box 388 Forked River, NJ 08731-0388

Aug 7, 2002 2130-02-20234

U. S. Nuclear Regulatory Commission Attn: Document Control Desk Washington DC 20555

Subject: Oyster Creek Nuclear Generating Station Docket No. 50-219 Monthly Operating Report – July 2002

Enclosed is the July 2002 Monthly Operating Report for the Oyster Creek Generating Station. The content and format of information submitted in this report is in accordance with the guidance provided by Generic Letter 97-02.

If any additional information or assistance is required, please contact Mr. John Rogers of my staff at 609.971.4893.

Very truly yours,

Ron J. De Gregorio, Vice President Oyster Creek Generating Station

RJD/JJR Enclosure cc: Administrator, Region I NRC Senior Project Manager Senior Resident Inspector



APPENDIX A Operating Data Report

Docket No:	50-219		
Date:	8/06/02		
Completed By:	Roger Gayley		
Telephone:	609.971.4406		

; • •

Reporting Period:

July 2002

		MONTH	YEAR TO DATE	CUMULATIVE
1.	DESIGN ELECTRICAL RATING (MWe NET). The nominal net electrical output of the unit specified by the utility and used for the purpose of plant design	650	•	•
2.	MAXIMUM DEPENDABLE CAPACITY (MWe NET). The gross electrical output as measured at the output terminals of the turbine generator during the most restrictive seasonal conditions minus the normal station service loads.	619	•	•
3.	NUMBER OF HOURS REACTOR WAS CRITICAL. The total number of hours during the gross hours of the reporting period that the reactor was critical.	744	5087	206,773.7
4.	HOURS GENERATOR ON LINE. (Service Hours) The total number of hours during the gross hours of the reporting period that the unit operated with the breakers closed to the station bus. The sum of the hours that the generator was on line plus the total outage hours should equal the gross hours in the reporting period.	744	5087	202,598.7
5.	UNIT RESERVE SHUTDOWN HOURS. The total number of hours during the gross hours of the reporting period that the unit was removed from service for economic or similar reasons but was available for operation.	0	0	918.2
6.	NET ELECTRICAL ENERGY (MWH). The gross electrical output of the unit measured at the output terminals of the turbine generator minus the normal station service loads during the gross hours of the reporting period, expressed in megawatt hours. Negative quantities should not be used.	446,911	3,144,022	115,251,179

* Design values have no "Year to Date" or "Cumulative" significance.

APPENDIX B Unit Shutdowns

 Docket No:
 50-219

 Date:
 8/06/02

 Completed By:
 Roger Gayley

 Telephone:
 (609) 971- 4406

. "

/

+ **1**

3

Reporting Period: July 2002

No.	Date	Туре*	Duration (Hours)	Reason ¹	Method of Shutting Down Reactor ²	Cause & Corrective Action to Prevent Recurrence
					None	
S Scheduled		1 <u>Reason</u> A-Equipment Failure (Explain) B-Maintenance or Test C-Refueling D-Regulatory Restriction E-Operator Training & Licensing Examin F-Administrative G-Operational Error (Explain)			2 <u>Method</u> 1-Manual 2-Manual S 3-Automatic 4-Other (Ex nination	c Scram

Summary: During July, Oyster Creek generated 446,911 net MWh electric, which was 97% of its MDC rating.

H-Other (Explain)

Oyster Creek Licensing Correspondence Distribution Sheet

 File No.
 02001
 Letter Date
 08/07/2002

 Reference/Letter No.
 2130-02-20234
 Date Sent / Received
 08/07/2002

Title Description: Monthly Operating Report - July 2002

LICENSING ENGINEER: John Rogers

SPECIAL NOTES:

ت ___ ت

Office of the President			Oyster Creek	
R. J. DeGregorio (Letter Only)	OCAB2		E. Harkness	MOB <u>X</u>
R. Maldondo	OCAB2		M. Trum	MOB
Communications	OCAB2		C. Wilson	MOB
			R. Brown	МОВ
Engineering			J. Vaccaro	MOB
V.Aggarwal	OCAB3	<u> </u>	JBobba	AOB
M. Newcomer	OCAB3		A. Krukowski	NMB
A. Agarwal	OCAB3		R. Ewart	OCAB2
D. Barnes	OCAB3		G. True	Whse2
T. E. Quintenz	OCAB3		D. Norton	Whse 1
M. Button	OCAB3		W. Collier	AOB Aux
F. Buckley	OCAB3		D. McMillan	Bldg 12
T. Powell	OCAB3		J. Magee	NMB
R. Larzo	OCAB3		M. Massaro	OCAB2
C. Lefler	OCAB3		D. Slear	OCAB2
			M. Moore	AOB

AmerGen/Exelon C. Pardee G. Vanderheyden M. Gallagher (Outgoing Only) J. Hufnagel (Outgoing Only) D. Walker KS Document Ctr I Toncic D Distel Jeff Benjamin	KSA 3-N KSA 3-N KSA 3-E KSA 3-E KSA 3-E KSA 3-E KSA 1-N KSB 3-W KSA 3-E X KSA 3-E X Cantera	Other NSRB (22 copies) R Gayley	OCAB3	
External Distribution NJBNE - K. Tosch INPO ANI - R. Oliveira BPU - R. Chilton T. Gould GE - P. Ray	_X			

File Index Number: 20.16.01.01 Cross Reference Number: 20.16.01.01