



**Entergy Operations, Inc.**  
Waterloo Road  
P.O. Box 756  
Port Gibson, MS 39150  
Tel 601 437 6299

**Charles A. Bottemiller**  
Manager  
Plant Licensing

August 14, 2002

U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Attention: Document Control Desk

Subject: Monthly Operating Report  
Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-29

GNRO-2002/00067

Ladies and Gentlemen:

In accordance with the requirement of Technical Specification 5.6.4, Entergy Operations, Inc. is providing the Monthly Operating Report for Grand Gulf Nuclear Station Unit 1 for July 2002.

This letter does not contain any commitments.

If you have any questions or require additional information, please contact this office.

Yours truly,

A handwritten signature in black ink, appearing to be "CAB".

CAB/AMT:amt  
attachments:

1. Operating Status
  2. Average Daily Power Level
  3. Unit Shutdown and Power Reductions
- (See Next Page)

cc:

August 14, 2002  
GNRO-2002/00067  
Page 2 of 2

cc:

Hoeg	T. L.	(GGNS Senior Resident)	(w/a)
Levanway	D. E.	(Wise Carter)	(w/a)
Reynolds	N. S.		(w/a)
Smith	L. J.	(Wise Carter)	(w/a)
Thomas	H. L.		(w/o)

U.S. Nuclear Regulatory Commission  
ATTN: Mr. E. W. Merschoff (w/2)  
Regional Administrator, Region IV  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-4005

U.S. Nuclear Regulatory Commission  
ATTN: Mr. David H. Jaffe NRR/DLPM (w/2)  
**ATTN: FOR ADDRESSEE ONLY**  
ATTN: U.S. Postal Delivery Address Only  
Mail Stop OWFN/7D-1  
Washington, D.C. 20555-0001

DOCKET NO	<u>50-416</u>
DATE	<u>08/06/2002</u>
COMPLETED BY	<u>S. D. Lin</u>
TELEPHONE	<u>(601) 437-6793</u>

**OPERATING STATUS**

1. Unit Name: GGNS UNIT 1
2. Reporting Period: July 2002
3. Licensed Thermal Power (MWt): 3833 MWt
4. Nameplate Rating (Gross MWe): 1372.5 MWE
5. Design Electrical Rating (Net MWe): 1250 MWE
6. Maximum Dependable Capacity (Gross MWe): 1257 MWE
7. Maximum Dependable Capacity (Net MWe): 1207 MWE
8. If changes occur in Capacity Ratings (Items 3 through 7) Since Last Report. Give Reason: N/A
9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reasons For Restrictions, If Any: N/A

	<u>This Month</u>	<u>Yr to Date</u>	<u>Cumulative*</u>
11. Hours in Reporting Period	<u>744</u>	<u>5,087</u>	<u>155,871</u>
12. Number of Hours Reactor was Critical	<u>744.0</u>	<u>5,036.2</u>	<u>133,563.1</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
14. Hours Generator On-Line	<u>744.0</u>	<u>5,013.2</u>	<u>129,914.5</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>2,843,084</u>	<u>19,110,970</u>	<u>472,873,636</u>
17. Gross Electrical Energy Generated (MWH)	<u>968,157</u>	<u>6,503,424</u>	<u>154,784,384</u>
18. Net Electrical Energy Generated (MWH)	<u>929,756</u>	<u>6,254,568</u>	<u>148,534,276</u>
19. Unit Service Factor	<u>100.0</u>	<u>98.6</u>	<u>84.7</u>
20. Unit Availability Factor	<u>100.0</u>	<u>98.6</u>	<u>84.7</u>
21. Unit Capacity Factor (Using MDC Net)	<u>103.5</u>	<u>101.9</u>	<u>84.3</u>
22. Unit Capacity Factor (Using DER Net)	<u>100.0</u>	<u>98.4</u>	<u>78.4</u>
23. Unit Forced Outage Rate	<u>0.0</u>	<u>1.5</u>	<u>5.1</u>
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): <u>Refueling Outage #12 to begin on 09/13/02 for 32 days.</u>			
25. If Shut Down At End of Report Period. Estimated Date of Startup: <u>N/A</u>			
26. Units in Test Status (Prior to Commercial Operation):			

Forecast Achieved

INITIAL CRITICALITY	<u>          </u>	<u>08/18/82</u>
INITIAL ELECTRICITY	<u>          </u>	<u>10/20/84</u>
COMMERCIAL OPERATION	<u>          </u>	<u>07/01/85</u>

\* Items 11 through 18 are cumulative results since initial electricity

DOCKET NO 50-416  
 DATE 08/06/2002  
 COMPLETED BY S. D. Lin  
 TELEPHONE (601) 437-6793

MONTH: July 2002

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>1253</u>	17	<u>1253</u>
2	<u>1256</u>	18	<u>1251</u>
3	<u>1257</u>	19	<u>1248</u>
4	<u>1254</u>	20	<u>1247</u>
5	<u>1253</u>	21	<u>1247</u>
6	<u>1254</u>	22	<u>1250</u>
7	<u>1252</u>	23	<u>1248</u>
8	<u>1255</u>	24	<u>1254</u>
9	<u>1255</u>	25	<u>1215</u>
10	<u>1254</u>	26	<u>1253</u>
11	<u>1253</u>	27	<u>1254</u>
12	<u>1255</u>	28	<u>1251</u>
13	<u>1198</u>	29	<u>1251</u>
14	<u>1254</u>	30	<u>1251</u>
15	<u>1253</u>	31	<u>1254</u>
16	<u>1257</u>		

### UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH July 2002

No.	Date	Type (1)	Duration Hours	Reason (2)	Method Of Shutting Down Reactor (3)	Licensee Event Report #	System Code (4)	Component Code (5)	Cause & Corrective Action To Prevent Recurrence (C&CA)
None									

**1****2****3****4****5**

F: Forced S: Scheduled	Reason: A-Equipment Failure (Explain) B-Maintenance or Test C-Refueling D-Regulatory Restriction E-Operator Training & Licensing Examination F-Administrative G-Operational Error (Explain) H-Other (Explain)	Method: 1-Manual 2-Manual Scram 3-Automatic Scram 4-Continued 5-Reduced load 6-Other	Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)	Exhibit 1 - Same Source
---------------------------	--	--	---	-------------------------