

July 26, 1991

Bucket Nos. 50-275 and 50-323

J. D. Shiffer
Nuclear Power Generation
Senior Vice President
Pacific Gas and Electric Company
771 Beale Street, Room 1451
San Francisco, CA 94106

Dear Mr. Shiffer:

SUBJECT: CORRECTION TO AMENDMENT NOS. 63 AND 62 TO FACILITY OPERATING LICENSE
NO. DPR-80 AND DPR-82 FOR THE DIABLO CANYON NUCLEAR POWER PLANT,
UNIT NOS. 1 AND 2 (TAC NOS. 77908 AND 77909)

By letter dated June 26, 1991, the Commission issued the subject amendment to
the Facility Operating License for Diablo Canyon Nuclear Power Plant, Unit
Nos. 1 and 2.

The Technical Specification page 3/4 2-20 inadvertently did not contain the
amendment number. The corrected page, 3/4 2-20 is enclosed. If you have any
questions regarding this correction, please contact me.

Sincerely,

ORIGINAL SIGNED BY

Harry Rood, Senior Project Manager
Project Director V
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

NRC FILE CENTER COPY

DISTRIBUTION

<u>Docket File</u>	NRC & LPDRs	PDV r/f	BBoger	MVirgilio	RCesaro
WJones	DHagan	PDV p/f	HRood	Ghill(4)	CGrimes
ACRS(10)	GPA/PA	OC/LFMB	OGC	RV(4)	RZimmerman, RV
ADummer	EJordan	RJones	JDyer		

OFC	: LA/PDV/DRPW	: I/PDV/DRPW	: PM/PDV/DRPW	: D/PDV/DRPW	:
NAME	: RCesaro <i>RCesaro</i>	: ADummer <i>ADummer</i>	: HRood <i>HR</i>	: JDyer <i>JML</i>	:
DATE	: 7/25/91	: 7/26/91	: 7/25/91	: 7/26/91	:

CP-1
DF01
111

OFFICIAL RECORD COPY
Document Name: DC CORCT AMEND/77908/77909



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

July 26, 1991

Docket Nos. 50-275 and 50-323

J. D. Shiffer
Nuclear Power Generation
Senior Vice President
Pacific Gas and Electric Company
771 Beale Street, Room 1451
San Francisco, CA 94106

Dear Mr. Shiffer:

SUBJECT: CORRECTION TO AMENDMENT NOS. 63 AND 62 TO FACILITY OPERATING LICENSE
NO. DPR-80 AND DPR-82 FOR THE DIABLO CANYON NUCLEAR POWER PLANT,
UNIT NOS. 1 AND 2 (TAC NOS. 77908 AND 77909)

By letter dated June 26, 1991, the Commission issued the subject amendment to
the Facility Operating License for Diablo Canyon Nuclear Power Plant, Unit
Nos. 1 and 2.

The Technical Specification page 3/4 2-20 inadvertently did not contain the
amendment number. The corrected page, 3/4 2-20 is enclosed. If you have any
questions regarding this correction, please contact me.

Sincerely,

A handwritten signature in cursive script that reads "Harry Rood".

Harry Rood, Senior Project Manager
Project Director V
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

Mr. J. D. Shiffer
Pacific Gas and Electric Company

Diablo Canyon

CC:
NRC Resident Inspector
Diablo Canyon Nuclear Power Plant
c/o U.S. Nuclear Regulatory Commission
P. O. Box 369
Avila Beach, California 93424

Mr. John Hickman
Senior Health Physicist
Environmental Radioactive Mgmt. Unit
Environmental Management Branch
State Department of Health Services
714 P Street, Room 616
Sacramento, California 95814

Dr. Richard Ferguson, Energy Chair
Sierra Club California
6715 Rocky Canyon
Creston, California 93432

Regional Administrator, Region V
U.S. Nuclear Regulatory Commission
1450 Maria Lane, Suite 210
Walnut Creek, California 94596

Ms. Sandra A. Silver
Mothers for Peace
660 Granite Creek Road
Santa Cruz, California 95065

Mr. Peter H. Kaufman
Deputy Attorney General
State of California
110 West A Street, Suite 700
San Diego, California 92101

Ms. Jacquelyn C. Wheeler
3303 Barranca Court
San Luis Obispo, California 93401

Ms. Nancy Culver
192 Luneta Street
San Luis Obispo, California 93401

Managing Editor
The County Telegram Tribune
1321 Johnson Avenue
P. O. Box 112
San Luis Obispo, California 93406

Michael M. Strumwasser, Esq.
Special Assistant Attorney General
State of California
Department of Justice
3580 Wilshire Boulevard, Room 800
Los Angeles, California 90010

Chairman
San Luis Obispo County Board of
Supervisors
Room 370
County Government Center
San Luis Obispo, California 93408

Richard F. Locke, Esq.
Pacific Gas & Electric Company
Post Office Box 7442
San Francisco, California 94120

POWER DISTRIBUTION LIMITS

SURVEILLANCE REQUIREMENTS

4.2.4.1 The QUADRANT POWER TILT RATIO shall be determined to be within the limit above 50% of RATED THERMAL POWER by:

- a. Calculating the ratio at least once per 7 days when the alarm is OPERABLE, and
- b. Calculating the ratio at least once per 12 hours during steady-state operation when the alarm is inoperable.

4.2.4.2 The QUADRANT POWER TILT RATIO shall be determined to be within the limit when above 75% of RATED THERMAL POWER with one Power Range channel inoperable by using the movable incore detectors to confirm that the normalized symmetric power distribution, obtained from the 4 pairs of symmetric thimble locations or from a full incore flux map per specification 3.3.3.2, is consistent with the indicated QUADRANT POWER TILT RATIO at least once per 12 hours.