Docket Nos. 50-275 and 50-323

> Mr. Gregory M. Rueger Nuclear Power Generation, B14A Pacific Gas and Electric Company 77 Beale Street, Room 1451 P.O. Box 770000 San Francisco, California 94177

Dear Mr. Rueger:

SUBJECT: ISSUANCE OF AMENDMENTS FOR DIABLO CANYON NUCLEAR POWER PLANT, UNIT NO. 1 (TAC NO. M88814) AND UNIT NO. 2 (TAC NO. M88815)

The Commission has issued the enclosed Amendment No. 92 to Facility Operating License No. DPR-80 and Amendment No. 91 to Facility Operating License No. DPR-82 for the Diablo Canyon Nuclear Power Plant, Unit Nos. 1 and 2, respectively. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated February 17, 1994, (reference LAR 94-02).

These amendments revise TS 3/4.3.2, "Engineered Safety Features Actuation System Instrumentation," Table 3.3-3, functional unit 6.c.2), Start Turbine-Driven Pump, and Table 3.3-4, functional unit 4.e, Negative Steam Pressure Rate - High. These amendments revise TS changes originally issued in License Amendments 84 and 83 for the Process Protection System Upgrade (Eagle 21).

A copy of the related Safety Evaluation is enclosed. A notice of issuance will be included in the Commission's next regular biweekly <u>Federal Register</u> notice.

Sincerely,

Original signed by:

Sheri R. Peterson, Project Manager Project Directorate V Division of Reactor Projects III/IV/V Office of Nuclear Reactor Regulation

Enclosures:

9404180035 940401 PDR ADDCK 05000275

1. Amendment No. 92 to DPR-80 2. Amendment No. 91 to DPR-82

PDR

3. Safety Evaluation

cc w/enclosures: See next page

1.30675

DISTRIBUTION		
Docket File	Region V (8)	OGC
EAdensam	KPerkins, RV	15B18
DHagan, 3206	NRC & Local PDRs	ACRS (10)
OPA, 2G5	DFoster-Curseen	P-315
JRoe	GHill (4), P1-37	SPeterson
TQuay	OC/LFDCB, 4503	
CGrimes, 11E22	PDV R/F	

OFFICE:	PDV/LA of-C	PDV/PM_0Q	HIGB,	ogc 48	PDV/Dirg?
NAME:	DFoster-Curseen	SPeterson:mk	JWe <b>r</b> meil	RBachmann	TQuay
DATE:	3 1/1/94	3 /14/94	3 /15/94	3 12/194	4/1/94

OFFICIAL RECORD COPY/ FILENAME: A:\DC88814.AMD

Docket Nos. 50-275 and 50-323

> Mr. Gregory M. Rueger Nuclear Power Generation, B14A Pacific Gas and Electric Company 77 Beale Street, Room 1451 P.O. Box 770000 San Francisco, California 94177

Dear Mr. Rueger:

SUBJECT: ISSUANCE OF AMENDMENTS FOR DIABLO CANYON NUCLEAR POWER PLANT, UNIT NO. 1 (TAC NO. M88814) AND UNIT NO. 2 (TAC NO. M88815)

The Commission has issued the enclosed Amendment No. 92 to Facility Operating License No. DPR-80 and Amendment No. 91 to Facility Operating License No. DPR-82 for the Diablo Canyon Nuclear Power Plant, Unit Nos. 1 and 2, respectively. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated February 17, 1994, (reference LAR 94-02).

These amendments revise TS 3/4.3.2, "Engineered Safety Features Actuation System Instrumentation," Table 3.3-3, functional unit 6.c.2), Start Turbine-Driven Pump, and Table 3.3-4, functional unit 4.e, Negative Steam Pressure Rate - High. These amendments revise TS changes originally issued in License Amendments 84 and 83 for the Process Protection System Upgrade (Eagle 21).

A copy of the related Safety Evaluation is enclosed. A notice of issuance will be included in the Commission's next regular biweekly <u>Federal Register</u> notice.

Sincerely,

Original signed by:

Sheri R. Peterson, Project Manager Project Directorate V Division of Reactor Projects III/IV/V Office of Nuclear Reactor Regulation

Enclosures: 1. Amendment No. 92 to DPR-80 2. Amendment No. 91 to DPR-82 3. Safety Evaluation cc w/enclosures: See next page	DISTRIBUTION Docket File EAdensam DHagan, 3206 OPA, 2G5 JRoe TQuay	Region V (8) OGC KPerkins, RV 15B18 NRC & Local PDRs ACRS (10) DFoster-Curseen P-315 GHill (4), P1-37 SPeterson OC/LFDCB, 4503 PDV P/E
	CGrimes, 11E22	PDV R/F

OFFICE:	PDV/LA df-C	PDV/PM_00	HIGB	OGC CAS	PDV/Ding?
NAME:	DFoster-Curseen	SPeterson:mk	JWermeil	RBachmann	TQuay
DATE:	3 1/1/94	3 /14/94	3 /15/94	3 12/194	4/1/94

OFFICIAL RECORD COPY/ FILENAME: A:\DC88814.AMD



#### UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

April 1, 1994

Docket Nos. 50-275 and 50-323

> Mr. Gregory M. Rueger Nuclear Power Generation, B14A Pacific Gas and Electric Company 77 Beale Street, Room 1451 P.O. Box 770000 San Francisco, California 94177

Dear Mr. Rueger:

ISSUANCE OF AMENDMENTS FOR DIABLO CANYON NUCLEAR POWER PLANT. SUBJECT: UNIT NO. 1 (TAC NO. M88814) AND UNIT NO. 2 (TAC NO. M88815)

The Commission has issued the enclosed Amendment No. 92 to Facility Operating License No. DPR-80 and Amendment No. 91 to Facility Operating License No. DPR-82 for the Diablo Canyon Nuclear Power Plant, Unit Nos. 1 and 2, respectively. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated February 17, 1994, (reference LAR 94-02).

These amendments revise TS 3/4.3.2, "Engineered Safety Features Actuation System Instrumentation," Table 3.3-3, functional unit 6.c.2), Start Turbine-Driven Pump, and Table 3.3-4, functional unit 4.e, Negative Steam Pressure Rate - High. These amendments revise TS changes originally issued in License Amendments 84 and 83 for the Process Protection System Upgrade (Eagle 21).

A copy of the related Safety Evaluation is enclosed. A notice of issuance will be included in the Commission's next regular biweekly Federal Register notice.

Sincerely,

Steri R Peterson

Sheri R. Peterson, Project Manager Project Directorate V Division of Reactor Projects III/IV/V Office of Nuclear Reactor Regulation

Enclosures:

- 1. Amendment No. 92 to DPR-80 2. Amendment No. 91 to DPR-82
- 3. Safety Evaluation

cc w/enclosures: See next page

Mr. Gregory M. Rueger Pacific Gas and Electric Company

cc: NRC Resident Inspector Diablo Canyon Nuclear Power Plant c/o U.S. Nuclear Regulatory Commission P. O. Box 369 Avila Beach, California 93424

Dr. Richard Ferguson, Energy Chair Sierra Club California 6715 Rocky Canyon Creston, California 93432

Ms. Nancy Culver San Luis Obispo Mothers for Peace P. O. Box 164 Pismo Beach, California 93448

Ms. Jacquelyn C. Wheeler P. O. Box 164 Pismo Beach, California 93448

Managing Editor The County Telegram Tribune 1321 Johnson Avenue P. O. Box 112 San Luis Obispo, California 93406

Chairman San Luis Obispo County Board of Supervisors Room 370 County Government Center San Luis Obispo, California 93408

Mr. Truman Burns Mr. Robert Kinosian California Public Utilities Commission 505 Van Ness, Rm. 4102 San Francisco, California 94102

Diablo Canyon Independent Safety Committee ATTN: Robert R. Wellington, Esq. Legal Counsel 857 Cass Street, Suite D Monterey, California 93940

Diablo Canyon

Mr. Steve Hsu Radiologic Health Branch State Department of Health Services Post Office Box 942732 Sacramento, California 94234

Regional Administrator, Region V U.S. Nuclear Regulatory Commission 1450 Maria Lane, Suite 210 Walnut Creek, California 94596

Mr. Peter H. Kaufman Deputy Attorney General State of California 110 West A Street, Suite 700 San Diego, California 92101

Christopher J. Warner, Esq. Pacific Gas & Electric Company Post Office Box 7442 San Francisco, California 94120

Mr. John Townsend Vice President and Plant Manager Diablo Canyon Power Plant P. O. Box 56 Avila Beach, California 93424



ور ا

UNITED STATES

WASHINGTON, D.C. 20555-0001

# PACIFIC GAS AND ELECTRIC COMPANY

# DOCKET NO. 50-275

# DIABLO CANYON NUCLEAR POWER PLANT, UNIT NO. 1

# AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 92 License No. DPR-80

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Pacific Gas & Electric Company (the licensee) dated February 17, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-80 is hereby amended to read as follows:

9404180040 94040 ADOCK 05000275 PDR

# (2) <u>Technical Specifications</u>

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 92, are hereby incorporated in the license. Pacific Gas & Electric Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan, except where otherwise stated in specific license conditions.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Sheri R. Dittere

\^ Theodore R. Quay, Director
Project Directorate V
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: April 1, 1994



٩

UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

# PACIFIC GAS AND ELECTRIC COMPANY

# DOCKET NO. 50-323

# DIABLO CANYON NUCLEAR POWER PLANT, UNIT NO. 2

# AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 91 License No. DPR-82

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Pacific Gas & Electric Company (the licensee) dated February 17, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-82 is hereby amended to read as follows:

# (2) <u>Technical Specifications</u>

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 91 , are hereby incorporated in the license. Pacific Gas & Electric Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan, except where otherwise stated in specific license conditions.

3. This license amendment is effective as of the date of its issuance, to be implemented for cycle 7.

FOR THE NUCLEAR REGULATORY COMMISSION

Sheri R. Peterson

Theodore R. Quay, Director Project Directorate V Division of Reactor Projects III/IV/V Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: April 1, 1994

# ATTACHMENT TO LICENSE AMENDMENTS

•

# AMENDMENT NO. 92 TO FACILITY OPERATING LICENSE NO. DPR-80

# AND AMENDMENT NO. 91 TO FACILITY OPERATING LICENSE NO. DPR-82

### DOCKET NOS. 50-275 AND 50-323

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change. Overleaf pages are also included, as appropriate.

REMOVE	INSERT
3/4 3-19	3/4 3-19
3/4 3-26	3/4 3-26
3/4 3-27	3/4 3-27

# TABLE 3.3-5

# ENGINEERED SAFETY FEATURES RESPONSE TIMES

INITIATING SIGNAL AND FUNCTION RESPONSE TIME IN SECONDS						
1.	Man	ual 1	Initiation			
	<b>a</b> .	Saf	ety Injection (ECCS)	N.A.		
		1) 2) 3) 4) 5)	Feedwater Isolation Reactor Trip Phase "A" Isolation Containment Ventilation Isolati Auxiliary Feedwater	N.A. N.A. N.A. on N.A. N.A.		
		6) 7) 8)	Component Cooling Water Containment Fan Cooler Units Auxiliary Saltwater Pumps	N.A. N.A. N.A.		
	b.	Pha	se "B" Isolation			
		1) 2)	Containment Spray (Coincident w SI Signal) Containment Ventilation Isolati	ith N.A. on N.A.		
	c.	Phas	se "A" Isolation			
		1)	Containment Ventilation Isolati	on N.A.		
	d.	Stea	am Line Isolation	N.A.		
2.	Cont	tainm	ent Pressure-High			
	a.	Safe 1) 2) 3) 4) 5) 6) 7) 8)	ety Injection (ECCS) Reactor Trip Feedwater Isolation Phase "A" Isolation Containment Ventilation Isolatic Auxiliary Feedwater Component Cooling Water Containment Fan Cooler Units Auxiliary Saltwater Pumps	$ \leq 27^{(7)}/25^{(4)} \\ \leq 2 \\ \leq 63 \\ \leq 18^{(1)}/28^{(3)} \\ \text{on} \qquad \text{N.A.} \\ \leq 60^{(3)} \\ \leq 38^{(1)}/48^{(3)} \\ \leq 40^{(3)} \\ \leq 48^{(1)}/58^{(3)} $		
3.	Pres	suri	zer Pressure-Low			
	a.	Safe 1) 2) 3) 4) 5) 6) 7) 8)	ty Injection (ECCS) Reactor Trip Feedwater Isolation Phase "A" Isolation Containment Ventilation Isolatic Auxiliary Feedwater Component Cooling Water Containment Fan Cooler Units Auxiliary Saltwater Pumps	$\leq 27^{(7)}/25^{(4)}/35^{(5)} \\ \leq 2 \\ \leq 63 \\ \leq 18^{(1)} \\ \text{On} \qquad \text{N.A.} \\ \leq 60^{(3)} \\ \leq 48^{(3)}/38^{(1)} \\ \leq 40^{(3)} \\ \leq 58^{(3)}/48^{(1)} \\ \end{cases}$		

.

DIABLO CANYON - UNITS 1 & 2 3/4 3-28 Amendment Nos. 51 & 50; 72 & 71, 77 & 76

ł

1

# TABLE 3.3-4 (Continued) ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

DIABLO CANYON - UNITS 1 & 2	FUNC	TIONA	AL UNIT	TRIP SETPOINT	ALLOWABLE VALUES				
	7.	Loss (4.1	s of Power 16 kV Emergency Bus Undervoltage) First Lovel						
		a.	1) Diesel Start	≥ 0 volts with a ≤ 0.8 second time delay and ≥ 2583 volts with a	≥ 0 volts with a ≤ 0.8 second time delay and ≥ 2583 volts with a				
			2) Initiation of Load Shed	<pre>≤ 10 second time delay One relay ≥ 0 volts with a ≤ 4 second time delay and ≥ 2583 volts with a ≤ 25 second time delay</pre>	<pre>≤ 10 second time delay One relay ≥ 0 volts with a ≤ 4 second time delay and ≥ 2583 volts with a &lt; 25 second time delay</pre>				
ω		Ь	Second Level	with one relay ≥ 2870 volts, instantaneous	with one relay ≥ 2870 volts, instantaneous				
/4 3-2			1) Diesel Start	$\geq$ 3785 volts with a $\leq$ 10 second time delay	≥ 3785 volts with a ≤ 10 second time delay				
27			2) Initiation of Load Shed	≥ 3785 volts with a ≤ 20 second time delay	≥ 3785 volts with a ≤ 20 second time delay				
Ameno	8.	Engi Syst	ineered Safety Features Actuation tem Interlocks						
dment		a. b.	Pressurizer Pressure, P-11 DELETED	≤ 1915 psig	≤ 1920.6 psig				
No		c.	Reactor Trip, P-4	N.A.	N.A.				
	NOTE	1:	Time constants utilized in the lead-lag controller for Steam Pressure - Low are $\tau_1$ = 50 seconds and $\tau_2$ = 5 seconds.						
• 90 • 90	NOTE	2: TD	Steam Generator Water Level Low-Low $= [B1(P)^3 + B2(P)^2 + B3(P) + B4][0.99]$	Trip Time Delay ]					
ري 14	Wher	e: P TD Geno	# RCS loop AT Equivalent to Power (%RTP), P ≤ 50% RTP # Time Delay for Steam Generator Water Level Low-Low Reactor Trip (in seconds) rators affected						
<del>8</del> 71,		B1 = -0.0072 B2 = +0.8181 B3 = -31.72							
, , ,	NOTE	3:	Time constants utilized in the rate- 50 seconds and $\tau_4 = 50$ seconds.	lag controller for Negative Steam Pres	sure Rate - High are $\tau_3$ =				

t SLIND . 2 N 3/4 3-21 Amendment Nos. <del>37 & 36</del>, <del>72 a 71,</del> <del>84 & 83, 86 & 85</del>, 92

ହ 91

# TABLE 3.3-3 (Continued)

.

.

# ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION

FUNCTIONAL UNIT					TOTAL NO. <u>OF CHANNELS</u>	CHANNELS TO_TRIP	MINIMUM CHANNELS <u>OPERABLE</u>	APPLICABLE MODES	ACTION
6.	Auxi	iliary	Feed	lwater					
	a.	Manu	al In	nitiation	l manual switch/pump	l manual switch/pump	l manual switch/pump	1, 2, 3	24
	b.	<ul> <li>b. Automatic Actuation Logic and Actuation Relays</li> <li>c. Stm. Gen. Water Level- Low-Low</li> <li>1) Start Motor- Driven Pumps</li> </ul>		2	1	2	1, 2, 3	22	
	c.								
				art Motor- iven Pumps					
			a.	Steam Generator Water Level- Low-Low	3/S.G.	2/S.G. in one S.G.	2/S.G. in each S.G.	1, 2, 3	20
			b.	RCS loop <b>∆</b> T	<b>4</b> (1/loop)	2	3	1, 2, 3	29
		2) Start Turbine- Driven Pump		art Turbine- iven Pump					
			a.	Steam Generator Water Level- Low-Low	3/S.G.	2/S.G. in any 2 S.G.	2/S.G. in each S.G.	1, 2, 3	20
			b.	RCS loop <b>∆</b> T	<b>4 (1/loop)</b>	2	3	1, 2, 3	29
	d. Undervoltage-RCP Bus Start Turbine- Driven Pump		2/bus	1/bus on both busses	1/bus	1	35		
	e. Safety Injection Start Motor-Driven Pumps			njection Start iven Pumps	See Item 1. ab requirements.	ove for all Safet	y Injection initi	ating function	s and

3/4 3-19 Amendment Nos. 61 & 60, 84 & 83, 92 & 91

# TABLE 3.3-3 (Continued)

# ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION

FUNCTIONAL UNIT					TOTAL NO. <u>OF CHANNELS</u>	CHANNELS TO TRIP	MINIMUM CHANNELS <u>OPERABLE</u>	APPLICABLE MODES	<u>ACTION</u>
	7.	Loss (4.) Unde	s of l 16 kV ervolt	Power Emergency Bus tage)					
		a.	First	t Level				1, 2, 3, 4	
			1) [	Diesel Start	1/Bus	1/Bus	1/Bus		16
			2)	Initiation of Load Shed	2/Bus	2/Bus	2/Bus		16
		b.	Sec	cond Level				1, 2, 3, 4	
			1)	Undervoltage Relays	2/Bus	2/Bus	2/Bus		16
			2)	Timers to Start Diesel	1/Bus	1/Bus	1/Bus		16
			3)	Timers to Shed Load	1/Bus	1/Bus	1/Bus		16
	8.	Engi Acti	ineero uation	ed Safety Features n System Interlocks					
		a.	Pre	essurizer Pressure, P-11	3	2	2	1, 2, 3	21
		b.	DEL	ETED					
		c.	Rea	nctor Trip, P-4	2	2	2	1, 2, 3	23

	ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS								
<u>FU</u>	NCTION	<u>al un</u>	<u>IT</u>	TRIP_SETPOINT	ALLOWABLE VALUES				
3.	Containment Isolation (Continued)								
	c.	Con	tainment Ventilation Isolation						
		1)	Automatic Actuation Logic and Actuation Relays	N.A.	N.A.				
	<ul> <li>2) Plant Vent Noble Gas Per the ODCP Activity-High (RM-14A and 14B)<sup>(a)</sup></li> <li>3) Safety Injection See Item 1. above for all Safety Inj Values.</li> </ul>								
			Safety Injection	See Item 1. above for all Safety Injection Trip Setpoints and Allowable Values.					
		4)	Containment Ventilation Exhaust Radiation-High (RM-44A and 44B) <sup>(b)</sup>	Per Specification 3.3.3	3.10				
4.	. Steam Line Isolation								
	a.	Man	ual	N.A.	N.A.				
	b. Automatic Actuation Logic and Actuation Relays		omatic Actuation Logic Actuation Relays	N.A.	N.A.				
	c.	Con	tainment Pressure-High-High	≤ 22 psig	≤ 22.3 psig				
	d.	Stea	am Line Pressure-Low	≥ 600 psig (Note 1)	≥ 594.6 psig (Note 1)				

# TABLE 3.3-4 (Continued)

.

Amendment Nos. 37 & 36 67 and 66, 78 and 68, 84 & 83

(a)The requirements for Plant Vent Noble Gas Activity-High (RM-14A and 14B) are not applicable following installation of RM-44A and 44B.

(b)The requirements for Containment Ventilation Exhaust Radiation-High (RM-44A and 44B) are applicable following installation of RM-44A and 44B.

# TABLE 3.3-4 (Continued)

DIAB	ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS																	
50 C	FUNC	CTIONA	L UN	IIT	TRIP SETPOINT	ALLOWABLE VALUES												
ANYO		e.	Neg	ative Steam Pressure Rate-High	≤ 100 psi (Note 3)	≤ 105.4 psi (Note 3)												
2   _	5.	Turt	ine	Trip and Feedwater Isolation														
UNITS		a.	Aut and	omatic Actuation Logic Actuation Relays	N.A.	N.A.												
1 & 2		b.	Ste Hig	am Generator Water level- h-High	≤ 75% of narrow range** instrument span each steam generator.	≤ 75.5% of narrow range** instrument span each steam generator.												
	6.	Auxi	liar	y Feedwater														
ω		a.	Man	ual	N.A.	N.A.												
/4 3-2		b.	Aut and	comatic Actuation Logic I Actuation Relays	N.A.	N.A.												
26 An		c.	Ste Wat	am Generator er Level-Low-Low	≥ 7.2% of narrow range instrument span each steam generator.	≥ 6.8% of narrow range instrument span each steam generator.												
lendi			Coi	ncident with:														
ment N			1)	RCS loop <b>∆</b> T Equivalent to Power ≤ 50% RTP	RCS loop ∆T variable input ≤ 50% RTP	RCS loop <b>∆</b> T variable input ≤ 51.5% RTP												
los.															With a time delay (TD)	TD (Note 2)	≤ (1.01)TD (Note 2)	
4			0r															
<del>م</del> 33			2)	RCS loop AT Equivalent to Power > 50% RTP														
Ł				With no time delay														
\$		d.	Unc	iervoltage – RCP	≥ 8050 volts	≥ 7730 volts												
\$		e.	Saf	fety Injection	See Item 1. above for all Sa Allowable Values.	fety Injection Trip Setpoints and												

72 & 71, 84 & 83, 92 & 91



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

# SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

# RELATED TO AMENDMENT NO. 92 TO FACILITY OPERATING LICENSE NO. DPR-80

# AND AMENDMENT NO. 91 TO FACILITY OPERATING LICENSE NO. DPR-82

# PACIFIC GAS AND ELECTRIC COMPANY

# DIABLO CANYON NUCLEAR POWER PLANT, UNITS 1 AND 2

# DOCKET NOS. 50-275 AND 50-323

# 1.0 INTRODUCTION

By letter of February 17, 1994, Pacific Gas and Electric Company (or the licensee) submitted a request for changes to the Technical Specifications (TS) for Diablo Canyon Power Plant (DCPP) Units 1 and 2. The proposed amendments would revise TS 3/4.3.2, "Engineered Safety Features Actuation System Instrumentation," Table 3.3-3, functional unit 6.c.2), Start Turbine-Driven Pump, and Table 3.3-4, functional unit 4.e, Negative Steam Pressure Rate -High. The proposed amendments would revise TS changes originally issued on October 7, 1993, in License Amendments 84 and 83 for the Process Protection System Upgrade (Eagle 21). Specifically, TS 3/4.3.2, "Engineered Safety Feature Actuation System Instrumentation," would be revised as follows:

- 1. Table 3.3-3, functional unit 6.c.2), channels to trip, would be changed from 2/steam generator in one steam generator to 2/steam generator in any 2 steam generators due to an administrative error.
- 2. Table 3.3-4 would be changed as follows:
  - Functional Unit 4.e., Negative Steam Pressure Rate High, trip setpoint and allowable value, would be changed from -100 psi/sec and -105.4 psi/sec to 100 psi and 105.4 psi, respectively.
  - b. A note would be added stating that the time constants utilized in the rate-lag controller for Negative Steam Pressure Rate - High, are equal to 50 seconds.



#### 2.0 EVALUATION

As part of the changes approved in License Amendments 84 and 83, Table 3.3-3, functional unit 6., Auxiliary Feedwater, item c., Steam Generator Water Level - Low-Low, requirements were revised to add a start of the motor-driven and turbine-driven auxiliary feedwater (AFW) pumps on reactor coolant system (RCS) loop delta-T. The addition of RCS loop delta-T AFW pump starts was the only intended change to functional unit 6.c. However, due to an administrative error, the channels to the trip column for the turbine-driven AFW pump start on steam generator water level - low-low was inadvertently changed from 2/Steam Generator in any 2 operating steam generators to 2/Steam Generator in one steam generator. The actuation logic for the turbine-driven AFW pump start on steam generator water level - low-low is not affected by the installation of Eagle 21 and the resistance temperature detector (RTD) bypass elimination changes. This administrative change to the turbine-driven AFW pump start function corrects the error and reflects the current actuation logic. The staff finds the proposed change acceptable.

On January 20, 1994, Westinghouse notified the licensee that the Eagle 21 TS issued in LA 84 and 83 required changes, and provided PG&E with corrected TS pages. Installation of Eagle 21 is scheduled for the Unit 1 sixth refueling outage (scheduled for March 1994) and the Unit 2 sixth refueling outage (scheduled for September 1994). As part of Eagle 21 installation, a new steam line break protection functional upgrade will be implemented to accommodate the removal of the steam flow signals and the comparison of steam line pressures. These ESF actuation signals have historically been the source of inadvertent safety injection (SI) actuations. The new protection logic uses low pressure and high negative steam pressure rate setpoints in each steam line, without comparison between steam lines, to initiate mitigating actions for steam line break (SLB) scenarios. Included in the new steam line break protection logic is a steam line isolation (SLI) signal generated on high negative steam pressure rate below the P-11 Pressurizer Pressure Low (P-11) setpoint.

With the new SLB protection logic, SI and SLI on high steam line flow coincident with either low steam line pressure or Lo-Lo  $T_{avg}$  are deleted; SI on high steam line differential pressure would also be deleted. These would be replaced with SI and SLI on low steam line pressure and SLI on high negative steam pressure rate when below P-11. Manual block switches allow operators to switch from the low steam line pressure protection to steam line pressure rate during normal heatup and cooldown operations while in Mode 3 below P-11.

There is no DCPP **specific accident analysis that credits mitigation via the** Negative Steam Line Pressure Rate - High, trip function. With the exception of the Boron Dilution event, no licensing basis event is limiting at an RCS pressure below the P-11 setpoint.

The 100 psi setpoint with rate-lag time constants equal to 50 seconds is employed at most Westinghouse plants with new steam line break protection.

The setpoint was chosen such that the protection setpoint would not be reached during a normal cooldown (with allowance for short term perturbations) and yet would provide automatic protection for rapid steam line depressurizations consistent with steam line breaks.

While typical cooldown rates are on the order of 50 degrees F/hour, larger perturbations were considered such that a "bounding" setpoint of 2.0 psi/sec was selected. Analytical work performed for Westinghouse plants demonstrated this setpoint would be reached for a spectrum of steam line breaks. At a constant depressurization of 2.0 psi/sec in a steamline, the output from the rate-lag filter asymptotically approaches the trip setpoint of 100 psi. At constant rates of greater than 2.0 psi/sec, the output from the rate-lag filter will exceed the trip setpoint of 100 psi. A greater depressurization rate (e.g., 10 psi/sec) will result in a shorter period of time before the trip setpoint is exceeded.

The rate-lag time constants are input into the Eagle 21 algorithm code as  $\tau_3$ and  $\tau_4$ , both set equal to 50 seconds. To more adequately define the Negative Steam Pressure Rate - High function, the licensee is proposing to change the units of the setpoint and allowable value from psi/sec to psi and to add Note 3 to Table 3.3-4. The proposed Note 3 states: "Time constants utilized in the rate-lag controller for Negative Steam Pressure Rate - High are  $\tau_3 = 50$ seconds and  $\tau_4 = 50$  seconds." Additionally, the negative signs would be deleted from the numerical values for the trip setpoint and allowable value. Since the heading for functional unit 4.e. already indicates a "negative" rate of pressure change, the additional minus signs could cause confusion.

The changes proposed in this license amendment request more adequately define the trip setpoint and allowable values to be consistent with the original intent of License Amendments 84 and 83 and actual plant practice. These clarifying changes do not involve changes to the actual values themselves or the manner in which they are used. In addition, these proposed changes are consistent with other similar values' signs/units located within Table 3.3-4, i.e., functional unit 4.d., Steam Line Pressure - Low.

Based on the above, the staff finds the proposed changes acceptable.

#### 3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the California State official was notified of the proposed issuance of the amendments. The State official had no comments.

#### 4.0 ENVIRONMENTAL CONSIDERATION

These amendments change a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and change surveillance requirements. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (59 FR 9789). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

#### 5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: S. Peterson

Date: April 1, 1994