

September 1, 1995

Mr. Gregory M. Rueger
Pacific Gas and Electric Company
NPG - Mail Code A10D
P. O. Box 770000
San Francisco, California 94177

SUBJECT: CORRECTION TO AMENDMENTS 107 AND 106 FOR DIABLO CANYON NUCLEAR
POWER PLANT, UNITS 1 AND 2 (TAC NO. M92768)

Dear Mr. Rueger:

On August 23, 1995, the Commission issued Amendment No. 107 to Facility Operating License No. DPR-80 and Amendment No. 106 to Facility Operating License No. DPR-82 for the Diablo Canyon Nuclear Power Plant, Unit Nos. 1 and 2 (DCPP). The amendments revised the combined technical specifications (TS) to add Mode 1 applicability to TS 3/4.4.2.2, "Safety Valves - Operating," and to change the low-temperature overpressure protection (LTOP) system enable temperature for Mode 4 applicability from 323 degrees F to 270 degrees F in TS 3/4.4.2.2, "Safety Valves - Operating."

Your staff informed us of an error in the supporting Safety Evaluation that referenced an incorrect TS number and title. Enclosed is a corrected copy of the Safety Evaluation with marginal lines indicating the areas that were changed. We apologize for any inconvenience this may have caused.

Sincerely,

ORIGINAL SIGNED BY:

James C. Stone, Senior Project Manager
Project Directorate IV-2
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket Nos. 50-275
and 50-323

Enclosure: Safety Evaluation

cc w/encl: See next page

DISTRIBUTION:

Docket
PUBLIC
PDIV-2 Reading
EGA1
JRoe
WBateman
KPerkins, WCFO
JStone
LHurley, RIV
JBianchi, WCFO (2)

CGrimes
GHill (4)
BJones
EPeyton
DChamberlain, RIV
OGC
ACRS (4)

OFC	PDIV-2	PDIV-2 <i>JCS</i>	
NAME	<i>ESP</i> EPeyton:esp	JStone	
DATE	9/1/95	9/1/95	

OFFICIAL RECORD COPY Document Name:

LF01
111
CP-1

NRC FILE CENTER COPY

180003

9509180141 950901
PDR ADOCK 05000275
P PDR

September 1, 1995

Mr. Gregory M. Rueger
Pacific Gas and Electric Company
NPG - Mail Code A10D
P. O. Box 770000
San Francisco, California 94177

SUBJECT: CORRECTION TO AMENDMENTS 107 AND 106 FOR DIABLO CANYON NUCLEAR
POWER PLANT, UNITS 1 AND 2 (TAC NO. M92768)

Dear Mr. Rueger:

On August 23, 1995, the Commission issued Amendment No. 107 to Facility Operating License No. DPR-80 and Amendment No. 106 to Facility Operating License No. DPR-82 for the Diablo Canyon Nuclear Power Plant, Unit Nos. 1 and 2 (DCPP). The amendments revised the combined technical specifications (TS) to add Mode 1 applicability to TS 3/4.4.2.2, "Safety Valves - Operating," and to change the low-temperature overpressure protection (LTOP) system enable temperature for Mode 4 applicability from 323 degrees F to 270 degrees F in TS 3/4.4.2.2, "Safety Valves - Operating."

Your staff informed us of an error in the supporting Safety Evaluation that referenced an incorrect TS number and title. Enclosed is a corrected copy of the Safety Evaluation with marginal lines indicating the areas that were changed. We apologize for any inconvenience this may have caused.

Sincerely,

ORIGINAL SIGNED BY:

James C. Stone, Senior Project Manager
Project Directorate IV-2
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket Nos. 50-275
and 50-323

Enclosure: Safety Evaluation

cc w/encl: See next page

DISTRIBUTION:

Docket
PUBLIC
PDIV-2 Reading
EGA1
JRoe
WBateman
KPerkins, WCFO
JStone
LHurley, RIV
JBianchi, WCFO (2)

CGrimes
GHill (4)
BJones
EPeyton
DChamberlain, RIV
OGC
ACRS (4)

OFC	PDIV-2	PDIV-2 <i>JM</i>	
NAME	<i>EPeyton</i> EPeyton:esp	JStone	
DATE	9/1/95	9/1/95	

OFFICIAL RECORD COPY Document Name:

Mr. Gregory M. Rueger

- 2 -

cc w/encl:

NRC Resident Inspector
Diablo Canyon Nuclear Power Plant
c/o U.S. Nuclear Regulatory Commission
P. O. Box 369
Avila Beach, California 93424

Dr. Richard Ferguson, Energy Chair
Sierra Club California
1100 11th Street, Suite 311
Sacramento, California 95814

Ms. Nancy Culver
San Luis Obispo
Mothers for Peace
P. O. Box 164
Pismo Beach, California 93448

Ms. Jacquelyn C. Wheeler
P. O. Box 164
Pismo Beach, California 93448

Managing Editor
The County Telegram Tribune
1321 Johnson Avenue
P. O. Box 112
San Luis Obispo, California 93406

Chairman
San Luis Obispo County Board of
Supervisors
Room 370
County Government Center
San Luis Obispo, California 93408

Mr. Truman Burns
Mr. Robert Kinosian
California Public Utilities Commission
505 Van Ness, Room 4102
San Francisco, California 94102

Mr. Steve Hsu
Radiologic Health Branch
State Department of Health Services
Post Office Box 942732
Sacramento, California 94232

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Harris Tower & Pavillion
611 Ryan Plaza Drive, Suite 400
Arlington, Texas 76011-8064

Mr. Peter H. Kaufman
Deputy Attorney General
State of California
110 West A Street, Suite 700
San Diego, California 92101

Christopher J. Warner, Esq.
Pacific Gas & Electric Company
Post Office Box 7442
San Francisco, California 94120

Mr. Warren H. Fujimoto
Vice President and Plant Manager
Diablo Canyon Nuclear Power Plant
P. O. Box 56
Avila Beach, California 93424

Diablo Canyon Independent Safety
Committee
ATTN: Robert R. Wellington, Esq.
Legal Counsel
857 Cass Street, Suite D
Monterey, California 93940



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 107 TO FACILITY OPERATING LICENSE NO. DPR-80
AND AMENDMENT NO. 106 TO FACILITY OPERATING LICENSE NO. DPR-82
PACIFIC GAS AND ELECTRIC COMPANY
DIABLO CANYON NUCLEAR POWER PLANT, UNITS 1 AND 2
DOCKET NOS. 50-275 AND 50-323

1.0 INTRODUCTION

By application dated June 29, 1995, Pacific Gas and Electric Company (or the licensee) requested changes to the Technical Specifications (Appendix A to Facility Operating License Nos. DPR-80 and DPR-82) for the Diablo Canyon Nuclear Power Plant, Units 1 and 2 (DCPP). The proposed changes would revise the combined Technical Specifications (TS) for DCPP to add Mode 1 applicability to TS 3/4.4.2.2, "Safety Valves - Operating," and to change the low-temperature overpressure protection (LTOP) system enable temperature for Mode 4 applicability from 323 degrees F to 270 degrees F in TS 3/4.4.2.2, "Safety Valves - Operating."

2.0 EVALUATION

The licensee's submission of License Amendment Request (LAR) 94-07 dated August 17, 1994, inadvertently deleted Mode 1 applicability of TS 3/4.4.2.2, "Safety Valves - Operating." The staff concurs with the licensee that the change to restore Mode 1 applicability to this specification is appropriate.

The licensee proposed changes to the TS associated with the LTOP system enable temperature in two submittals, LARs 94-07 and 94-09, both dated August 17, 1994. LAR 94-09 proposed a change in the system enable temperature from 323 degrees F to 270 degrees F. The staff issued the associated amendment (100/99 for Units 1 and 2, respectively) on April 13, 1995, approving the new system enable temperature. The licensee's submittal for LAR 94-07 added a reference to the system enable temperature to TS 3/4.4.2.2, "Safety Valves - Operating," and included the 323 degrees F value. The licensee now proposes to revise the value contained in TS 3/4.4.2.2 to 270 degrees F to be consistent with the safety evaluation for Amendment 100/99 and the system enable temperature contained elsewhere in the TS. The staff concurs with the licensee that the change to include the correct system enable temperature in TS 3/4.4.2.2 is appropriate.

3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the California State official was notified of the proposed issuance of the amendments. The State official had no comments.

4.0 ENVIRONMENTAL CONSIDERATION

These amendments change a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (60 FR 37098). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: M. A. Miller

Date: August 23, 1995