

KNPP/NRC Meeting Covering:

Licensing Submittals for
Fuel Transition and
Power Uprates (MUR and Stretch)

August 8, 2002

Rockville, MD

Participants

- KNPP Participants
 - Jerry Riste - Licensing Manager
 - Harv Hanneman - Power Uprate Project Manager
 - John Holly - Analytical Lead for AST, Fuel Transition, and Power Uprate
 - Lynne Gunderson - Power Uprate Licensing Lead
 - Ted Maloney – Licensing Engineer

- NRC Participants

2

Agenda

- Purpose
- Overview
- Submittals Associated with Power Uprate
 - Alternate Source Term (AST) Submittal Status
 - Core Operating Limits Report (COLR) Status
 - Fuel Transition Status
 - Gothic 7.0 Containment Analysis Methodology
 - Measurement Uncertainty Recapture (MUR) Uprate
 - Stretch Uprate
- License Amendment Schedules/Interdependencies
- Summary/Wrap-Up

3

Purpose

- Update the NRC Staff on recent and planned submittals that support power uprates including:
 - AST, COLR, and Fuel Transition (already submitted)
 - Gothic 7.0, MUR, and Stretch (proposed submittals)
- Discuss individual submittal contents and proposed schedule
- Discuss the integrated analyses, schedule, and interdependencies
- Obtain NRC feedback


4

Overview

- Transition to Westinghouse Fuel (April 2003)
- T_{ave} increase (April 2003)
- KNPP originally designed for higher power
- A 7.4% Power Uprate in two steps
 - Measurement Uncertainty Recapture Uprate (1.4%)
 - Submittal December 2002
 - Implementation May 2003
 - Stretch Power Uprate (additional 6%)
 - Submittal February 2003
 - Implementation December 2003
- Submittals/analyses interdependencies

5

Overview



6

AST Submittal

- Overview of submittal
 - Original submittal sent 03/19/02
 - Selective Implementation
 - RAI Responses
 - Approval needed by 12/02
- Links to other submittals/schedule:
 - Fuel transition radiological analyses based on AST
 - MUR uprate will use the same AST analyses
 - AST analyses will be evaluated/reperformed for Stretch

7

COLR Submittal

- Overview of submittal
 - LAR 185 submitted 07/26/02
 - Standard COLR format
 - Approval needed by 02/03
- Links to other submittals/schedule:
 - Fuel transition assumed COLR was approved
 - COLR to be used for Cycle 26
 - MUR and Stretch LARs will also assume COLR

8

Fuel Transition Submittal

- Overview of Submittal
 - LAR 187 submitted 07/26/02
 - Fuel transition from FRA-ANP to Westinghouse 422V+
 - Reload Transition Safety Report (RTSR)
 - Fuel Analysis (100.6% of 1772 MWt with T_{ave} band of 556.3°F – 573.0°F)
 - LOCA and non-LOCA accident analyses performed at 7.4% uprate (100.6% of 1772 MWt with T_{ave} band)

9

Fuel Transition Submittal

- Overview of Submittal
 - Radiological accident analyses use AST (102% of 1650 MWt)
 - Technical Specification and COLR changes
 - Actual Cycle 26 Reload Safety Evaluation and COLR need to be completed prior to 2003 Refueling Outage
 - Approval needed by 02/03

10

Fuel Transition Submittal

- Links to other submittals
 - Requires approval of AST and COLR
 - Provides the LOCA and non-LOCA accident analyses for MUR and Stretch Uprates
 - The LAR 187 LOCA and non-LCOA accident analyses will be referenced in the MUR and Stretch Uprate submittals

11

Gothic 7.0 Submittal

- Overview of Proposed Submittal
 - Gothic 6.0 containment evaluation model approved for KNPP DBA's, LOCA, and MSLB
 - Gothic 7.0 with MDLM required for power uprate containment analysis
 - Submittal planned for 09/02
 - Approval needed by 03/03
- Links to other submittals/schedule:
 - Required for stretch uprate containment analysis only

12

Gothic 7.0 Submittal

- Technical Discussion Points
 - Mist Diffusion Layer Model (MDLM) used for heat and mass transfer
 - MDLM validated against 8 data sets from 5 different test facilities
 - KNPP containment analysis DBA's are covered by the validation database
 - Conservative factor applied to MDLM based on 95/95 statistics

13

Gothic 7.0 Submittal

- Technical Discussion Points
 - Code version upgrade has minimal impact on results
 - MDLM has a small impact on LOCA results and reduces MSLB peak pressure by 2 psi
 - MDLM conceptual model similar to that used in AP600 containment model

14

Proposed MUR Uprate Submittal

- Submittal to consider RIS 2002-03, MUR power uprate guidance
- AMAG Crossflow Ultrasonic Flow Measuring Device (UFMD):
 - Clamp on system (no spool piece)
 - Electronics Unit takes/receives data and calculates correction factors for venturi-measured FW flow and FW temperature.
 - Input to the PPCS for RTO calculation
 - Supports a power measurement uncertainty of $\pm 0.6\%$ allowing a 1.4% increase in licensed RTP from 1650 MWt to 1673 MWt

15

Proposed MUR Uprate Submittal

- Technically supported by CENPD-397-P-A, which was approved March 20, 2000, and is referenced in the following approved MUR uprates:
 - Salem SER 05/25/01
 - SONGS SER 07/06/01
 - Hope Creek SER 07/30/01

16

Proposed MUR Uprate Submittal

- Accident and Transient Analyses
 - Non-LOCA transients will reference Fuel Transition submittal (100.6% of 1772 MWt)
 - LOCA will reference Fuel Transition submittal (100.6% of 1772 MWt)
 - Radiological analyses will reference AST submittal (102% of 1650 MWt)
 - Containment Integrity analysis will reference RSG (50.59) (102% of 1650 MWt)

17

Proposed MUR Uprate Submittal

- Component Integrity and Design
 - New analyses supporting the 7.4% uprate and will bound the MUR
- Electrical Equipment Design
 - Evaluated for 7.4% uprate and will bound the MUR
 - Grid loading and stability studies performed by ATC for 7.4% uprate and will bound the MUR
 - No electrical equipment changes expected for MUR

18

Proposed MUR Uprate Submittal

- System Design
 - Evaluated for 7.4% uprate and will bound the MUR
- Other
 - Operations procedure and training changes
 - Simulator changes
 - Changes to protection system settings and emergency settings

19

Proposed MUR Uprate Submittal

- Expected License and Technical Specification Changes:
 - Operating License, Maximum Power Level will change to 1673 MWt
 - Definition of Rated Power will change to 1673 MWt
 - Methods for the COLR will include CENPD-397-P-A

20

Conclusion MUR Uprate

- Summary and conclusion for MUR
 - A 1.4% increase to a rated power of 1673 MWt
 - Achieved using AMAG Crossflow UFMD that has an NRC approved topical report
 - RIS 2002-03 guidance will be considered
 - Links to other submittals
 - Relies on analyses from AST and Fuel Transition
 - Assumes the COLR is approved

21

Conclusion MUR Uprate

- MUR Uprate Schedule
 - LAR submittal in December 2002
 - UFMD installation and commissioning complete by March 2003
 - Approval needed by April 2003 for implementation in May 2003

22

Stretch Power Uprate Overview

- Increase RTP by 6.0% from 1673 MWt to 1772 MWt
- Links to previous submittals:
 - AST (uses methodology)
 - Fuel Transition (LOCA and non-LOCA Accident Analysis)
 - Gothic 7.0 (uses methodology)

23

Stretch Power Uprate Overview

- Minimal Plant Modifications
 - FW valve trim change
 - I&C setpoint/range changes
 - Certain turbine bolting changes
- Proposed submittal content
 - Standard Westinghouse format for submittal (e.g. Byron/Braidwood)
 - References AST, Fuel Transition, and Gothic 7.0 analyses and methodologies
 - New analyses for systems/components, containment integrity, and radiological analyses


24

Stretch Power Uprate Overview

- Stretch Uprate Schedule
 - LAR submittal in February 2003
 - Approval needed by November 2003 to support implementation in December 2003

25

Summary/Wrap-up



26

Summary/Wrap-up

- Several submittal interdependencies
- Timely reviews and approvals needed to meet power uprate schedules
- NRC Feedback

27