

March 4, 1993

Docket Nos. 50-275  
and 50-323

Mr. Gregory M. Rueger  
Nuclear Power Generation, B14A  
Pacific Gas and Electric Company  
77 Beale Street, Room 1451  
P.O. Box 770000  
San Francisco, California 94177

Dear Mr. Rueger:

SUBJECT: REQUEST FOR RELIEF FROM THE ASME CODE INSPECTION REQUIREMENTS FOR  
CONTAINMENT ELECTRICAL PENETRATIONS, DIABLO CANYON UNITS 1 AND 2  
(TAC NOS. M84115 AND M84116)

By letters dated July 14, 1992, as supplemented February 8, 1993, you requested relief from the ASME Code requirements for inspection of containment electrical penetration welds. The relief request proposed substitution of the alternative requirements of Code case N-505, which has not been incorporated by reference in the appropriate Regulatory Guide. The staff concluded that the proposed alternative may be authorized pursuant to 10 CFR 50.55a(a)(3). This alternative will provide an acceptable level of quality and safety.

A copy of the related Safety Evaluation is enclosed. This completes the staff effort on this issue and closes TAC Nos. M84115 and M84116. If you have any questions regarding this matter, please contact Sheri Peterson at (301) 504-1325.

Sincerely,  
Original signed by  
Theodore R. Quay, Director  
Project Directorate V  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

Enclosures:  
Safety Evaluation

cc w/enclosure:  
See next page

DISTRIBUTION

Docket Files	NRC & LPDRs	PDV r/f	JRoe	TMurley/FMiraglia
MVirgilio	DFoster	SPeterson	TQuay	JPartlow
OGC	ERossi	JLieberman	EJordan	JMitchell
GHill (4)	ACRS (10)	OPA	OC/LFDCB	KPerkins, RV

\*See Previous Concurrence

OFC	LA/PDV*	PM/PDV*	OGC*	D/PDV <i>ml</i>
NAME	DFoster	SPeterson:lh	MYoung	TQuay
DATE	03/02/93	03/02/93	03/02/93	3 / 4 / 93

OFFICIAL RECORD COPY

DOCUMENT NAME:DC84115.REL

9303090475 930304  
PDR ADOCK 05000275  
PDR

345

NRC OFFICIAL COPY

*DF01*



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

March 4, 1993

Docket Nos. 50-275  
and 50-323

Mr. Gregory M. Rueger  
Nuclear Power Generation, B14A  
Pacific Gas and Electric Company  
77 Beale Street, Room 1451  
P.O. Box 770000  
San Francisco, California 94177

Dear Mr. Rueger:

SUBJECT: REQUEST FOR RELIEF FROM THE ASME CODE INSPECTION REQUIREMENTS FOR  
CONTAINMENT ELECTRICAL PENETRATIONS, DIABLO CANYON UNITS 1 AND 2  
(TAC NOS. M84115 AND M84116)

By letters dated July 14, 1992, as supplemented February 8, 1993, you requested relief from the ASME Code requirements for inspection of containment electrical penetration welds. The relief request proposed substitution of the alternative requirements of Code case N-505, which has not been incorporated by reference in the appropriate Regulatory Guide. The staff concluded that the proposed alternative may be authorized pursuant to 10 CFR 50.55a(a)(3). This alternative will provide an acceptable level of quality and safety.

A copy of the related Safety Evaluation is enclosed. This completes the staff effort on this issue and closes TAC Nos. M84115 and M84116. If you have any questions regarding this matter, please contact Sheri Peterson at (301) 504-1325.

Sincerely,

A handwritten signature in cursive script that reads "Theodore R. Quay".

Theodore R. Quay, Director  
Project Directorate V  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

Enclosure:  
Safety Evaluation

cc w/enclosure:  
See next page

Mr. Gregory M. Rueger  
Pacific Gas and Electric Company

Diablo Canyon

cc:

NRC Resident Inspector  
Diablo Canyon Nuclear Power Plant  
c/o U.S. Nuclear Regulatory Commission  
P. O. Box 369  
Avila Beach, California 93424

Mr. Hank Kocol  
Radiologic Health Branch  
State Department of Health Services  
Post Office Box 942732  
Sacramento, California 94234

Dr. Richard Ferguson, Energy Chair  
Sierra Club California  
6715 Rocky Canyon  
Creston, California 93432

Regional Administrator, Region V  
U.S. Nuclear Regulatory Commission  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596

Ms. Nancy Culver  
San Luis Obispo  
Mothers for Peace  
P. O. Box 164  
Pismo Beach, California 93448

Mr. Peter H. Kaufman  
Deputy Attorney General  
State of California  
110 West A Street, Suite 700  
San Diego, California 92101

Ms. Jacquelyn C. Wheeler  
3303 Barranca Court  
San Luis Obispo, California 93401

Michael M. Strumwasser, Esq.  
Special Assistant Attorney General  
State of California  
Department of Justice  
3580 Wilshire Boulevard, Room 800  
Los Angeles, California 90010

Managing Editor  
The County Telegram Tribune  
1321 Johnson Avenue  
P. O. Box 112  
San Luis Obispo, California 93406

Christopher J. Warner, Esq.  
Pacific Gas & Electric Company  
Post Office Box 7442  
San Francisco, California 94120

Chairman  
San Luis Obispo County Board of  
Supervisors  
Room 370  
County Government Center  
San Luis Obispo, California 93408

Mr. Truman Burns  
Mr. Robert Kinosian  
California Public Utilities Commission  
505 Van Ness, Rm. 4102  
San Francisco, California 94102

Diablo Canyon Independent Safety Committee  
ATTN: Robert R. Wellington, Esq.  
Legal Counsel  
857 Cass Street, Suite D  
Monterey, California 93940



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
REQUEST FOR RELIEF FROM THE ASME CODE INSPECTION REQUIREMENTS  
FOR CONTAINMENT ELECTRICAL PENETRATION WELDS  
PACIFIC GAS AND ELECTRIC COMPANY  
DIABLO CANYON POWER PLANT, UNITS 1 AND 2  
DOCKET NOS. 50-275 AND 50-323

1.0 INTRODUCTION

By letters dated July 14, 1992 and February 8, 1993, Pacific Gas and Electric (PG&E), the licensee, requested relief from the inspection requirements of ASME Code Section III, paragraph NE-5221. In place of NE-5221, the licensee proposed substitution of Code case N-505. NE-5221 specifies that volumetric methods, either radiography (RT) or ultrasonic (UT), be employed to inspect full penetration butt welds in containment penetrations. Code case N-505 provides for alternative use of liquid penetrant (PT) or magnetic particle (MT) examination of containment penetration welds. Code case N-505 has been adopted by the ASME Main Committee but its evaluation for incorporation by reference in the appropriate Regulatory Guide is pre-decisional, hence the need for NRC approval.

The proposed Code case application was for refueling outage work planned on four 12 inch diameter containment electrical penetrations at Diablo Canyon Power Plant Units 1 and 2. Two electrical penetrations on each unit were planned to be replaced during their respective refueling outages; unit 2 fifth refueling outage (2R5) and unit 1 sixth refueling outage (1R6). The final closure welds would be butt weld joints on the outside portion of containment electrical penetrations 10E and 6E (both units). The closure weld would be performed after the cables were reinstalled in the conduit.

The basis of the licensee's request was the impracticality of performing RT of a cable conduit with wires and cables inside. Their presence would interfere with the interpretation of a radiograph. The licensee has had unsatisfactory experiences with UT in previous similar applications. In the past, UT has resulted in false indications of flaws. This resulted in an excessive amount of weld repair and delays that were found to be unnecessary.

2.0 DISCUSSION

ASME Section III permits electrical penetration welds to be either lap joints with fillet welds or full penetration butt joints. Fillet welds can only be examined by means of a surface examination (PT or MT). Full penetration butt

welds are required by the Code to be examined by volumetric means (RT or UT). This is a more comprehensive, and thus more stringent, examination than the surface examination required of the fillet welds.

Code case N-505 permits surface examinations of the butt weld as it is being executed as an alternative to the volumetric examination requirement in Section III. This is accomplished by requiring PT or MT of the butt weld root pass and the completed weld. Since a majority of weld defects are found in either the root or final passes, this examination of both passes provides a reasonable assurance that a structurally sound weld is produced. For welds greater in thickness than 3/8 inch, an intermediate PT or MT examination is required after approximately half the weld thickness has been deposited.

A second requirement of the Code case is a reduction in the allowable stress for the weld joint. The allowable stress for the joint is reduced to 80% of that for a radiographed butt joint. This follows the practice of pressure vessel design wherein allowable joint strength is reduced by factors that are dependent upon the degree and type of weld examination. The staff finds this to be a reasonably conservative approach to structural design.

A prime function of the containment is leak isolation in the event of design basis events. In order to perform this function, leak tightness must be maintained to the maximum extent practical. This can be demonstrated by one of a variety of leak tests: pressure test with air, helium leak, or vacuum box. In addition to the surface examinations specified in the Code case, the licensee is required to perform a leak tightness test on the associated containment electrical penetration welds in accordance with Diablo Canyon Post Modification Test-45.06, "Pressurized Test of Conax Penetrations 06E and 10E Welds." Thus, the proposed alternative will provide reasonable assurance that the subject butt welds would perform the intended functions and, thus, provide an acceptable level of quality and safety.

### 3.0 CONCLUSION

Pursuant to 10 CFR 50.55a(a)(3), the use of other Code cases may be authorized by the staff. The licensee must demonstrate that (i) the proposed alternatives would provide an acceptable level of quality and safety, or (ii) compliance with the specified requirements of this section would result in hardship or unusual difficulties without a compensating increase in the level of quality and safety. The staff finds that the proposed use of Code case N-505 will provide an acceptable level of quality and safety and, pursuant to 10 CFR 50.55a(a)(3)(i), is authorized for use during refueling outages 2R5 and 1R6 at Diablo Canyon Power Plant.

Principal Contributor: G. Hornseth

Date: March 4, 1993

Docket Nos. 50-275  
and 50-323

Mr. Gregory M. Rueger  
Nuclear Power Generation, B14A  
Pacific Gas and Electric Company  
77 Beale Street, Room 1451  
P.O. Box 770000  
San Francisco, California 94177

Dear Mr. Rueger:

SUBJECT: REQUEST FOR RELIEF FROM THE ASME CODE INSPECTION REQUIREMENTS FOR  
CONTAINMENT ELECTRICAL PENETRATIONS, DIABLO CANYON UNITS 1 AND 2  
(TAC NOS. M84115 AND M84116)

By letters dated July 14, 1992, as supplemented February 8, 1993, you requested relief from the ASME Code requirements for inspection of containment electrical penetration welds. The relief request proposed substitution of the alternative requirements of Code case N-505, which has not been incorporated by reference in the appropriate Regulatory Guide. The staff concluded that the proposed alternative may be authorized pursuant to 10 CFR 50.55a(a)(3). This alternative will provide an acceptable level of quality and safety.

A copy of the related Safety Evaluation is enclosed. This completes the staff effort on this issue and closes TAC Nos. M84115 and M84116. If you have any questions regarding this matter, please contact Sheri Peterson at (301) 504-1325.

Sincerely,

Theodore R. Quay, Director  
Project Directorate V  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

Enclosures:  
Safety Evaluation

cc w/enclosure:  
See next page

DISTRIBUTION

Docket Files	NRC & LPDRs	PDV r/f	JRoe	TMurley/FMiraglia
MVirgilio	DFoster	SPeterson	TQuay	JPartlow
OGC	ERossi	JLieberman	EJordan	JMitchell
GHill (4)	ACRS (10)	OPA	OC/LFDCB	KPerkins, RV

OFC	LA/PDV	PM/PDV	OGC	D/PDV
NAME	DFoster	SPeterson:lh	M/Young	TQuay
DATE	3/2/93	3/2/93	3/2/93	1 /93

OFFICIAL RECORD COPY

DOCUMENT NAME:DC84115.REL