



Duane Arnold Energy Center
3277 DAEC Road
Palo, IA 52324-9785

Operated by Nuclear Management Company, LLC

August 15, 2002

NG-02-0698

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station 0-P1-17
Washington, DC 20555-0001

Subject: Duane Arnold Energy Center
Docket No: 50-331
Operating License: DPR-49
July 2002 Monthly Operating Report
File: A-118d

Please find enclosed the Duane Arnold Energy Center Monthly Operating Report. The report has been prepared in accordance with the guidelines of NRC Generic Letter 97-02: Revised Contents Of The Monthly Operating Report, and distribution has been made in accordance with DAEC Technical Specifications, Section 5.6.4.

Very truly yours,

John Bjerseth
Plant Manager-Nuclear

JKB/RBW

Enclosures

IE24

August 15, 2002

NG-02-0698

Page 2 of 2

cc:

Mr. James E. Dyer
Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Ms. Lisa Stump
Iowa State Utilities Board
Lucas State Office Building
Des Moines, IA 50319

Ms. Barbara Lewis
McGraw-Hill, Inc.
1200 G Street NW, Suite 1100
Washington, DC 20005

Dr. William A. Jacobs, Jr.
GDS Associates, Inc.
1850 Parkway Place, Suite 720
Marietta, GA 30068-8237

Mr. Dennis Murdock
Central Iowa Power Cooperative
Box 2517
Cedar Rapids, IA 52406

Mr. Dale Arends
Corn Belt Power Cooperative
1300 13th Street North
Humboldt, IA 50548

Document Control Desk
INPO Records Center
700 Galleria Parkway
Atlanta, GA 30339-5957

Mr. Al Gutterman
Morgan Lewis
1111 Pennsylvania Avenue, NW
Washington, DC 20004

Mr. Darl Hood
1 White Flint North
Mail Stop 8H4A
11555 Rockville Pike
Rockville, MD 20852


DOCU
NRC Resident Inspector
CTS Project

OPERATING DATA REPORT

DOCKET NO: 50-331
 DATE: 08-15-2002
 Unit: Duane Arnold Energy Center
 COMPLETED BY: Richard Woodward
 TELEPHONE: (319) 851-7318

OPERATING STATUS

1. Unit Name: Duane Arnold Energy Center
2. Reporting Period: July 2002
3. Licensed Thermal Power (MW_{th}): 1912
Tech Spec. Amendment 243 and TSCR for extended power uprate was implemented November 7, 2001. Current operating thermal power, as limited by balance-of-plant equipment, is 1790.
4. Nameplate Rating (Gross MW_e DER): 676 425
Current rated output, adjusted for as-built balance-of-plant conditions is 614 0.
5. Design Electrical Rating (Net MW_e DER): 581.4
6. Maximum Dependable Capacity (Gross MW_e MDC): 593.1
7. Maximum Dependable Capacity (Net MW_e MDC): 565.5
8. If Changes Occur in Capacity Ratings (Items Number 3 through 7) since the last report, give reasons: N/A
9. Power Level to Which Restricted, If Any (Net MW_e): N/A
10. Reasons for Restrictions, If Any: N/A



| | Jul-02 | 2002 | Cumulative |
|---|-------------|-------------|---------------|
| 11. Hours in Reporting Period | 744.0 | 5,087.0 | 241,031.0 |
| 12. Number of Hours Reactor Was Critical | 744.0 | 4,903.7 | 190,884.3 |
| 13. Reactor Reserve Shutdown Hours | 0.0 | 0.0 | 192.8 |
| 14. Hours Generator On-Line | 744.0 | 4,862.8 | 186,787.7 |
| 15. Unit Reserve Shutdown Hours | 0.0 | 0.0 | 0.0 |
| 16. Gross Thermal Energy Generated (MWH) | 1,323,984.9 | 8,539,621.5 | 273,038,251.3 |
| 17. Gross Electrical Energy Generated (MWH) | 444,221.0 | 2,919,111.0 | 91,653,328.6 |
| 18. Net Electrical Energy Generated (MWH) | 420,340.2 | 2,763,727.9 | 86,139,353.9 |
| 19. Unit Service Factor | 100.0% | 95.6% | 77.4% |
| 20. Unit A availability Factor | 100.0% | 95.6% | 77.4% |
| 21. Unit Capacity Factor (Using MDC Net) | 99.9% | 96.5% | 69.5% |
| 22. Unit Capacity Factor (Using DER Net) | 97.2% | 93.9% | 67.1% |
| 23. Unit Forced Outage Rate | 0.0% | 0.0% | 8.4% |

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of each): N/A
25. If Shutdown at End of Report Period, Estimated Date of Startup: N/A

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-331
 DATE: 08-15-2002
 Unit: Duane Arnold Energy Center
 COMPLETED BY: Richard Woodward
 TELEPHONE: (319) 851-7318

MONTH July 2002

| Day | Average Daily Power Level (MWe-Net) |
|-----|--|
| 1 | 569 |
| 2 | 568 |
| 3 | 566 |
| 4 | 568 |
| 5 | 566 |
| 6 | 574 |
| 7 | 567 |
| 8 | 559 |
| 9 | 565 |
| 10 | 572 |
| 11 | 576 |
| 12 | 579 |
| 13 | 557 |
| 14 | 498 |
| 15 | 575 |
| 16 | 574 |
| 17 | 569 |
| 18 | 567 |
| 19 | 564 |
| 20 | 556 |
| 21 | 559 |
| 22 | 567 |
| 23 | 576 |
| 24 | 577 |
| 25 | 570 |
| 26 | 569 |
| 27 | 565 |
| 28 | 559 |
| 29 | 568 |
| 30 | 564 |
| 31 | 554 |

REFUELING INFORMATION

DOCKET NO: 50-331
 DATE: 08-15-2002
 Unit: Duane Arnold Energy Center
 COMPLETED BY: Richard Woodward
 TELEPHONE: (319) 851-7318

1. Name of facility. Duane Arnold Energy Center
2. Scheduled date for next refueling shutdown. Spring 2003
3. Scheduled date for restart following refueling. Spring 2003
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment? No
5. Scheduled date(s) for submitting proposed licensing action and supporting information. N/A
6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures. N/A
7. Current fuel assemblies inventory

| | Number of Fuel Assemblies | Projected date of last refueling that can be discharged (after allowing margin for maintenance of continuous full-core discharge capability) |
|---|---------------------------------|--|
| Installed into reactor core | 368 | |
| Discharged from core to Spent Fuel Storage Pool | 1912 | |
| Scheduled for transfer to Dry Fuel Storage November 2003 | 610 | |
| Installed capacity of Spent Fuel Storage Pool | 2411 | 2008 |
| Licensed capacity of Spent Fuel Storage Pool (with re-racking) | 2829 | 2014 |
| Licensed capacity of Spent Fuel Storage Pool and Cask Pool (with reracking) | 3152 | |

DOCKET NO: 50-331
 DATE: 08-15-2002
 Unit: Duane Arnold Energy Center
 COMPLETED BY: Richard Woodward
 TELEPHONE: (319) 851-7318

UNIT SHUTDOWNS AND POWER REDUCTIONS
 REPORT MONTH: July 2002

| No. | Date | Type (1) | Duration (Hours) | Reason (2) | Method of Shutting Down Reactor (3) | Licensee Event Report # | Cause |
|-----|----------------|----------|--|------------|-------------------------------------|-------------------------|-------------------|
| 6 | 7/13 - 14/2002 | S | 0 (3.80 Effective-Full-Power-Hours) | B | 5 | | Sequence Exchange |
| | | | | | | | |

| | | |
|---|---|---|
| 1 - F: Forced S: Scheduled | 2 - Reason A-Equipment Failure (Explain) B-Maintenance or Test C-Refueling D-Regulatory Restriction E-Operator Training & License Examination F-Administrative G-Operational Error (Explain) H-Other (Explain) | 3 - Method: 1-Manual 2-Manual Scram 3-Automatic Scram 4-Continued 5-Reduced Load 9-Other (Explain) |
|---|---|---|

DOCKET NO.: 50-331
 DATE: 08-15-2002
 Unit: Duane Arnold Energy Center
 COMPLETED BY: Richard Woodward
 TELEPHONE: (319) 851-7318

Monthly Operational Overview for July 2002

At the beginning of July, the DAEC had continuously operated thirty-seven days.

On July 13th between 21:02 and midnight, operators reduced power from 1790 to 1030 MWth to perform a sequence exchange. Operators began increasing power at 03:30, and full power was achieved at 14:15 on July 14th.

Power was reduced to 1692 MWth on July 15th from 00:37 to 01:34 to adjust load line.

Power was reduced to 1700 MWth on July 16th from 04:31 to 05:37 for a control rod adjustment.

On July 20th at 17:13, operators reduced power to 1765 MWth for three hours when main condenser back pressure increased due to near record high wet-bulb temperatures. At 20:00, following a drop in ambient temperature, the condenser backpressure decreased, and full-power was restored.

The DAEC operated continuously at full-power for the remainder of the month.

| Following is the allocation of production and losses: | Electrical Output MWe | Capacity Factor % of 614 MWe (Target Output) | Full Power Equivalent Hours (FPHeq) |
|--|-----------------------|--|-------------------------------------|
| Net Electric Output | 564.94 | 92.01% | 684.59 |
| Plant House Loads (while on-line) | +32.11 | +5.23% | 38.90 |
| Subtotal: Gross Electric Output | 597.05 | 97.24% | 723.49 |
| Capacity Losses (departures from full thermal power): | | | |
| Sequence Exchange 7/13 21:02 - 7/14 14:15 | 3.14 | 0.51% | 3.80 |
| CRD Adjustments 7/15 00:37 - 01:34 & 7/16 04:31 - 05:37 | 0.02 | 0.00% | 0.02 |
| High Condenser Back Pressure 7/20 17:13 - 20:35 | 0.12 | 0.02% | 0.14 |
| Maintain Margin to 1790 Administrative MWth Limit | 0.34 | 0.06% | 0.41 |
| Efficiency Losses (occur even at full thermal power): | | | |
| Unidentified (residual) | (0.24) | (0.04%) | (0.30) |
| -/+ Seasonal Effects (i.e., hot weather decrease) | 13.57 | 2.21% | 16.44 |
| Subtotal: On-line Losses (Capacity, Efficiency, and Weather): | 16.95 | 2.76% | 20.51 |
| Off-Line Losses: (none) | 0.00 | 0.00% | 0.00 |
| Total: Target Electric Output, %, # of clock-hours | 614.00 | 100.00% | 744.00 |

On July 9th, the Containment Atmosphere Dilution (CAD) system Nitrogen Storage Inventory indication went below the Technical Specification (TS) minimum limit of 67,000 scf. The operator then re-pressurized the system to above the TS limit. Subsequent investigation found that a surveillance, previously performed that day, had left CAD nitrogen inventory near the 67,000 scf limit. The functional check of the CAD system had used a portion of the CAD nitrogen inventory by actually flowing nitrogen through a test rig. There were no actual safety consequences nor was there any impact on public health and safety as a result of this event. The event was reported under 50.72 (b)(3)(v)(D). (Event Notification #39049).

Licensing Action Summary:

| | | | |
|------------------------------|------|--|---|
| Plant Availability: | 100% | Unplanned Auto Scrams (while critical) this month: | 0 |
| Number of reportable events: | 1 | Unplanned Auto Scrams (while critical) last 12 months: | 0 |
| | | Main Steam Safety/Relief Valve Challenges this month: | 0 |