

November 17, 1993

Docket No. 50-529

Mr. William F. Conway
Executive Vice President, Nuclear
Arizona Public Service Company
P.O. Box 53999
Phoenix, Arizona 85072-3999

Dear Mr. Conway:

SUBJECT: CORRECTION TO NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT -
PALO VERDE NUCLEAR GENERATING STATION, UNIT 2 (TAC NO. M88173)

The Commission has requested the Office of the Federal Register to publish a correction to the enclosed "Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for Hearing" published on Monday, November 15, 1993 (58 FR 60223). The correction was done to extend the comment period from November 30, 1993, to December 15, 1993. This additional time will allow the public to have a full 30-day comment period even though the exigent notice will allow the amendment to be issued on November 30, 1993. This notice relates to your application for amendment dated November 5, 1993.

The proposed amendment would provide for a one-time extension of up to 72 hours to be applied to the existing Technical Specification (TS) Limiting Conditions for Operation for single train inoperability for the following systems: Emergency Core Cooling System, TS 3.5.2; Containment Spray System, TS 3.6.2.1; Auxiliary Feedwater System, TS 3.7.1.2; Essential Cooling Water System, TS 3.7.3; Essential Chilled Water System, TS 3.7.6; and Shutdown Cooling System, TS 3.7.11.

Sincerely,

Original signed by:
Brian E. Holian, Project Manager
Project Directorate V
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosure:
As Stated

cc w/enclosure:
See next page

DISTRIBUTION:

Docket File
JRoe
ACRS (10), P315
TQuay
Region V

NRC & Local PDRs
BHolian
OPA, 2G5
OGC, 15B18

PDV Reading File
LTran
EBarnhill
OC/LFDCB, 4503

OFFICE	PDV/LA	PDV/PM	PDV/D
NAME	EBarnhill <i>EB</i>	BHolian:mc <i>Bet</i>	TQuay <i>TQR</i>
DATE	11 / 16 / 93	11 / 17 / 93	11 / 17 / 93

OFFICIAL RECORD COPY

DOCUMENT NAME: PVCORAMD.NOT

DF01

9312020280 931017
PDR ADOCK 05000529
P PDR

NRC FILE CENTER COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

November 17, 1993

Docket No. 50-529

Mr. William F. Conway
Executive Vice President, Nuclear
Arizona Public Service Company
P.O. Box 53999
Phoenix, Arizona 85072-3999

Dear Mr. Conway:

SUBJECT: CORRECTION TO NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT -
PALO VERDE NUCLEAR GENERATING STATION, UNIT 2 (TAC NO. M88173)

The Commission has requested the Office of the Federal Register to publish a correction to the enclosed "Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for Hearing" published on Monday, November 15, 1993 (58 FR 60223). The correction was done to extend the comment period from November 30, 1993, to December 15, 1993. This additional time will allow the public to have a full 30-day comment period even though the exigent notice will allow the amendment to be issued on November 30, 1993. This notice relates to your application for amendment dated November 5, 1993.

The proposed amendment would provide for a one-time extension of up to 72 hours to be applied to the existing Technical Specification (TS) Limiting Conditions for Operation for single train inoperability for the following systems: Emergency Core Cooling System, TS 3.5.2; Containment Spray System, TS 3.6.2.1; Auxiliary Feedwater System, TS 3.7.1.2; Essential Cooling Water System, TS 3.7.3; Essential Chilled Water System, TS 3.7.6; and Shutdown Cooling System, TS 3.7.11.

Sincerely,

A handwritten signature in black ink, appearing to read "Brian E. Holian".

Brian E. Holian, Project Manager
Project Directorate V
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosure:
As Stated

cc w/enclosure:
See next page

Mr. William F. Conway
Arizona Public Service Company

Palo Verde

cc:

Mr. Steve Olea
Arizona Corporation Commission
1200 W. Washington Street
Phoenix, Arizona 85007

James A. Beoletto, Esq.
Southern California Edison Company
P. O. Box 800
Rosemead, California 91770

Senior Resident Inspector
Palo Verde Nuclear Generating Station
5951 S. Wintersburg Road
Tonopah, Arizona 85354-7537

Regional Administrator, Region V
U. S. Nuclear Regulatory Commission
1450 Maria Lane
Suite 210
Walnut Creek, California 94596

Mr. Charles B. Brinkman, Manager
Washington Nuclear Operations
ABB Combustion Engineering Nuclear Power
12300 Twinbrook Parkway, Suite 330
Rockville, Maryland 20852

Mr. Aubrey V. Godwin, Director
Arizona Radiation Regulatory Agency
4814 South 40 Street
Phoenix, Arizona 85040

Chairman
Maricopa County Board of Supervisors
111 South Third Avenue
Phoenix, Arizona 85003

Jack R. Newman, Esq.
Newman & Holtzinger, P.C.
1615 L Street, N.W., Suite 1000
Washington, D.C. 20036

Mr. Curtis Hoskins
Executive Vice President and
Chief Operating Officer
Palo Verde Services
2025 N. 3rd Street, Suite 220
Phoenix, Arizona 85004

Roy P. Lessey, Jr., Esq.
Bradley W. Jones, Esq.
Akin, Gump, Strauss, Hauer and Feld
El Paso Electric Company
1333 New Hampshire Ave., Suite 400
Washington, D.C. 20036

Mr. Ronald J. Stevens, Director
Nuclear Regulatory Affairs
Arizona Public Service Company
P. O. Box 52034
Phoenix, Arizona 85072-2034


ARIZONA PUBLIC SERVICE COMPANY
PALO VERDE NUCLEAR GENERATING STATION, UNIT 2
DOCKET NO. 50-529
NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO
FACILITY OPERATING LICENSE, PROPOSED NO SIGNIFICANT HAZARDS
CONSIDERATION DETERMINATION, AND OPPORTUNITY FOR A HEARING CORRECTION

In notice document 93-28122 beginning on page 60223, in the issue of Monday, November 15, 1993, make the following correction:

In the third full paragraph, in the first column, on page 60225, in line 1, the statement "By November 30, 1993" should be corrected to read "By December 15, 1993."

Dated at Rockville, Maryland, this 17th day of November 1993.

FOR THE NUCLEAR REGULATORY COMMISSION



Brian E. Holian, Project Manager
Project Directorate
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation