



Entergy Nuclear Northeast
Entergy Nuclear Operations, Inc
Vermont Yankee
185 Old Ferry Rd
P.O. Box 500
Brattleboro, VT 05302
Tel 802-257-5271

August 22, 2002
BVY 02-67

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

- References:
- (a) Letter, VYNPC to USNRC, "Technical Specification Proposed Change No. 250, Scram and Isolation Valve Closure Functions of the Main Steam Line Radiation Monitors," BVY 02-18, March 19, 2002
 - (b) Letter, VYNPC to USNRC, "Technical Specification Proposed Change No. 250, Supplement No. 1, Scram and Isolation Valve Closure Functions of the Main Steam Line Radiation Monitors," BVY 02-41, June 4, 2002
 - (c) Letter, VYNPC to USNRC, "Technical Specification Proposed Change No. 250, Scram and Isolation Valve Closure Functions of the Main Steam Line Radiation Monitors – Additional Information," BVY 02-49, July 16, 2002
 - (d) Letter, VYNPC to USNRC, "Technical Specification Proposed Change No. 250, Scram and Isolation Valve Closure Functions of the Main Steam Line Radiation Monitors – Additional Information No. 2," BVY 02-52, July 24, 2002

**Subject: Vermont Yankee Nuclear Power Station
License No. DPR-28 (Docket No. 50-271)
Technical Specification Proposed Change No. 250
Scram and Isolation Valve Closure Functions
of the Main Steam Line Radiation Monitors –
Additional Information No. 3**

By letter dated March 19, 2002 [Reference (a)] and supplemented by letter dated June 4, 2002 [Reference (b)], Vermont Yankee (VY) proposed to amend its Facility Operating License, DPR-28 by eliminating the reactor scram and main steam isolation valve closure requirements associated with the main steam line radiation monitors (MSLRMs) and modifying other requirements related to MSLRM trip functions. Additional information in this regard was provided by References (c) and (d). The information provided herewith supplements References (a) through (d) and responds to questions posed by NRC staff during a telephone conference conducted on August 19, 2002.


If you have any questions on this transmittal, please contact Mr. Gautam Sen at (802) 258-4111.

Sincerely,



Michael A. Balduzzi
Vice President, Operations

A001
DJH



STATE OF VERMONT)
)ss
WINDHAM COUNTY)

Then personally appeared before me, Michael A. Balduzzi, who, being duly sworn, that he is Vice President, Operations of Vermont Yankee Nuclear Power Station, that he is duly authorized to execute and file the foregoing document, and that the statements therein are true to the best of his knowledge and belief.

Sally A. Sandstrum
Sally A. Sandstrum, Notary Public
My Commission Expires February 10, 2003

Attachment

- cc: USNRC Region 1 Administrator (Attachment without CD-ROM)
- USNRC Resident Inspector – VYNPS (Attachment without CD-ROM)
- USNRC Project Manager – VYNPS (Attachment with CD-ROM)
- Vermont Department of Public Service (Attachment without CD-ROM)

Docket No 50-271
BVY 02-67

Attachment

Vermont Yankee Nuclear Power Station

Proposed Technical Specification Change No. 250

Scram and Isolation Valve Closure Functions of the
Main Steam Line Radiation Monitors

Additional Information No. 3

**RESPONSE TO NRC REQUEST FOR ADDITIONAL INFORMATION
Vermont Yankee Proposed Change No. 250**

RESPONSE TO RAI #4

Question 4: (paraphrased)

Please provide the bases (inputs and assumptions) for the following atmospheric dispersion factors (χ/Qs):

- a. Main stack to worst-case offsite receptor;
- b. Main stack to the low population zone (LPZ);
- c. Main stack to the control room intake; and
- d. Turbine building to the control room intake.

Response:

The χ/Qs in question appear in Table 1.2 of BVY 02-49 (Ref. c) for main stack releases to the worst-case offsite receptor and the LPZ, and in Table 3.2 of BVY 02-49 for main stack and turbine building releases to the control room. These χ/Qs are based on the design inputs and assumptions in Tables 4.1 through 4.4 of this document. Refer also to Table 2.1 of BVY 02-52 (Ref. d) for turbine building releases and receptors at the exclusion area boundary (EAB)

The attached CD ROM provides an update to the hourly meteorological data collected on site at Vermont Yankee during the years 1989-1993 that was transmitted in Reference (d). Namely, the stabilities derived from these files were based on the temperature difference between the upper (295-ft) and lower (33-ft) ΔT instrument levels. It is noted that the hourly meteorological databases employed in the computation of the χ/Qs addressed in this response (i.e., the databases for 1979 and 1985) are not included in the attached CD ROM.

All χ/Q values were generated with the Framatome ANP DE&S computer code SKIRON-II which implements the Regulatory Guide 1.145 methodology, along with a "sliding window" approach for averaging time spans greater than one hour.

**RESPONSE TO NRC REQUEST FOR ADDITIONAL INFORMATION
Vermont Yankee Proposed Change No. 250**

Table 4.1

**Design Input and Assumptions for Atmospheric Dispersion Factor Calculation
Main Stack Releases to Worst-Case Offsite Receptor**

Seq.	DESCRIPTION		VALUE
1	Atmospheric dispersion factors (χ/Q)	0 - 0.5 hr 0.5 - 1 hr 1 - 2 hr	2.03E-04 (fumig.) 1.54E-04 9.17E-05
2	Release height (stack height)		93.9 m
3	Building cross-sectional area and height for building wake effects		Not applicable
4	Plume meander		Not applicable
5	Minimum wind speed acceptable as valid observation, and wind speed assigned to calms		0.268 m/sec
6	Temperature sensor separation (295' -33')		79.9 m
7	Plume rise		Not applicable
8	Average depth of limited mixing layer (for plume reflection)		950 m
9	Critical receptor distances from stack, and associated terrain heights		
	1.	0-0.5 hr - fumigation condition (shortest distance from the stack to a receptor on the Site Area Boundary for Gaseous Effluents within a 45-degree sector centered on the compass direction of interest, per Sec. C.1.2 of Reg. Guide 1.145)	D = 253 m (WSW) h _t = 2.4 m
	2.	0.5 - 2 hr (where the terrain height first exceeds the stack height)	D = 2100 m (W) h _t = 106.1 m
10	Recirculation correction		Not considered
11	Meteorological data base		Hourly site data for 1985

**RESPONSE TO NRC REQUEST FOR ADDITIONAL INFORMATION
Vermont Yankee Proposed Change No. 250**

Table 4.2

**Design Input and Assumptions for Atmospheric Dispersion Factor Calculation
Main Stack Releases to LPZ**

Seq.	DESCRIPTION		VALUE
1	Atmospheric dispersion factors (χ/Q)	0 - 0.5 hr 0.5 - 1 hr 1 - 2 hr 2 - 8 hr 8 - 24 hr 24 - 96 hr 96 - 720 hr	2.55E-05 2.55E-05 1.87E-05 1.01E-05 1.09E-06 6.90E-07 4.61E-07
2	Release height (stack height)		93.9 m
3	Building cross-sectional area and height for building wake effects		Not applicable
4	Plume meander		Not applicable
5	Minimum wind speed acceptable as valid observation, and wind speed assigned to calms		0.268 m/sec
6	Temperature sensor separation (295'-33')		79.9 m
7	Plume rise		Not applicable
8	Average depth of limited mixing layer (for plume reflection)		950 m
9	Receptor distance from stack (all sectors)		5 miles (8047 m)
10	Terrain height at receptors (arbitrarily set higher than the release height of 93.9 m; i.e., plume centerline is at ground level)		100 m
11	Recirculation correction		Not considered
12	Meteorological data base		Hourly site data for 1985

**RESPONSE TO NRC REQUEST FOR ADDITIONAL INFORMATION
Vermont Yankee Proposed Change No. 250**

Table 4.3

**Design Input and Assumptions for Atmospheric Dispersion Factor Calculation
Main Stack Releases to Control Room Intake**

Seq.	DESCRIPTION	VALUE														
1	Atmospheric dispersion factors (χ/Q)	<table border="0"> <tr><td align="center">0 - 0.5 hr</td><td align="center">2.39E-04 (fumig.)</td></tr> <tr><td align="center">0.5 - 1 hr</td><td align="center">1.05E-06</td></tr> <tr><td align="center">1 - 2 hr</td><td align="center">8.70E-07</td></tr> <tr><td align="center">2 - 8 hr</td><td align="center">4.79E-07</td></tr> <tr><td align="center">8 - 24 hr</td><td align="center">2.34E-07</td></tr> <tr><td align="center">24 - 96 hr</td><td align="center">1.23E-07</td></tr> <tr><td align="center">96 - 720 hr</td><td align="center">6.90E-08</td></tr> </table>	0 - 0.5 hr	2.39E-04 (fumig.)	0.5 - 1 hr	1.05E-06	1 - 2 hr	8.70E-07	2 - 8 hr	4.79E-07	8 - 24 hr	2.34E-07	24 - 96 hr	1.23E-07	96 - 720 hr	6.90E-08
0 - 0.5 hr	2.39E-04 (fumig.)															
0.5 - 1 hr	1.05E-06															
1 - 2 hr	8.70E-07															
2 - 8 hr	4.79E-07															
8 - 24 hr	2.34E-07															
24 - 96 hr	1.23E-07															
96 - 720 hr	6.90E-08															
2	Release height (stack height)	93.9 m														
3	Building cross-sectional area and height for building wake effects	Not applicable														
4	Plume meander	Not applicable														
5	Minimum wind speed acceptable as valid observation, and wind speed assigned to calms	0.268 m/sec														
6	Temperature sensor separation (295'-33')	79.9 m														
7	Plume rise	Not applicable														
8	Average depth of limited mixing layer (for plume reflection)	950 m														
9	Receptor distances to critical locations, and terrain heights 1. 0 - 0.5 hr (Fumigation condition - d distance from stack to control room (CR) building) 2. 0.5 - 720 hrs (worst sector, distance from stack to CR air intake) [Note: The concentration at the intake is higher than at the CR building, since, for elevated plumes, the plume spreads closer to the ground as the distance from the release point increases.]	<table border="0"> <tr><td align="center">D = 213 m</td></tr> <tr><td align="center">h_t = 2.4 m</td></tr> <tr><td align="center">D = 259 m (SSE)</td></tr> <tr><td align="center">h_t = 2.4 m</td></tr> </table>	D = 213 m	h _t = 2.4 m	D = 259 m (SSE)	h _t = 2.4 m										
D = 213 m																
h _t = 2.4 m																
D = 259 m (SSE)																
h _t = 2.4 m																
10	Recirculation correction	Not considered														
11	Meteorological data base	Hourly site data for 1985														

**RESPONSE TO NRC REQUEST FOR ADDITIONAL INFORMATION
Vermont Yankee Proposed Change No. 250**

Table 4.4

**Design Input and Assumptions for Atmospheric Dispersion Factor Calculation
Turbine Building Releases to Control Room Intake**

Seq.	DESCRIPTION		VALUE
1	Atmospheric dispersion factors (χ/Q)	0 – 1 hr 1 – 2 hr 2 – 8 hr 8 – 24 hr 24 – 96 hr 96 – 720 hr	3.665E-03 2.187E-03 7.572E-04 3.934E-04 2.705E-04 2.044E-04
2	Release height		Ground level
3	Building cross-sectional area for building wake effects (CR-affecting sectors) [Note: In view of the short distance to the CR, plume meander was excluded, and no limit was imposed on the building-wake correction.]		2114 m ²
4	Building height (for building wake effects, sector averaging model)		21 m
5	Minimum wind speed acceptable as valid observation		0.268 m/sec
6	Wind speed assigned to calms		0.134 m/sec
7	Temperature sensor separation (198'-33')		50.3 m
8	Plume rise and terrain heights		Not applicable
9	Average depth of limited mixing layer (for plume reflection)		1000 m
10	Downwind sectors which may potentially affect the control room [Note: Selected χ/Q was for worst-case individual sector]		NE, ENE, E, ESE and SE
11	Receptor distance (release point to CR)		25 m (all sectors)
12	Recirculation correction		Not considered
13	Meteorological data base		Hourly site data for 1979

* * *