ES-301

Administrative Topics Outline

Form ES-301-1

Facility Examin	: <u>Nine Mile Point # 2</u> ation Level (circle one):	Bate of Examination: July 29, 2002 Coperating Test Number: 1
Admini	strative Topic/Subject Description	Describe method of evaluation: 1. ONE Administrative JPM, OR 2. TWO Administrative Questions
A.1	Plant Parameter Verification	JPM - Line up the Containment Monitoring system to determine Containmentwater level above the 224 foot elevation.(EOP-6, Attachment 23)K/A's 2.1.7 (3.7)2.1.20 (4.3)TaskJ223-959-04-01-2
	Refueling	Question 1 - Given N2-OSP-LOG-S004/5 Mode 5 Shift Checks and plant specific out of specification data, determine the required actions K/A's 2.1.23 (3.9) Question 2 - Given plant conditions related to Offsite Power and Emergency Diesel Generator availability, determine if Shutdown Safety Criteria is met for the Power Availability Safety Function. K/A 2 1 23 (3.9)
A.2	Tagging and Clearances	 JPM - Given a completed "Clearance Request Form", blank "Clearance Sheet" and "Tag List" and access to the appropriate reference material, develop a clearance boundary. K/A 2.2.13 (3.6) Task J299-902-03-50-3
A.3	Radiation Work Permit	Question - Given a specified survey map, identify radiological hazards.K/A2.3.10 (2.9)Question - While walking through the Plant next to a high radiation area you see a leak that can be isolated by reaching over the barrier rope and closing the valve.What are the requirements for doing this?K/A's2.3.4 (2.5)2.3.10 (2.9)
A.4	Emergency Protective Action Recommendations	JPM - Perform the actions required when notified of an injured and contaminated person in the Plant. (EPIP-EPP-04) K/A's 2.4.12 (3.4) 2.4.39 (3.3) Task J200-921-05-01-2

NINE MILE POINT NUCLEAR STATION

OPERATOR JOB PERFORMANCE MEASURE

Title: Determine Containment Water Level above the 224 foot elevation. Revision: 0

Task Number:

223-959-04-01-2 - Lineup the Containment Monitoring system to determine Containment level above 224 feet.

Approvals:

General Supervisor

<u>/ 6/6/02</u> Date

dana-

Operations Training (Designee)

EXAM SECURITY ntrol Date

Configuration Contro

	/
1	Da

General Supervisor	
Operations (Designee)	

Performer:		(RO)			
Trainer/Evaluator:					
Evaluation Method: X Perfo	rm	Simulate			
Evaluation Location: X Pla	nt	Simulator			
Expected Completion Time:	10 min.	Time Critical Task:	No	Alternate Path Task:	No
Start Time:	Stop Time:	Comp	oletion Time:		
JPM Overall Rating:	Pass	Fail			

NOTE: A JPM overall rating of fail shall be given if any critical step is graded as fail. Any grade of unsat or individual competency area unsat requires a comment.

Comments:

Evaluators Signature:

Date:	

Recommended Start Location: (Completion time based on the start location) Main Control Room or other designated site.

Simulator Set-up (if required): None

Directions to the Instructor/Evaluator:

Prior to performance of this JPM, obtain SSS / CSO general permission to open equipment cabinets and inspection covers. If opening the equipment cabinet or inspection cover will affect Tech. Spec. Operability, operational status, or the effects are unknown, obtain specific SSS / CSO permission.

Directions to Operators:

Read Before Every JPM Performance:

For the performance of this JPM, I will function as the SSS, CSO, and Auxiliary Operators. Prior to providing direction to perform this task, I will provide you with the initial conditions and answer any questions. During task performance, I will identify the steps to be simulated, or discuss and provide cues as necessary.

With the exception of accessing panels, NO plant equipment will be physically manipulated. Repositioning of devices will be simulated by discussion and acknowledged by my cues.

Read Before Each Evaluated JPM Performance:

This evaluated JPM is a measure of your ability to perform this task independently. The Control Room Supervisor has determined that a verifier is not available and that additional / concurrent verification will not be provided; therefore, it should not be requested.

Read Before Each Training JPM Performance:

During this Training JPM, applicable methods of verification are expected to be used. Therefore, either another individual or I will act as the independent/peer verifier.

Notes to Instructor / Evaluator:

- 1. Critical steps are identified in grading areas as Pass/Fail. All steps are sequenced critical unless denoted by a "•".
- 2. During Evaluated JPM:
 - Self verification shall be demonstrated.
- 3. During Training JPM:
 - Self verification shall be demonstrated.
 - No other verification shall be demonstrated.

References:

- 1. N2-EOP-6, Attachment 23
- 2. NUREG K/A General Knowledges and Abilities 2.1.7 (3.7), 2.1.20 (4.3), 2.1.31...(4.2)

Tools and Equipment:

1. None

Task Standard:

Determine Containment Water Level using N2-EOP-6, attachment 23.

.

- 1. The Plant is scrammed.
- 2. Containment flooding is in progress.
- Current conditions dictate that Containment Level can <u>NOT</u> be determined due to level being greater than the upper range of the level instrument.
- 4. N2-EOP-6, Attachment 23 has been completed up to Step 3.7.

Initiating Cues:

"(Operator's name), the SSS has directed you to complete Step 3.7 of N2-EOP-6, Attachment 23 and report current Containment Water Level."

Performance Steps	Standard	Grade
1. Provide repeat back of initiating cue. Evaluator Acknowledge repeat back providing correction if necessary	Proper communications used for repeat back (GAP-OPS-O1/Operations Manual)	Sat/Unsat
RECORD START TIME		
 Obtain a copy of the reference procedure and review/utilize the correct section of the procedure. 	N2-EOP-6, Attachment 23 is obtained.	Sat/Unsat
CUE: Acting as the SSS, provide the Candidate with the copy of Attachment 23 completed up to Step 3.7.		
3. Review of Attachment 23.	Reviews ATTACHMENT 23 , to ensure that the Steps up to Step 3.7 are complete.	Sat/Unsat
4. Performs Containment Level determination.	Uses the appropriate Figure 23.1a or b to determine Containment Water Level as follows;	Sat/Unsat
CUE: When asked, indicated injection temperatures are approximately 72°F.		
	• Determines with the current injection temperatures that Figure 23.b is the appropriate figure for use.	Pass/Fail
NRC EXAM Administrative RO/JPM # A.1.1	3	APRIL 2002

CUE:

Standard

- Determines appropriate ΔP by; Sat/Unsat
 Determining the S-D pressure.
 - "S" pressure is SUPPRESSION CHAMBER PRESSURE as indicated on 2CMS*PI7A on Panel 601.
 - "D" pressure is PRIMARY CONTAINMENT INLET NITROGEN PRESSURE as indicated on 2CPS-PI127 on Panel 873.
 - Using a ΔP of 15 psi and the "D" pressure from above, determines and reports that CONTAINMENT WATER LEVEL is approximately 264 feet.

CUE: <u>As the SSS, acknowledge the</u> <u>Candidates report of Containment</u> Water Level.

When asked, indicate that

2CMS*PI7A on Panel 601 is reading

48psig. And that 2CPS-PI127 on

Panel 873 is reading 33 psig.

Terminating Cue: A Containment Water level has been determined.

RECORD STOP TIME

- 1. The Plant is scrammed.
- 2. Containment flooding is in progress.
- 3. Current conditions dictate that Containment Level can **NOT** be determined due to level being greater than the upper range of the level instrument.
- 4. N2-EOP-6, Attachment 23 has been completed up to Step 3.7.

Initiating Cues:

"(Operator's name), the SSS has directed you to complete Step 3.7 of N2-EOP-6, Attachment 23 and report current Containment Water Level."

Nine Mile Point 2 Category "A" - Examination O	utline Cross Reference
Operating Test Number	Cat "A" Test: 1
Examination Level	RO
Administrative Topic	A.1
Subject Description:	Fuel Handling/Shift Checks
Question Number:	1

Question:

The plant is in Mode 5, with the following:

- Recently Irradiated fuel is being moved in the Spent Fuel Pool
- You are the Reactor Operator performing Mode 5 Shift Checks.

Review the ECCS Equipment Room temperature data provided and determine the required actions, if any?

SAT

UNSAT

Answer:

Notify the SSS of the out of spec reading. Action must be initiated to restore Low Pressure Core Spray and RHS "A" Pump Room temperatures to at least 70°F as soon as practicable. (N2-OP-52, Precaution & Limitation D.26.0)

Explanation: N2-OSP-LOG-S004/5, Item 93, Note [ba] requires action if any ECCS Equipment Room temperature is < 70°F.

Technical Reference(s):

N2-OSP-LOG-S004/5, Item 93, Note [ba], Precaution and Limitation 6.2 N2-OP-52, Precaution & Limitation D.26.0

K/A #:	Importance:
2.1.23	3.9

Comments:

Evaluator is to provide candidate with marked up copy of appropriate pages of N2-OSP-LOG-S004/5.

Candidate Copy

Nine Mile Point 2 Category "A" - Examination Ou	Itline Cross Reference
Operating Test Number	Cat "A" Test: 1
Examination Level	RO
Administrative Topic	A.1
Subject Description:	
Question Number:	1

Question:

The plant is in Mode 5, with the following:

- Recently Irradiated fuel is being moved in the Spent Fuel Pool
- You are the Reactor Operator performing Mode 5 Shift Checks.

Review the ECCS Equipment Room temperature data provided and determine the required actions, if any?

Nine Mile Point 2 Category "A" - Examination Οι	Itline Cross Reference
Operating Test Number	Cat "A" Test: 1
Examination Level	RO
Administrative Topic	A.1
Subject Description:	Fuel Handling/Shutdown Safety
Question Number:	2

Question:

The plant is in Mode 5, with the following:

- Line 5 is operable.
- Line 6 is operable.
- Division I Emergency Diesel Generator is operable.
- Division II Emergency Diesel Generator is **inoperable** and removed from service under a Red Clearance.
- THEN, A plant worker inadvertently removes the "Close" circuit control power fuses for Division I Emergency Diesel Generator Output Breaker and breaks the fuse holder.

Is the minimum Shutdown Safety Criteria being met? Justify your answer. SAT UNSAT

Answer:

Minimum Shutdown Safety Criteria for Power Availability is NOT being met.

Explanation: From NIP-OUT-01 Attachment 4: Power Availability, the Shutdown Safety Criteria during Mode 5 is met when available power sources = N+1=3. With both offsite lines available (2 sources) and no EDGs available, then the plant is below the required value of 3. Additionally, none of the available sources is an EDG.

Technical Reference(s):
NIP-OUT-01, Attachment 4

2123	3.0
K/A #:	Importance:

Comments:

Candidate Copy

Nine Mile Point 2 Category "A" - Examination Outline Cross Reference						
Operating Test Number	Cat "A" Test: 1					
Examination Level	RO					
Administrative Topic	A.1					
Subject Description:						
Question Number:	2					

Question:

The plant is in Mode 5, with the following:

- Line 5 is operable.
- Line 6 is operable.
- Division I Emergency Diesel Generator is operable.
- Division II Emergency Diesel Generator is **inoperable** and removed from service under a Red Clearance.
- THEN, A plant worker inadvertently removes the "Close" circuit control power fuses for Division I Emergency Diesel Generator Output Breaker and breaks the fuse holder.

Is the minimum Shutdown Safety Criteria being met? Justify your answer.

NINE MILE POINT NUCLEAR STATION

OPERATOR JOB PERFORMANCE MEASURE

<u> </u>	Develop a	Clearance Boun	dary for Spent Fuel I	Pool Cooling Pump 2	2SFC*P1A Revis	ion: <u>0</u>	_
Task Number:	299-902-03	-50-3 - Develo	oping Clearance Bou	ndaries			
Approvals:							
		/				/	
General Supervi Operations Trai	isor ning (Designe	Date e)		General Supervisor Operations (Designee)	Date	
Configuration C	Control	/ Date					
Performer:			(RO)				
Trainer/Evaluate	or:						
Evaluation Meth	od: <u>X</u> Perfo	orm	Simulate				
Evaluation Loca	tion: X Pla	ent	_ Simulator				
Expected Compl	etion Time:	15 min.	Time Critical Tasl	k: No	Alternate Path	Task:	No
Start Time:	······	Stop Time:	C	ompletion Time:			
JPM Overall Rat	ing:	Pass	Fail				
NOTE: A IPM o	varall rating a	f fail abalt he at		• • • • • • •			

NOTE: A JPM overall rating of fail shall be given if <u>any</u> critical step is graded as fail. Any grade of unsat or individual competency area unsat requires a comment.

Comments:

Evaluators Signature:_____

Date:_____

Recommended Start Location: (Completion time based on the start location) Main Control Room or other designated site.

Simulator Set-up (if required): None

Directions to the Instructor/Evaluator:

Prior to performance of this JPM, obtain SSS / CSO general permission to open equipment cabinets and inspection covers. If opening the equipment cabinet or inspection cover will affect Tech. Spec. Operability, operational status, or the effects are unknown, obtain specific SSS / CSO permission.

Directions to Operators:

Read Before Every JPM Performance:

For the performance of this JPM, I will function as the SSS, CSO, and Auxiliary Operators. Prior to providing direction to perform this task, I will provide you with the initial conditions and answer any questions. During task performance, I will identify the steps to be simulated, or discuss and provide cues as necessary.

With the exception of accessing panels, NO plant equipment will be physically manipulated. Repositioning of devices will be simulated by discussion and acknowledged by my cues.

Read Before Each Evaluated JPM Performance:

This evaluated JPM is a measure of your ability to perform this task independently. The Control Room Supervisor has determined that a verifier is not available and that additional / concurrent verification will not be provided; therefore, it should not be requested.

Read Before Each Training JPM Performance:

During this Training JPM, applicable methods of verification are expected to be used. Therefore, either another individual or I will act as the independent/peer verifier.

Notes to Instructor / Evaluator:

- 1. Critical steps are identified in grading areas as Pass/Fail. All steps are sequenced critical unless denoted by a "•".
- 2. During Evaluated JPM:
 - Self verification shall be demonstrated.
- 3. During Training JPM:
 - Self verification shall be demonstrated.
 - No other verification shall be demonstrated.

References:

- 1. GAP-OPS-02
- 2. PID-38B-10
- 3. EE-1Q
- 4. N2-OP-38
- 5. NUREG K/A General Knowledges and Abilities 2.2.13 (3.6)

Tools and Equipment:

1. None

Task Standard:

Develop a Clearance boundary.

- 1. The Plant is operating at 100%.
- 2. Maintenance has requested a Clearance be placed on 2SFC*P1A.
- 3. The SSS has just handed you the Clearance Request Form for this job.
- -4. 2SFC*P1A is shut down and 2SFC*P1B is operating.

Initiating Cues:

- 1. Provide candidate with Attachment 5, Clearance Request Form and Blank Tag List, Attachment 7
- 2. "(Operator's name), Develop a Clearance boundary for the requested Clearance. Indicate the appropriate boundaries, vents/drains, power supplies, and required positions for a safe clearance on a Tag List. Return the completed Tag List to the SSS for review."

Pe	rformance Steps		Standard	Grade
1.	Provide repeat back of initiating cue. Evaluator Acknowledge repeat back providing correction if necessary	P1 (C	roper communications used for repeat back GAP-OPS-O1/Operations Manual)	Sat/Unsat
RI	ECORD START TIME			
2.	 Obtain a copy of the reference procedure and review/utilize the correct section of the procedure. 		AP-OPS-02 is obtained.	Sat/Unsat
			D-38 is referenced	Sat/Unsat
<i></i>		N2 rei	2-OP-38, Attachment 4 or EE-1Q is ferenced.	Sat/Unsat
3.	Indicate power supplies needed for Clearance boundary.	•	Includes 2SFC*P1A control switch in pull-to-lock.	Pass/Fail
		•	Includes 2ENS*SWG101-5 breaker open and racked-out.	Pass/Fail
4.	Indicate valves needed for Clearance boundary.	٠	Includes 2SFC*V21A (pump discharge isol valve) closed.	Pass/Fail
		•	Includes 2SFC*V13A (pump suction isol valve) closed.	Pass/Fail
		•	Includes 2SFC*V16A (vent) AND/OR 2SFC*V111A (drain) open.	Pass/Fail
5.	Return the Tag List Attachment 7 to the SSS.	Re	turns Attachment 7 to the SSS.	Sat/Unsat

Standard

CUE: As the SSS acknowledge the receipt of the Tag List.

Terminating Cue: Completed GAP-OPS-02 Tag List, Attachment 7 is returned to the SSS.

RECORD STOP TIME

- 1. The Plant is operating at 100%.
- 2. Maintenance has requested a Clearance be placed on 2SFC*P1A.
- 3. The SSS has just handed you the Clearance Request Form for this job.
- 4. 2SFC*P1A is shut down and 2SFC*P1B is operating.

Initiating Cues:

- 1. Provide candidate with Attachment 5, Clearance Request Form and Blank Tag List, Attachment 7
- 2. "(Operator's name), Develop a Clearance boundary for the requested Clearance. Indicate the appropriate boundaries, vents/drains, power supplies, and required positions for a safe clearance on a Tag List. Return the completed Tag List to the SSS for review."

ATTACHMENT 5: CLEARANCE REQUEST FORM

Unit _2_			
Date of Request	DDAY		
Type of Clearance	Danger		
	Operating Permit		
	□ Caution		
Equipment and System	n to be Cleared: SFC *P1A - Spent Fuel	Pool Cooling System	
Work Controlling Docu	ment No./Description of Work: _Clearanc	e is required to repair the	he pump. This is
scheduled corrective n	naintenance. Breach of pump pressure bo	oundary is required. Pur	mp must be
de-coupled from the m	otor.		
Suggested Clearance	Tagging Points (Not Required):		
Hazards Associated wi Potential Adverse Effect	th the Work to be Performed:		
Hazards Associated wi Potential Adverse Effec Other Systems Affected	th the Work to be Performed:		
Hazards Associated wi Potential Adverse Effec Other Systems Affected Grounds Required:	th the Work to be Performed:		
Hazards Associated wi Potential Adverse Effec Other Systems Affected Grounds Required: Starting Time <u>08:00</u>	th the Work to be Performed:	Duration 24	hours
Hazards Associated wi Potential Adverse Effec Other Systems Affectec Grounds Required: Starting Time <u>08:00</u> Reference Drawings(s)	ith the Work to be Performed: cts:	Duration <u>24</u>	hours
Hazards Associated wi Potential Adverse Effec Other Systems Affected Grounds Required: Starting Time <u>08:00</u> Reference Drawings(s) Clearance to be held by	ith the Work to be Performed: cts:	Duration24	hours
Hazards Associated wi Potential Adverse Effec Other Systems Affectec Grounds Required: Starting Time <u>08:00</u> Reference Drawings(s) Clearance to be held by	th the Work to be Performed: cts:	Duration <u>24</u> <u>1234</u> Phone(hours
Hazards Associated wi Potential Adverse Effer Other Systems Affecter Grounds Required: Starting Time <u>08:00</u> Reference Drawings(s) Clearance to be held by Requester/Planner:	th the Work to be Performed:	Duration <u>24</u> <u>1234</u> Phone(<u>1234</u>	hours 's)
Hazards Associated wi Potential Adverse Effer Other Systems Affecter Grounds Required: Starting Time <u>08:00</u> Reference Drawings(s) Clearance to be held by Requester/Planner:	th the Work to be Performed:	Duration <u>24</u> <u>1234</u> Phone(<u>1234</u> Phone	hours
Hazards Associated wi Potential Adverse Effer Other Systems Affecter Grounds Required: Starting Time <u>08:00</u> Reference Drawings(s) Clearance to be held by Requester/Planner: Recommended Clearan	the Work to be Performed:	Duration <u>24</u> 24 1234 Phone(1234 Phone	hours
Hazards Associated wi Potential Adverse Effer Other Systems Affecter Grounds Required: Starting Time <u>08:00</u> Reference Drawings(s) Clearance to be held by Requester/Planner: Recommended Clearan Operations Review:	th the Work to be Performed:	Duration <u>24</u> 24 1234 Phone(1234 Phone	hours
Hazards Associated wi Potential Adverse Effer Other Systems Affecter Grounds Required: Starting Time <u>08:00</u> Reference Drawings(s) Clearance to be held by Requester/Planner: Recommended Clearan Operations Review:	th the Work to be Performed:	Duration <u>24</u> 24 24 24 Phone(234 Phone	hours
Hazards Associated wi Potential Adverse Effer Other Systems Affecter Grounds Required: Starting Time <u>08:00</u> Reference Drawings(s) Clearance to be held by Requester/Planner: Recommended Clearan Operations Review: Clearance No	th the Work to be Performed:	Duration24 1234 1234 Phone(1234 Phone Date /	hours

ATTACHMENT 7: TAG LIST

CLEARANCE SHEET	CLEAR	RANCE NO.			·			Daga			
Component to be Worked:						······			0		
Equipment ID	Tag	Тад	Place	Place	Place 1st	Place 2nd	Deat				1
	Serial No	Туре	Seq.	Config.	Verifier	Verifier	Seq.	Config.	Verifier	Rest. 2 nd	Tag Notes
								-			
	2										
									<u></u>		
		·									
					1	I		I		I	

ATTACHMENT 7: TAG LIST

CLEARANCE SHEET			NCE NO	· · · · · · · · · · · · · · · · · · ·							
								Page <u>1</u> of <u>1</u>			
Component to be Worked: 2S	FC*P1A		·								
Equipment ID	Tag Serial No	Tag Type	Place. Seq.	Place. Config.	Place. 1 st Verifier	Place. 2 nd Verifier	Rest. Seq.	Rest. Config.	Rest. 1 st Verifier	Rest. 2 nd Verifier	Tag Notes
2SFC*P1A Control Switch		Danger		PULL-TO-LOCK							
2ENS*SWG101-5 (2SFC*P1A Power Supply Breaker)		Danger		BREAKER OPEN AND RACKED-OUT							
2SFC*V21A, Pump Discharge Isolation Valve		Danger		CLOSED							,
2SFC*V13A, Pump Suction Isolation Valve		Danger		CLOSED							
2SFC*V16A (vent) AND / OR 2SFC*V111A (drain)		Danger		OPEN							
									_		

8

Nine Mile Point 2 Category "A" - Examination O	utline Cross Reference
Operating Test Number	Cat "A" Test: 1
Examination Level	RO
Administrative Topic	A.3
Subject Description:	Radiation Work Permits
Question Number:	1

Question:

Using the attached Survey 68 for Turbine Building 277' Condensate Demin Valve Aisle, identify the radiological posting(s) required at the entrance to the area, if any.

SAT

Answer:

UNSAT

a. Contaminated Area

Contaminated areas identified by dashed lines on the east side of the room with contamination levels of 24K dpm/100cm², 3100 dpm/100cm², and 420 dpm/100cm².

b. High Radiation Area

High radiation levels in the central west side of the Valve aisle near the 4" Resin Transfer Pipe with radiation levels of 110mr/hr and 900 mr/hr @ 30 cm.

Technical Reference(s): S-RAP-RPP-0103, Sect. 4.0

2310	importance:
N/A #;	Importance:

Comments:

Candidate Copy

Nine Mile Point 2 Category "A" - Examination Outline Cross Reference						
Operating Test Number	Cat "A" Test: 1					
Examination Level	RO					
Administrative Topic	A.3					
Subject Description:						
Question Number:	1					

Question:

Using the attached Survey 68 for Turbine Building 277' Condensate Demin Valve Aisle, identify the radiological posting(s) required at the entrance to the area, if any.



Nine Mile Point 2 Category "A" - Examination Ou	Itline Cross Reference
Operating Test Number	Cat "A" NRC Exam 2002
Examination Level	RO
Administrative Topic	A.3
Subject Description:	Radiation Work Permit
Question Number:	2

Question:

While performing rounds in the Reactor Building, you notice a small leak has developed on a line inside of a High Radiation area. You know you can stop the leak immediately by reaching over the radiation rope boundary and tightening the isolation valve.

What, if any, are the requirements for performing this type of activity?

Answer: To isolate the leak, obtain permission from Radiation Protection and sign in • on the appropriate RWP is required. NOTE: The Candidate may include in the answer, to contact the Control Room to obtain SSS permission for this activity. This is a correct answer for this question however, it is NOT required for complete credit. SAT UNSAT

Technical Refe	rence(s):
GAP-RPP-08, S	ection 3.2, Rev. 8
K/A #:	Importance:
2.3.4	2.5

Comments:

CANDIDATE'S COPY

Question:

While performing rounds in the Reactor Building, you notice a small leak has developed on a line inside of a High Radiation area. You know you can stop the leak immediately by reaching over the radiation rope boundary and tightening the isolation valve.

What, if any, are the requirements for performing this type of activity?

NINE MILE POINT NUCLEAR STATION

OPERATOR JOB PERFORMANCE MEASURE

Fitle: Perform require	ed CSO actior	ns for an injured	AND contaminate	ed person. Revis	sion: <u>0</u>
Task Number: 200-921-05-01-	2 – Perform in the pla	the actions requi ant.	ired when notified	of an injured and cor	ntaminated person
Approvals:					
	/				/
Operations Training (Designee)	Date		Operations (Des	sor ignee)	Date
Configuration Control	/ Date	_			
Performer:		(RO)			
Trainer/Evaluator:					
Evaluation Method: X Perform		_Simulate			
Evaluation Location: X Plant		Simula	ator		
Expected Completion Time: 19	5 min.	Time Critical T	`ask: No	Alternate Pat	h Task: No
Start Time: Start	top Time:		Completion Tim	e:	
JPM Overall Rating: Pa	ass	Fail			

NOTE: A JPM overall rating of fail shall be given if <u>any</u> critical step is graded as fail. Any grade of unsat or individual competency area unsat requires a comment.

Comments:

Evaluators Signature:_____

Date:	

APRIL 2002

1

Recommended Start Location: (Completion time based on the start location) Main Control Room or other designated site.

Simulator Set-up (if required): None

Directions to the Instructor/Evaluator:

Prior to performance of this JPM, obtain SSS / CSO general permission to open equipment cabinets and inspection covers. If opening the equipment cabinet or inspection cover will affect Tech. Spec. Operability, operational status, or the effects are unknown, obtain specific SSS / CSO permission.

Directions to Operators:

Read Before Every JPM Performance:

For the performance of this JPM, I will function as the SSS, CSO, and Auxiliary Operators. Prior to providing direction to perform this task, I will provide you with the initial conditions and answer any questions. During task performance, I will identify the steps to be simulated, or discuss and provide cues as necessary.

With the exception of accessing panels, NO plant equipment will be physically manipulated. Repositioning of devices will be simulated by discussion and acknowledged by my cues.

Read Before Each Evaluated JPM Performance:

This evaluated JPM is a measure of your ability to perform this task independently. The Control Room Supervisor has determined that a verifier is not available and that additional / concurrent verification will not be provided; therefore, it should not be requested.

Read Before Each Training JPM Performance:

During this Training JPM, applicable methods of verification are expected to be used. Therefore, either another individual or I will act as the independent/peer verifier.

Notes to Instructor / Evaluator:

- 1. Critical steps are identified in grading areas as Pass/Fail. All steps are sequenced critical unless denoted by a "•".
- 2. During Evaluated JPM:
 - Self verification shall be demonstrated.
- 3. During Training JPM:
 - Self verification shall be demonstrated.
 - No other verification shall be demonstrated.

References:

- 1. EPIP-EPP-04 and Attachment 1
- 2. NUREG K/A General Knowledges and Abilities 2.4.12 (3.4), 2.4.39 (3.3)

Tools and Equipment:

1. None

Task Standard:

Under the direction of the SSS, complete Attachment 1 of EPIP-EPP-04 when notified of an injured and contaminated person in the Plant.

- 1. The Plant is operating at 100%.
- 2. You have just received a report that a Plant Mechanic has passed out in between the "B" & "C" Condensate Pumps.
- 3. The Mechanic is bleeding from the left arm and respiration is shallow.

Initiating Cues:

"(Operator's name), Perform the required actions, as the CSO."

Performance Steps	Standard	Grade	
1. Provide repeat back of initiating cue. Evaluator Acknowledge repeat back providing correction if necessary	Proper communications used for repeat back (GAP-OPS-O1/Operations Manual)	Sat/Unsat	
RECORD START TIME			
 Obtain a copy of the reference procedure an review/utilize the correct section of the procedure. 	d Obtains a copy of EPIP-EPP-04. References Section 3.1 and Attachment 1.	Sat/Unsat	
3. Place the GAItronics in the "Merge" Mode. NOTE: If the Candidate chooses to use the GAItronics it should be placed in the "MERGE mode. Its OK if the Candidate chooses to NOT use the GAItronics, just mark this step NA.	Places the GAItronics in the " MERGE " mode, <u>IF USED</u> , by placing the switch on the Communications Console in the Control Room to the " MERGE " position.	Sat/Unsat/NA	
 Notify the Fire Brigade. NOTE: <u>Any of the listed notification</u> <u>methods is acceptable.</u> 	 Notifies the FIRE BRIGADE AND requests response via the, GAItronics Phone Radio 	Pass/Fail	
CUE: As the Fire Brigade Leader reply that, "the Brigade is on the way to the Condensate Pump Bay and I will report on the situation as soon as I arrive on the scene."	Dispatch the Fire Brigade to the scene to evaluate the situation.	Pass/Fail	

5. Notify the SSS.

Notifies the SSS of the reported situation.

Pass/Fail

Grade

- CUE: <u>As the SSS, acknowledge the</u> <u>Candidates report.</u>
- CUE: As the Fire Brigade Leader, request Radiation Protection and Medical Department assistance. Also requests an ambulance as the Mechanic is still unconscious.
- 6. Contact Radiation Protection.
- **NOTE:** <u>Any of the listed notification</u> methods is acceptable.
- CUE: As the Radiation Protection Tech state that, "Radiation Protection assistance is on the way to the Condensate Pump Bay and they will report on any radiation concerns as soon as they evaluate the scene."
- 7. Contact the Medical Department.
- CUE: As the Medical Department Representative acknowledge the report of the situation.
- CUE: As the Fire Brigade Leader at the scene report to the Candidate that, "Radiation Protection Technicians have determined that the injured Mechanic IS CONTAMINATED." Also request that an ambulance is required at this time.

Contacts Radiation Protection <u>AND</u> request that they report to the scene of the medical emergency via,

GAItronics

Standard

- Phone
- Radio

Contacts the Medical Department <u>AND</u> request that they report to the scene of the medical emergency via,

Pass/Fail

Pass/Fail

- GAItronics
- Phone
- Radio

Performance Steps		Standard	Grade	
8. Co CUE:	ntact Oswego County 911 Center. <u>As the 911 Center Operator</u> <u>acknowledge the request and that the</u> <u>person for transport is contaminated.</u> <u>State that an ambulance will be on</u> <u>the way shortly.</u>	 Contact OSWEGO COUNTY 911 CENTER and request an ambulance be sent to the NINE MILE POINT UNIT 2 SECURITY ACCESS. Via land telephone line at 343-1313. Inform the 911 Center that the person for transport <u>IS</u> CONTAMINATED. 	Sat/Unsat Pass/Fail	
9. Con	As the Site Security Supervisor. As the Site Security Supervisor acknowledge the request.	Contacts the SITE SECURITY SUPERVISOR and request a security force member be sent to the Condensate Pump Bay <u>AND</u> informs them of the impending ambulance arrival.	Sat/Unsat	
10. Cor	As the Oswego Hospital. As the Oswego Hospital Representative acknowledge the report of the situation and state that the REA will be setup.	 Contacts the OSWEGO HOSPITAL. Via land telephone line at 349-5522. Informs them that ONE contaminated injured person will be transported to them. Request that setup the RADIATION EMERGENCY AREA (REA). 	Sat/Unsat Sat/Unsat Pass/Fail	
11. Req supe repo	uest that Radiation Protection ervision and a Radiation Protection Tech ort to the Oswego Hospital. <u>As the SSS, acknowledge that you</u>	Request the SSS to contact on-call Radiation Protection. State that Radiation Protection supervision and a Tech need to report to Oswego Hospital. State that a Radiation Protection Tech will accompany the contaminated injured person in the ambulance.	Sat/Unsat Sat/Unsat Sat/Unsat	
	will contact on-call Radiation Protection Supervisor.			

Performance Steps	Standard	Grade
 12. Contact Site Security Supervisor. CUE: As the Site Security Supervisor acknowledge the request. 	Direct the SITE SECURITY SUPERVISOR to contact the MANAGER, NUCLEAR COMMUNICATIONS AND PUBLIC AFFAIRS <u>AND</u> provide details of the incident.	Sat/Unsat
CUE: As the Fire Brigade Leader, inform the Candidate that the contaminated injured person has left the site and is proceeding to Oswego Hospital in the ambulance.		
13. Inform the SSS of the termination of the emergency.	Informs the SSS that the contaminated injured person has left the site in an ambulance and is being transported to Oswego Hospital. Indicates to the SSS that the emergency can be terminated.	Sat/Unsat Sat/Unsat

CUE: <u>As the SSS, acknowledge the</u> <u>Candidates report.</u>

Terminating Cue: The SSS has received and acknowledged the report that indicates the contaminated injured person has left the Site in an ambulance and that the Emergency can be terminated.

RECORD STOP TIME

- 1. The Plant is operating at 100%.
- 2. You have just received a report that a Plant Mechanic has passed out in between the "B" & "C" Condensate Pumps.
 - 3. The Mechanic is bleeding from the left arm and respiration is shallow.

Initiating Cues:

"(Operator's name), Perform the required actions, as the CSO."

ES-301

Administrative Topics Outline

Form ES-301-1

Facility Examin	7: <u>Nine Mile Point # 2</u> nation Level (circle one)	: SRO	Date of Examination:				
Admin	istrative Topic/Subject Description	Describe method of evaluation: 1. ONE Administrative JPM, OR 2. TWO Administrative Questions					
A.1	Reactor Plant Startup Requirements	JPM - Given GAP-CHE-01 B 1" values exceeded for CDI contifications. K/A 2.1.34 (2.9) Task J341-022-03-03-2	WR Water Chemistry Limits and "Action Level onductivity, determine and make the appropriate				
	Plant Parameter Verification	JPM - Determination of Techr Operation and APLHGR is Ex K/A 2.1.7 (4.4) Task J341-032-03-03-2	nical Specification Actions When in Single Loop ceeded.				
A.2	Surveillance Testing	JPM - Given a completed survand results comply with specif K/A's 2.2.12 (3.4) 2.2. Task J341-012-01-03-2	eillance test and appropriate results ensure test ications and requirements. 24 (3.8)				
A.3	Control of Radiation Release	JPM - Direct Reactor Building K/A's 2.3.11 (3.2) 2.3. Task J344-906-05-03-2	Evacuation due to a Radiation Emergency 6 (3.1)				
A.4	Emergency Classification	JPM - Emergency Plan Classifi Approval. K/A's 2.4.29 (4.0) 2.4.	cation And Protective Action Recommendation 41 (4.1)				

NINE MILE POINT NUCLEAR STATION

OPERATOR JOB PERFORMANCE MEASURE

Γitle:

Notifications due to exceeding CDI Conductivity - Action Level 1

Revision: 0

341-022-03-03-2 Monitor Plant Chemistry Parameters to ensure conformance to requires Units. Task Number:

Approvals:

/ 6/6/02 Date General Supervisor

Operations Training (Designee)

EXAM SECULITY **Configuration Control**

pervisor

Operations (Designee)

16/3/02

Performer:		(SRO)			
Trainer/Evaluator:					
Evaluation Method: X Perfo	rm	Simulate			
Evaluation Location:Plant	X	Simulator			
Expected Completion Time:	10 min.	Time Critical Task:	No	Alternate Path Task:	No
Start Time:	Stop Time:	Comp	oletion Time:		
JPM Overall Rating:	Pass	Fail			
NOTE: A IDM and all (66 1 1 11 1 1				

NOTE: A JPM overall rating of fail shall be given if any critical step is graded as fail. Any grade of unsat or individual competency area unsat requires a comment.

Comments:

Evaluators Signature:

Date:		

Recommended Start Location: (Completion time based on the start location) Simulator or other designated site.

Simulator Set-up (if required): None

Directions to the Instructor/Evaluator:

Prior to performance of this JPM, obtain SSS / CSO general permission to open equipment cabinets and inspection covers. If opening the equipment cabinet or inspection cover will affect Tech. Spec. Operability, operational status, or the effects are unknown, obtain specific SSS / CSO permission.

Directions to Operators:

Read Before Every JPM Performance:

For the performance of this JPM, I will function as the SSS, CSO, and Auxiliary Operators. Prior to providing direction to perform this task, I will provide you with the initial conditions and answer any questions. During task performance, I will identify the steps to be simulated, or discuss and provide cues as necessary.

With the exception of accessing panels, NO plant equipment will be physically manipulated. Repositioning of devices will be simulated by discussion and acknowledged by my cues.

Read Before Each Evaluated JPM Performance:

This evaluated JPM is a measure of your ability to perform this task independently. The Control Room Supervisor has determined that a verifier is not available and that additional / concurrent verification will not be provided; therefore, it should not be requested.

Read Before Each Training JPM Performance:

During this Training JPM, applicable methods of verification are expected to be used. Therefore, either another individual or I will act as the independent/peer verifier.

Notes to Instructor / Evaluator:

- 1. Critical steps are identified in grading areas as Pass/Fail. All steps are sequenced critical unless denoted by a "•".
- 2. During Evaluated JPM:
 - Self verification shall be demonstrated.
- 3. During Training JPM:
 - Self verification shall be demonstrated.
 - No other verification shall be demonstrated.

References:

- 1. GAP-CHE-01, Enclosure #2
- 2. NUREG K/A General Knowledges and Abilities 2.1.34 (2.9)

Tools and Equipment:

1. GAP-CHE-01, Enclosure #2

Task Standard:

Determine Action Level status and make appropriate notification(s) for a given value of CDI Conductivity.

.

.

- 1. The Reactor is operating at 20% power.
- You have just been handed a Chemistry Report that indicates Condensate (CDI) Conductivity (μS/cm) @ 25°C is reading 0.246.

Initiating Cues:

"(Operator's name), determine if a Chemistry Action Level has been exceeded and if necessary, identify Station personnel that are required to be notified."

Pe	rformance Steps	Standard	Grade	
1.	Provide repeat back of initiating cue. Evaluator Acknowledge repeat back providing correction if necessary	Proper communications used for repeat back (GAP-OPS-O1/Operations Manual)	Sat/Unsat	
RI	ECORD START TIME			
2.	Obtain a copy of the reference procedure and review/utilize the correct section of the procedure.	GAP-CHE-01 obtained. Enclosure 2 is referenced.	Sat/Unsat	
3.	Determines Action Level 1 is exceeded	 Using the supplied Chemistry Analysis information and Enclosure 2; Determines that Action Level 1 <u>HAS</u> been exceeded under Section III.b. Determines that Action Level 2 <u>HAS</u> <u>NOT</u> been exceeded using the same section. Enters Section 3.2.1 of GAP-CHE-01. 	Pass/Fail Pass/Fail Sat/Unsat	
4. CU	 Performs appropriate Notifications. E: Role playing as the SSS and all the called Managers, acknowledge the Candidate's report of the CDI Conductivity exceeding Action Level 1. 	 Notifies the following personnel of the parameter that has exceeded ACTION LEVEL 1; SSS Chemistry Manager Operations Manager Plant Manager, AND Engineering Services Branch Manager. 	Sat/Unsat	

.

.

Standard

CUE: As the SSS, tell the Candidate that troubleshooting will begin to determine the cause.

Terminating Cue: An Action Level has been chosen and the appropriate notification for that level have been made.

RECORD STOP TIME

- 1. The Reactor is operating at 20% power.
- ⁻². You have just been handed a Chemistry Report that indicates Condensate (CDI) Conductivity (μS/cm) @ 25°C is reading **0.246**.

Initiating Cues:

"(Operator's name), determine if a Chemistry Action Level has been exceeded and if necessary, identify Station personnel that are required to be notified."

perating Condition/Parameter			Action Level				Prior to Startup	
			1	2		3		•
Cold Shutdown (Mode 4,5) a. Reactor Water and Fuel Storage Pool								
Conductivity (µS/cm) @ 25°C			>2.0*	>5.0*	>	10.0(1)*	<u>≤</u> 1.	5
Chloride (ppb)			>100*	>200*	>	500(1)*	≤10	0
Sulfate (ppb)			>100	•		·	≤10	0
pH at 25°C (Low	w)		<5.3*(1)	<4.9*		<4.6*		
(High)			>8.6*(1)	>9.3*		>9.6*		
. Startup/Hot Standby (Mode 2,3) a. Reactor Water								
Conductivity (uS/cm) @ 25°C.5				>1.0		>5.0	≤1.	0
, (**	ŀ			>2.0(1)				
Chloride (ppb)			•	>100(1)		>200	<u><</u> 2	0
Sulfate (ppb)			-	>100		>200		0
Dissolved Oxygen (ppb) above 284°F (140°C)			>300					
pH @ 25°C (Lo	w)	-	<5.6*(1)	<4.9*		<4.6*		
(Hig	jh) [>8.6*(1)	>9.3*		>9.6*		
b. Feedwater/Condensate								
Feedwater and CDE Conductivity (µS/cm) @ 25°C			>0.15**	-		-		
Feedwater Suspended Corrosion Products (ppb)			>100	•				
Condensate (CDI) Conductivity (µS/cm) @ 25°C		>	»0.10*** ⁽⁴⁾	>0.5***	>	1.0***(2)		
Feedwater Dissolved Oxygen (ppb)			>200**	•		•	<20	0**
II. Power Operation (Mode 1) (>10% Power) a. Reactor Water (>25% Power For Fuel Warranty Parameters)		No	rmal Water Cher Action Lev	nistry (NWC) vels		HV Act	C/NMCA	3
	1		2	3		1	2	3
Conductivity (µS/cm) @ 25°C	>0.30)	>1.0 ⁽¹⁾	>5.0		0.30(6)	1.0	5.0
Chloride (ppb)	>5		>20	>100		>5	>50	>200
Sulfate (ppb)	>5		>20	>100		>5	>50	>20
pH at 25°C (Low)	<5.6*(1)	<4.9*	<4.6*	ļ	ļ		
(High)	>8.6*(.9	>9.3*	>9.6*		<u> </u>		L
b. Feedwater/Condensate	0.00		. 0.41		r			<u> </u>
Feedwater and CDE Conductivity (µS/cm) @ 25°C	>0.06	5	>0.1	>0.2*	 			<u> </u>
Condensate Demineralizer Outlet conductivity (µS/cm) @ 25°C	>0.2	<u> </u>	>0.5	>1 ()***(2)	<u> </u>			├
Eacdwater Total Motals (nnh) Ea Cu Ni Zh Sol and Insol	>0.10		>30*	>1.0 0*	 			├
Feedwater Total Iron (nnh)	>5 (3)	>20*	>40*				├
(insol)	>10*							
(Sol)	>1.0	*	>2.0*	>4.0*				
Feedwater Total Copper (ppb)	>0.2(3)	(7)*	>2.0*	>4.0*				
Feedwater and CDE Dissolved Oxygen (ppb) (low)	<20'	*	<10*	<5*			ļ	
(High)	>50'	•	>200*	>550*		1	<u> </u>	
c. Control Rod Drive Water			.					
Conductivity (µS/cm) @ 25°C	>0.1	5	· · ·	· ·			1	<u> </u>
Dissolved Oxygen(ppb)	>200	0	· ·	· ·	1	<u> </u>	<u> </u>	

- (1) Technical Requirements Manual Actions are controlling.
- Fuel Warranty Limits
- After establishing condenser vacuum with steam air ejector
- (2) Limit of 10µS/cm applies with no chemical addition
- *** SER 89-069 and SER 90-142 **** RG 1.56

*

**

- to circulating water system. EPRI Guidelines weekly integrated value. (3) (4)
- Limit applies during Chemical Additions
- During NMCA the Conductivity will intentionally exceed AL2 for over 48 hours. No further actions are required. (5)
- (6) Conductivity excludes contribution from Iron during and post noble metals chemical addition.
- (7) Feedwater total copper Fuel Warranty action level 1 limit equals 0.5 ppb.

NINE MILE POINT NUCLEAR STATION

OPERATOR JOB PERFORMANCE MEASURE

tle:	Determination of Technical Specification Actions when in Single Loop Operation Revision: 0 and APLHGR is exceeded.					_0_		
Task Number: 341-032-03-03-2 – Evaluate Plant System's performance and coordinate appropriate actions per Technical Specifications, as required								
Approvals:								
		/					/	
General Supervisor Operations Trainin	g (Designee	Date		Gener Opera	ral Supervisor ations (Designe	;)	Date	
Configuration Cont	trol	/ Date	_					
Performer:			(SRO))				
Trainer/Evaluator:_								
Evaluation Method	: X Perfo	rm	Simulate					
aluation Location	n: <u>X</u> Pla	nt	Simulator					
Expected Completion	on Time:	10 min.	Time Critical	Fask:	No	Alternate Path	Task: No)
Start Time:		Stop Time:		Comp	letion Time:			
JPM Overall Rating	;:	Pass	Fail					

NOTE: A JPM overall rating of fail shall be given if <u>any</u> critical step is graded as fail. Any grade of unsat or individual competency area unsat requires a comment.

Comments:

Evaluators Signature:_____

Date:	

NRC EXAM Administrative SRO/JPM # A.1.2

.

Recommended Start Location: (Completion time based on the start location) Any appropriate location with the required Reference Material.

Simulator Set-up (if required): None

mrections to the Instructor/Evaluator:

Prior to performance of this JPM, obtain SSS / CSO general permission to open equipment cabinets and inspection covers. If opening the equipment cabinet or inspection cover will affect Tech. Spec. Operability, operational status, or the effects are unknown, obtain specific SSS / CSO permission.

Directions to Operators:

Read Before Every JPM Performance:

For the performance of this JPM, I will function as the SSS, CSO, and Auxiliary Operators. Prior to providing direction to perform this task, I will provide you with the initial conditions and answer any questions. During task performance, I will identify the steps to be simulated, or discuss and provide cues as necessary.

With the exception of accessing panels, NO plant equipment will be physically manipulated. Repositioning of devices will be simulated by discussion and acknowledged by my cues.

Read Before Each Evaluated JPM Performance:

This evaluated JPM is a measure of your ability to perform this task independently. The Control Room Supervisor has determined that a verifier is not available and that additional / concurrent verification will not be provided; therefore, it should not be requested.

Read Before Each Training JPM Performance:

During this Training JPM, applicable methods of verification are expected to be used. Therefore, either another individual or I will act as the independent/peer verifier.

Notes to Instructor / Evaluator:

- 1. Critical steps are identified in grading areas as Pass/Fail. All steps are sequenced critical unless denoted by a "•".
- 2. During Evaluated JPM:
 - Self verification shall be demonstrated.
- 3. During Training JPM:
 - Self verification shall be demonstrated.
 - No other verification shall be demonstrated.

References:

- 1. Plant Technical Specifications
- 2. NUREG K/A General Knowledges and Abilities 2.1.12(4.0)

Tools and Equipment:

1. 3D Monicore Periodic Log indicating MAPRAT is above 1.0

Task Standard:

Given current plant status and Thermal Limit information, determine the actions required by Technical Specifications.

- 1. The Reactor was operating at 100% power when ONE RCS pump tripped due to an unknown cause.
- 2. N2-SOP-29 has been completed through step 4.3.3.g.
- 3. Maintenance is investigating the cause of the RCS Pump trip.

Initiating Cues:

"(Operator's name), determine the actions required by Technical Specification."

Performance Steps	Standard	Grade	
1. Provide repeat back of initiating cue. Evaluator Acknowledge repeat back providing correction if necessary	Proper communications used for repeat back (GAP-OPS-O1/Operations Manual)	Sat/Unsat	
RECORD START TIME			
2. Obtain a copy of the reference procedure and review/utilize the correct section of the procedure.	Obtains a copy of Technical Specifications. Refers to Reactor Coolant System (RCS) Section.	Sat/Unsat	
 Enters T.S 3.4.1, Recirculation Loops Operating. 	Enters T.S. $-3.4.1$ and determines "Single Loops" operation is allowable as long as the specified LCO's are met.	Pass/Fail	
NOTE: The Steps listed as c. and d. were accomplished by I&C in step 4.3.3.d of N2-SOP-29.	 a. LCO 3.2.1, Average Planar Linear Heat Generation Rate. b. LCO 3.2.2, Minimum Critical Power Ratio. c. LCO 3.3.1.1, Reactor Protection System (RPS) Instrumentation. Reset APRM Biased Thermal Power-Upscale for Single Loop. d. LCO 3.3.2.1, Control Rod Block Instrumentation. Reset RBM – Upscale for Single Loop. 		
CUE: As the Reactor Engineer, provide the candidate with a copy of 3D Monicore	Review 3D Monicore Periodic Log and determine MAPRAT is above 1.0	Pass/Fail	
reriouic Log.	Determines APLHGR limit is being exceeded	Pass/Fail	

Pe	rformance Steps	Standard	Grade
4.	Determines Technical Specification LCO requirements.	 Refers to T.S. 3.4.1, Condition "C" and determines; The APLHGR must be returned to within its LCO limit within four (4) hours, and 	Pass/Fail
		 Refers to T.S. 3.2.1, Condition "A" and determines; The APLHGR(s) must be restored to within limits within two (2) hours IF Required Action A.1 is not met, power must be below 25% RTP in four (4) hours per Required Action B.1 	Pass/Fail

CUE: If asked as the Reactor Engineer, tell the Candidate that you are investigating Rod patterns that will lower the affected APLHGR.

Terminating Cue: Appropriate Technical Specifications have been entered and LCO's referenced.

RECORD STOP TIME

- 1. The Reactor was operating at 100% power when <u>ONE</u> RCS pump tripped due to an unknown cause.
- 2. N2-SOP-29 has been completed through step 4.3.3.g.
- 3. Maintenance is investigating the cause of the RCS Pump trip.

Initiating Cues:

"(Operator's name), determine the actions required by Technical Specification."

5

10	V V V		97		85 4	S OS 91	45 1	38	7 E	30	97	23	81	10 10	90	20	
20	¥ ¥ ¥		7 7		' <u>1</u>	'1		1		1	1	1	- 4		۲	5	0
63	619	- 1	45			•	L					-			-	, c. /	n -
170	¥ ¥ ¥		40													<u>۲</u>	, V -
50	* * *		88			• 1	L				91			Q I		1	
90	<u>አ አ አ</u>		98				-1	- 1						- 1		1 C	ר נו
L 0	***		34				-	-								ב ب	1 1
80	***		25					- 1				u 1			~ .	1	•
60	አአአ		08		9	l		- 1	- 1			21			ςL	5 7	· L
οι	777		87					+	+							ع با	C
11	አ አአ		97					• 1						21		1	·/
15	21	·	54					- 1	- 1					U !			с. С
£1	***	i	22					-	-							1 1 1 1	C
7 L	¥ ¥ ¥	4	50					۰.				91			ZI	ц С	e .
9 L	¥ ¥ ¥	2	81		91			- [•			~ .			<u>с</u> г	3	с. с
9 L	***	•	91					-									C
L L	***	1	7 L					-					91			41 6	17
81	***	i	5 L				•	-									¥
61	¥ ¥ ¥	() L													- <u>-</u>	, A
50	***	8	30			-										<u>.</u> 	ć
12	485	10 <u>9</u>	90			•							* [.]	-		с. С /	а С
22	690	-0 t	70										•				2
5.5	7	č	20				38	32	7	88	GΕ	t	85			<u>_</u> 61	C
54	55	()0									•				0.	2
25	7 S																
10C	Md (13	FCH RF	LON														
	* 311¥		a.141	ГТ. ТШМ =	* ዋ ለ ዎን	iq=q ¶A	ячам	1=M	Q.d.,	I7M≃	ЧЯ	арт.	년 M = :) N	ias A	- ÕH ?	s /
	V L B V - C I - T		97 0	85-3	C~7	218-	0	86~	- 22 -	4-		289	0	86-85		728-(0
1	3 31 7-01-1	1 U	194 0	· · · · ·	6-16	618	0	7 -	72-	-12		685	10	2 4- 4		428.(0
+ +	2 01 1 2-65-1		194 ° 0	C =	- ¥ C	618	0	62-	7 ~	24		289	•0	68-4		448.0)
t	-88-6	15 U	997 0 997 n	20-0-	L V tr → 1 i	200	0	82-	·62-	7		289	0	86-96		428.(J .
	2-10-5 2-10-5	8F 0	99-0	17-7	¥ 1. C−71	200	0	7 -	88-	1.6	I	289	0	4 -85		428.0)
07	2 - 42 - to	, u	99-0	07-03	3 <u>L</u> L 7	200	U O	ι- 	7 -	-02		689	0	92- 4		468.0)
7 7	-02-4	ភ ជ	9910		υ ο Ζ-ας	200 1	, ,	LL-	L	. V		966	0	95-26		428.0)
<u> </u>	E-17 -7	t /.	99.0	- GS-#	-/*	2001	L I	•	εν- +(-			966	0	42-4		428-C)
Žt	2-52-12	· 2	99.0	274-03	2- 2	2001	L I	92-	13-	Έ₽ 		922	0	1-7	i i	458.0)
	DOT	— 	ANDY)()(ייט גע 1 יו	TANYAN PCO	L	C V	30-	VЯ		9 <i>22</i>	.0	41-1		428-0)
			<u>сале</u> (сня				พางกา	£ 1 81	101		10	1.14N	4	DOJ	<u>a</u> (90.19M	1
		088-	L =WI'I	MCPR.	MOTER	, LAUNAR DIGTE	400 L	אי <u>ה</u> . ה	しつい	1 I.M.	ы 16 ф. 16 ф.	. w			.		
		087.	() = 17A	A4AM	00010	=(14,14) TAUMAN	м с.с. м	1 - 1	-001	. 11.13 1.14	DIM T S	C	уршая	900 300	• N(01790)
					000 1	<u>uu</u> 10,	~ ~ ~	ι ι		aav	MET	• 0	ւՕաՕ	UN EV	TUD	19900)
*(01061		ENT	(TAO.T						n	30.5	1				М	
μ	10 <u>5</u>		WO.14	CORE						,	- + u>	· /		IS INA	,	MCDD MCDD	1
そと	- 89		вомев	CORE	89	· 0	0.914	∀н/:	ях	<u></u>	990 1902	2 (C 1		19/UM	આ સ	CAULE) \
		YAAMM	US SNIT	GAO .1	65	-7-	HUN	()M	нх 	۲ ۲	120 120	, ⊒! }}		815 09/001	л М	3400	ļ
					0000	- - i	са ш я <u>т</u>	. H.H.	an R B	ບ ຊຸ	000 1 ° 1 0	ан		יכוע ירח/ ויט	u u	ad 	
	CORE	ғ <u>п</u> г,	- AGAHS	MAGJ		-			-1 11	01 C 1	4 1.0 1774	-		ат\ 11ф)	a. 	្រំជាខ	2 * I
203	117010	10301	(I.IMЧ ФЯ -	АТГЯЯ		STA	ізэя	() ⁽ 1)	¥:)	31 61	ыціі 1973 1973	, , (;		жы / ето	а(ы	TOLAU	•
870	10114	10201	TD EWLD	T ASE						- (167 1	7		11 D (11 D	ne NE N	RECES	
ርዓተ	ъвти	11:40	r-3003	ur-ot		90'1 C	0100	тяяч	d	- F	1957 1957	•		.1. M I	n C Mili	1.3 WOY TGBAG	
ΩЭТА.IU	CALCI	01:10	r-3003	ur-01		<u>अस</u> ्र:	DINO	W (1	Ē	•		;	SN	ម្រី ទី ២ ក ។ លោក ។	<u>ч</u> с И М М М	DOGET	/
		LL	ON BON	япояг	8070	CTG 3.1	LTM :	ANTI	N				0.0	- mar 14 V. (- K ().	9000 9	
PAG									•								

NOTTURISTER DIAL POWER DISTRIBUTION

05 06 10 14 18 55 56 30 34 38 45 46 20 24 28

39

L

7 Y Y

97

10

አአአ

8

L

ለ አ አ

9

NT	VE MTT.	E PT2	C¥08	TNSTRU CALTR	MENT R RATED 1	EADTNGS LPRM RF	S/STAT SADING	TUS SEQUENCE NO 11 GS 10-JUL-2002 11:40 CM CULARES
571) C R		1. 1. 1. 17.	.3 0. 2 1. .0* 0. .3 15.	.3 1. 2 1. 8 13.0 1 26.2	$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	1		10-JUL-2002 11:40 CALCULATED CASE TD FMLD1020710114048 LPRM SHAPE - FULL CORE
49D C R A	34.6 40.4 20.3 36.9	5 30. 51. 20. 41.	3 29. 0 53. 5 20. 1 36.	9 37.8 3 46.6 1 18.0 5 36.2	39.4 14.4 28.9 32.9	34.5 19.9 39.9 45.4		FAILED SENSORS: LPRM (O SIGNAL FAILED) LPRM (O PANACEA DETERT
41D C B A	40.0 63.1 21.2 42.6	46. 52.(20. 36.5	7 39_1 0 55_0 1 15 5 30_3	5 41.2 6 19.6 1 39.3 3 44.7	44.5 20.6 37.4 40.5	61.4 21.8 43.9 49.9	52.5 21.8 37.8 42.8	OTHER SENSORS (O TOTAL) 5 8 SUB RODS 8 NONE 8
33D C R A	48.5 65.5 21.8 37.8	39.5 52.0 20.5 41.1	5 34.5 9 46.6 5 17.3 34.7	5 60.4 5 20.0 40.1 45.6	53.2 21.2 42.6 48.5	67.4 21.6 37.5 42.5	56.3 21.4 43.0 48.9	3 4 7
25D C B A	42.9 56.4 21.9 43.9	46.7 63.1 20.3 36.9	39.4 53.3 16.5 33.2	61.6 19.9 39.9 45.4	65.5 21.0 38.1 41.2	55.9 21.7 43.6 49.7	66.1 21.6 37.5 42.5	Ψ = ΨΤΡ RUN RECOMMENDED
17D C B A	49.9 67.5 20.6 37.4	40_0 52_6 19_9 39_9	37.8 51.0 13.1 26.3	61.4 17.3 34.7 39.4	54,2 20,2 40,6 46,2	67.1 21.0 38.1 41.2	55.9 21.2 42.6 48.5	C = MFLCPR LOCATION M = MAPRAT LOCATION D = MFLPD LOCATION P = PCRAT LOCATION * = MULTIPLE LOCATION
09D C B A		40.5 54.2 17.3 34.7	45.4 65.5 19.9 39.9	29.9 53.3 20.0 40.1	53.3 61.4 19.6 39.3	62.4 40.4 14.4 28.9		
	08 6055	16	24	.3.2	40	48	56	
CORE CORE LOAD	POWER FLOW LINE	UMMAR 39 44 53	¥ - 4 % (- 7 % (3 %	CALC SU OPER SU FLOW BA	B FLOW B FLOW STS	45 -0 ME2	- 4× - 9× As	DP MEAS PST 45.60 DP CALC PST 32.93 FEEDWTR FLOW MLB/HR 61.39
READT AGAF	NG		6 1 5 4	1 6 60 904 4	APRM C7 2 0.4 4 4.956 5	ALTBRAN 3 44.5 50.527	TON 4 68.3 4.81	14
APRM ጥ	- %CTI TP RUM	P IS RFC	105 Ommend	.9 ¢	9.7 7	10.9	70.9	
STRIN	GS:	••• n F/t.	NONE	F []}				

NINE MILE POINT NUCLEAR STATION

OPERATOR JOB PERFORMANCE MEASURE

—Title:

Review and Approval of Completed Surveillance Test N2-OSP-DER-Q001, Revision: <u>0</u> Drywell Equipment Drains Valve Operability Test.

Task Number: 341-012-01-03-2 Review surveillance test results to ensure compliance with specifications.

Approvals:

<u>/6/6/</u>02 Date General Supervisor

eneral Supervisor

Operations Training (Designee)

EXAM SECULITY Date **Configuration Control**

Operations (Designee)

Date

Performer:		(SRO)			
Trainer/Evaluator:	<u> </u>				
Evaluation Method: X Perfo	orm	Simulate			
Evaluation Location:Plant	X	Simulator			
Expected Completion Time:	10 min.	Time Critical Task:	No	Alternate Path Task:	No
Start Time:	Stop Time:	Comp	letion Time:		
JPM Overall Rating:	Pass	Fail			
	CC '1 1 11 1 ·				

NOTE: A JPM overall rating of fail shall be given if <u>any</u> critical step is graded as fail. Any grade of unsat or individual competency area unsat requires a comment.

Comments:

Evaluators Signature:

Date:		

Recommended Start Location: (Completion time based on the start location) Simulator

Simulator Set-up (if required): None

Directions to the Instructor/Evaluator:

Prior to performance of this JPM, obtain SSS / CSO general permission to open equipment cabinets and inspection covers. If opening the equipment cabinet or inspection cover will affect Tech. Spec. Operability, operational status, or the effects are unknown, obtain specific SSS / CSO permission.

Directions to Operators:

Read Before Every JPM Performance:

For the performance of this JPM, I will function as the SSS, CSO, and Auxiliary Operators. Prior to providing direction to perform this task, I will provide you with the initial conditions and answer any questions. During task performance, I will identify the steps to be simulated, or discuss and provide cues as necessary.

With the exception of accessing panels, NO plant equipment will be physically manipulated. Repositioning of devices will be simulated by discussion and acknowledged by my cues.

Read Before Each Evaluated JPM Performance:

This evaluated JPM is a measure of your ability to perform this task independently. The Control Room Supervisor has determined that a verifier is not available and that additional / concurrent verification will not be provided; therefore, it should not be requested.

Read Before Each Training JPM Performance:

During this Training JPM, applicable methods of verification are expected to be used. Therefore, either another individual or I will act as the independent/peer verifier.

Notes to Instructor / Evaluator:

- 1. Critical steps are identified in grading areas as Pass/Fail. All steps are sequenced critical unless denoted by a "•".
- - Self verification shall be demonstrated.
- 3. During Training JPM:
 - Self verification shall be demonstrated.
 - No other verification shall be demonstrated.

References:

- 1. N2-OSP-DER-Q001, Drywell Equipment Drains Valve Operability Test
- 2. NUREG K/A General Knowledges and Abilities 2.2.12 (3.4), 2.2.24 (3.8)

Tools and Equipment:

1. Copy of N2-OSP-DER-Q001, Drywell Equipment Drains Valve Operability Test, completed through Step 9.4.

Task Standard:

Given a copy of N2-OSP-DER-Q001, Drywell Equipment Drains Valve Operability Test, completed through Section 9.4. Complete Section 10.0, Acceptance Criteria and determine if the valves meet the proper

- 1. The Plant is operating at 100% power.
- N2-OSP-DER-Q001, Drywell Equipment Drains Valve Operability Test, has just been completed through Section 9.4.

Initiating Cues:

"(Operator's name), this is a copy of N2-OSP-DER-Q001, Drywell Equipment Drains Valve Operability Test, just completed through Section 9.4, as the Station Shift Supervisor, review the test results and complete Sections 10.1 and 10.2."

Performance Steps	Standard	Grade
1. Provide repeat back of initiating cue. Evaluator Acknowledge repeat back providing correction if necessary	Proper communications used for repeat back (GAP-OPS-O1/Operations Manual)	Sat/Unsat
RECORD START TIME		
 Review/utilize the correct section of the procedure. Evaluator is to provide the marked up copy of N2-OSP-DER-Q001, DRYWELL EQUIPMENT DRAINS VALVE OPERABILITY TEST, to the candidate. 	Reviews General Test Methods, References/Commitments and the Precaution and Limitation Sections.	Sat/Unsat
3. Determines Status of the completed Surveillance.	Review of the completed sections of N2-OSP- DER-Q001, DRYWELL EQUIPMENT DRAINS VALVE OPERABILITY TEST .	Sat/Unsat
CUE: As the Assistant Station Shift Supervisor, tell the Candidate that you are entering the Tech. Specs. and will advise him on the LCO requirements.	 Determines that 2DER*MOV131, EQUIPMENT DRAIN TANK VENT OUTBOARD ISOLATION VALVE, is NOT OPERABLE, due to; Step 8.7, stroke time, greater than Tech. Spec. limit [≤18 sec.]. Surveillance is UNSATISFACTORY. 	Pass/Fail
4. Notify appropriate Plant Management.	Completes Sections 10.1 and 10.2 of N2-OSP- DER-Q001, DRYWELL EQUIPMENT DRAINS VALVE OPERABILITY TEST.	Sat/Unsat
CUE: As the Manager of Operations acknowledge the status presented.	Notifies MANAGER OF OPERATIONS or designee.	Sat/Unsat

Ferminating Cue: Determination of the status of this surveillance has been made and the proper notifications have been performed.

RECORD STOP TIME _____

- ✓1. The Plant is operating at 100% power.
 - 2. N2-OSP-DER-Q001, Drywell Equipment Drains Valve Operability Test, has just been completed through Section 9.4.

Initiating Cues:

"(Operator's name), this is a copy of N2-OSP-DER-Q001, Drywell Equipment Drains Valve Operability Test, just completed through Section 9.4, as the Station Shift Supervisor, review the test results and complete Sections 10.1 and 10.2."

NINE MILE POINT NUCLEAR STATION

OPERATOR JOB PERFORMANCE MEASURE

Title:	Direct React	tor Building	Evacuation due t	o a Radiation	n Emergency.	Rev	ision: 0	
Task Number:	344-906-05-	03-2 – Direc	et Actions require	d for a Radia	ation Emergen	cy.		
Approvals:								
<u></u>		/					1	
Operations Train	or ing (Designee	Da)	te	General Operation	Supervisor ons (Designee))	Date	
Configuration Co	ntrol	/ Da	te					
Performer:			(SR	0)				
Trainer/Evaluator	•							
Evaluation Metho	d: <u>X</u> Perfor	m	Simulate					
Evaluation Locati	on:Plant	_ <u>X</u>	Simulator					
Expected Comple	tion Time:	15 min.	Time Critica	l Task: 1	No	Alternate Path	1 Task:	No
Start Time:		Stop Time:_		Completi	ion Time:			
JPM Overall Ratin	ıg:	Pass	Fail					
NOTE: A JPM ove competence	erall rating of by area unsat r	fail shall be equires a cor	given if <u>any</u> crition nment.	al step is gra	aded as fail. A	ny grade of uns	at or indi	vidual

Comments:

Evaluators Signature:

Date:		

Recommended Start Location: (Completion time based on the start location) Any appropriate location with the required Reference Material.

Simulator Set-up (if required): None

IN (

Directions to the Instructor/Evaluator:

Prior to performance of this JPM, obtain SSS / CSO general permission to open equipment cabinets and inspection covers. If opening the equipment cabinet or inspection cover will affect Tech. Spec. Operability, operational status, or the effects are unknown, obtain specific SSS / CSO permission.

Directions to Operators:

Read Before Every JPM Performance:

For the performance of this JPM, I will function as the SSS, CSO, and Auxiliary Operators. Prior to providing direction to perform this task, I will provide you with the initial conditions and answer any questions. During task performance, I will identify the steps to be simulated, or discuss and provide cues as necessary.

With the exception of accessing panels, NO plant equipment will be physically manipulated. Repositioning of devices will be simulated by discussion and acknowledged by my cues.

Read Before Each Evaluated JPM Performance:

This evaluated JPM is a measure of your ability to perform this task independently. The Control Room Supervisor has determined that a verifier is not available and that additional / concurrent verification will not be provided; therefore, it should not be requested.

Read Before Each Training JPM Performance:

During this Training JPM, applicable methods of verification are expected to be used. Therefore, either another individual or I will act as the independent/peer verifier.

Notes to Instructor / Evaluator:

- 1. Critical steps are identified in grading areas as Pass/Fail. All steps are sequenced critical unless denoted by a "•".
- 2. During Evaluated JPM:
 - Self verification shall be demonstrated.
- 3. During Training JPM:
 - Self verification shall be demonstrated.
 - No other verification shall be demonstrated.

References:

- 1. EPIP-EPP-5A and Attachment 1
- 2. NUREG K/A General Knowledges and Abilities 2.3.10(3.3), 2.4.29(4.0) 2.4.38(4.0)

Tools and Equipment:

1. None

Task Standard:

Given a set of Plant conditions, direct actions to evacuate a local area without an Emergency Classification being declared.

- The Reactor is operating at 100% power.
- It is Day Shift on a Tuesday morning and normal work is being carried out in the Reactor Building.
- I&C is working in the TIP Room.
- A problem with one of the TIP probes has caused a high radiation condition in that area
 - Several area Rad Monitors on Reactor Building 240 and 261 are alarming.
 - Current radiation readings in the TIP Room area are 600 mr/hr.
 - <u>NO</u> emergency has been declared.

Initiating Cues:

"(Operator's name), Take necessary action to ensure safety of plant personnel."

Pe	rformance Steps	Standard	Grade
1.	Provide repeat back of initiating cue. Evaluator Acknowledge repeat back providing correction if necessary	Proper communications used for repeat back (GAP-OPS-O1/Operations Manual)	Sat/Unsat
RI	ECORD START TIME		
1.	Obtain a copy of the reference procedure and review/utilize the correct section of the procedure. Evaluator is to provide a blank copy of	EPIP-EPP-5A is obtained and Attachment 1 is referenced.	Sat/Unsat
2.	EPIP-EPP-05A, Attachment 1 to the candidate.	Inserts the following information into	
	EPIP-EPP-5A.	ATTACHMENT 1;	
		 (Block 3a): "This is NOT a Drill. (Block 3b): Nine Mile Point, Unit 2 is evacuating the Reactor Building (minimum acceptable area is RB 240 and 261 elevations) 	Pass/Fail Pass/Fail
		• (Block 3c): Due to high radiation	Pass/Fail
		 (Block 3d): ALL personnel should leave the Unit 2 Reactor Building (minimum acceptable area is RB 240 and 261 elevations). 	Pass/Fail

Performan	Performance Steps		Standard	Grade
\smile			 Personnel should NOT leave the area via any North or West accesses. Staying clear of the TIP Room. Personnel should report to their normal work locations. 	Sat/Unsat Pass/Fail
CUE: (B <u>Ca</u> <u>"A</u> <u>be</u>	Block 3e) <u>When asked by the</u> andidate, state that ACCOUNTABILITY" is NOT sing performed.	•	(Block 3e): Should be left blank, based on the Cue	
NOTE: (I ei hi	Block 3f) <u>The Candidate may check</u> ither of these boxes as this is up to is/her opinion.	•	(Block 3f): Checks either block 1 or 2	Sat/Unsat
_		•	(Block 3g): Circles "is not a drill".	Sat/Unsat
6. Provide CSO.	completed Attachment 1 to the	Pro AT	wides the CSO with the completed TACHMENT 1 .	Sat/Unsat
Cue: W A7 ca the	Then the Candidate completes TTACHMENT 1, inform Indidate that the CSO will make e announcment.			

Terminating Cue: When the Candidate has completed Attachment 1 and given it to the CSO for announcement.

RECORD STOP TIME

- The Reactor is operating at 100% power.
- It is Day Shift on a Tuesday morning and normal work is being carried out in the Reactor Building.
 - I&C is working in the TIP Room
 - A problem with one of the TIP probes has caused a high radiation condition in that area
 - Several area Rad Monitors on Reactor Building 240 and 261 are alarming.
 - Current radiation readings in the TIP Room area are 600 mr/hr.
 - <u>NO</u> emergency has been declared.

Initiating Cues:

"(Operator's name), Take necessary action to ensure safety of plant personnel."

NINE MILE POINT NUCLEAR STATION

OPERATOR JOB PERFORMANCE MEASURE

-Title:

Emergency Classification and Protective Action Recommendations (PAR'S) Revision: 0

Task Number:

344-019-03-03-2 - Classify Emergency Events requiring Emergency Plan Implementation. 344-902-05-03-2 - Make Protective Action Recommendations as necessary per EPP's.

Approvals:

<u>/6/6/02</u> Date General Supervisor

Operations Training (Designee)

EXAM SECURE **Configuration Control** Date

Supervisor Operations (Designee)

Performer:		(SRO)				
Trainer/Evaluator:						
Evaluation Method: X Perfor	m .	_Simulate				
Evaluation Location: X Plan	nt	Simulator				
Expected Completion Time:	15 min.	Time Critical T	ask:	No	Alternate Path Task:	No
Start Time:	Stop Time:		Compl	etion Time:	<u>.</u>	
JPM Overall Rating:	Pass	Fail				

NOTE: A JPM overall rating of fail shall be given if any critical step is graded as fail. Any grade of unsat or individual competency area unsat requires a comment.

Comments:

Evaluators Signature:

Date:	

NRC EXAM Administrative SRO JPM # A.4

Recommended Start Location: (Completion time based on the start location) Main Control Room or any other appropriate location with the proper references.

Simulator Set-up (if required): None.

Directions to the Instructor/Evaluator:

Prior to performance of this JPM, obtain SSS / CSO general permission to open equipment cabinets and inspection covers. If opening the equipment cabinet or inspection cover will affect Tech. Spec. Operability, operational status, or the effects are unknown, obtain specific SSS / CSO permission.

Directions to Operators:

Read Before Every JPM Performance:

For the performance of this JPM, I will function as the SSS, CSO, and Auxiliary Operators. Prior to providing direction to perform this task, I will provide you with the initial conditions and answer any questions. During task performance, I will identify the steps to be simulated, or discuss and provide cues as necessary.

With the exception of accessing panels, NO plant equipment will be physically manipulated. Repositioning of devices will be simulated by discussion and acknowledged by my cues.

Read Before Each Evaluated JPM Performance:

This evaluated JPM is a measure of your ability to perform this task independently. The Control Room Supervisor has determined that a verifier is not available and that additional / concurrent verification will not be provided; therefore, it should not be requested.

Read Before Each Training JPM Performance:

During this Training JPM, applicable methods of verification are expected to be used. Therefore, either another individual or I will act as the independent/peer verifier.

Notes to Instructor / Evaluator:

- 1. Critical steps are identified in grading areas as Pass/Fail. All steps are sequenced critical unless denoted by a "•".
- 2. During Evaluated JPM:
 - Self verification shall be demonstrated. •
- 3. During Training JPM:
 - Self verification shall be demonstrated. ٠
 - No other verification shall be demonstrated. ٠

References:

- 1. EPIP-EPP-02, Classification of Emergency Conditions at Unit 2
- 2. EPIP-EPP-18, Activation and Direction of Emergency Plans
- 3. EPIP-EPP-08, Off-Site Dose Assessment and Protective Action Recommendation
- 4. Unit 2 EOP Flow Charts, N2-EOP-C2, N2-EOP-C5, and N2-EOP-PC

5. NUREG 1123, 2.4.16(4.0), 2.4.29(4.0). 2.4.40(4.0).2.4.41(4.1), 2.4.44(4.0)

Tools and Equipment:

1. N2-EOP Flowcharts, EAL Matrix and marked up copy of Part I Notification Fact Sheet

Task Standard:

Given a set of Plant conditions, classify the Emergency and make Protective Action Recommendations (PAR's) as required.

NRC EXAM Administrative SRO JPM # A.4

- A LOCA is in progress, Drywell pressure is 10 psig rising slowly and N2-EOP-PC has been entered.
- Not all Control Rods were fully inserted on the Scram, N2-EOP-C5, Failure to Scram, has been entered.
- All attempts to insert the Control Rods have failed to this point.
- Indicated Reactor Vessel Water level was -85 inches and remaining fairly constant.
- Reactor Power is 12% as indicated on SPDS.
- N2-EOP-C2, RPV Blowdown, has been entered.
- All 7 ADS Valves are open
- Reactor Pressure is 100 psig and lowering slowly.
- Indicated Reactor Vessel Water level is -90 inches and slowly lowering, following the blowdown.
- <u>ALL</u> available "Preferred ATWS Injection Systems" and "Alternate ATWS Injections Systems" are injecting into the Reactor Vessel.

Initiating Cues:

"(Operator's name), using the Emergency Operating Procedures (EOP's) and Emergency Action Level Matrix, determine the required Emergency Classification for this event."

Performance Steps	Standard	Grade
1. Provide repeat back of initiating cue. Evaluator Acknowledge repeat back providing correction if necessary	Proper communications used for repeat back (GAP-OPS-O1/Operations Manual)	Sat/Unsat

RECORD START TIME

Part A

1.	Obtain a copy of the reference procedure and review/utilize the correct section of the procedure.	N2-EOP-C5 is referenced and reviewed against current conditions. EPIP-EPP-02 Attachment 1 (EAL Matrix) referenced.	Sat/Unsat
2. Deterr Emerg	Determines and declares a "General Emergency".	Determines that with the provided conditions, N2-EOP-C5 must be exited and all SAP's entered from Step L-18 (or Step L-8).	Sat/Unsat
		GENERAL EMERGENCY is declared based on Primary Containment Flooding IS REQUIRED (EAL GE 2.1.3 OR 2.2.3)	Pass/Fail

Performance Steps	Standard	Grade
Part B		
NOTE: If the candidate declares an event below the General Emergency level, the critical step is unsatisfactory. The JPM shall be stopped.		
EVALUATOR: When the candidate declares a General Emergency, provide the candidate with attached Part B Initial Conditions and Initiating Cue Information Sheet.		
<u>Cue:</u> As the Control Room Communicator , provide the candidate with the attached Part I- Notification Fact Sheet for SSS/ED review.		
3. Review Part I- Notification Fact Sheet.	Refers to EPIP-EPP-08, Step 3.1.2 to review and approve Part I- Notification Fact Sheet	Sat/Unsat
NOTE: If necessary, inform the candidate that verification of data other than Block #7 on the notification sheet is not required. Only the verification of PARs is required.	Refers to EPIP-EPP-08, Attachment 1 Uses TABLE 1.2 to determine affected ERPA's , based on wind direction of 280°, identified in Block #12 of the Part I.	Sat/Unsat
 Determines ERPAs to be evacuated and sheltered. 	Confirms the following ERPAs are identified in Block #7	Pass/Fail
 Confirms ERPAs identified on Part I are correctly identified. 	 Block #7 B: EVACUATES two (2) miles around and five (5) miles downwind of the following ERPA's: 1, 2, 3, 4, 5, 7, 9, 26, 27. <u>AND</u> SHELTERS all remaining ERPA's. 	
 Indicates approval of the Part I- Notification Fact Sheet PARs by signing the "Approved By (SSS/ED or ED/RM)" line on the bottom of the form OR for this JPM, verbally indicates to the 	Signs"Approved By (SSS/ED or ED/RM)" line on the bottom of the form OR verbally indicates to the Evaluator that the PARs indicated on the sheet are correct.	Pass/Fail

Terminating Cue: Determination of an Event Classification and Protective Action Recommendations (PAR's) for the given situation.

RECORD STOP TIME

Evaluator that the PARs are correct.

Part A

Initial Conditions:

- A LOCA is in progress, Drywell pressure is 10 psig rising slowly and N2-EOP-PC has been entered.
- Not all Control Rods were fully inserted on the Scram, N2-EOP-C5, Failure to Scram, has been entered.
- All attempts to insert the Control Rods have failed to this point.
- Indicated Reactor Vessel Water level was -85 inches and remaining fairly constant.
- Reactor Power is 12% as indicated on SPDS.
- N2-EOP-C2, RPV Blowdown, has been entered.
- All 7 ADS Valves are open
- Reactor Pressure is 100 psig and lowering slowly.
- Indicated Reactor Vessel Water level is -90 inches and slowly lowering, following the blowdown.
- <u>ALL</u> available "Preferred ATWS Injection Systems" and "Alternate ATWS Injections Systems" are injecting into the Reactor Vessel.

Initiating Cues:

"(Operator's name), using the Emergency Operating Procedures (EOP's) and Emergency Action Level Matrix, determine the required Emergency Classification for this event."

5

Part B Initial Conditions and Initiating Cue Information Sheet

←Initial Conditions:

- 1. A General Emergency has been declared, based on the previous plant conditions
- 2. You have assumed the role as SSS/ED in the Control Room.

Initiating Cue:

"(Operator's Name), Prior to transmitting the Part I- Notification Fact Sheet to offsite agencies, review and approve the Protective Action Recommendations that are identified on the Part I- Notification Fact Sheet, that has been provided to you by the Control Room Communicator".