

APR 6 1984

NRC PDR  
LPDR  
PRC System  
NSIC  
HDenton  
DEisenhut  
HRood  
JLee (2)

MEMORANDUM FOR: James R. Miller, Chief  
Operating Reactors Branch No. 3  
Division of Licensing

FROM: George W. Knighton, Chief  
Licensing Branch No. 3  
Division of Licensing

SUBJECT: REQUEST FOR PUBLICATION IN MONTHLY FR NOTICE - NOTICE OF  
ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE

Southern California Edison Company, et al, Docket No. 50-362, San Onofre  
Nuclear Generating Station, Unit 3, San Diego County, California

Date of application for amendment: January 3, 1984

Brief description of amendment: Temporary change to Technical Specification  
3.6.1.7 to allow the 8-inch containment purge system to be operated up to  
3000 hours per 365 days prior to the third refueling outage. After the third  
refueling outage, the limit will revert to the previous value of 1000 hours  
per 365 days.

Date of issuance: March 13, 1984

Amendment No.: 9

Facility Operating License No. NPF-15: Amendment revised the Technical  
Specifications.

Date of initial notice in Federal Register: February 2, 1984 (49 F.R. 4166)

The Commission's related evaluation of the amendment is contained in a

8404250304 840406  
PDR ADOCK 05000362  
P PDR

Safety Evaluation dated March 13, 1984. No significant hazards consideration comments were received.

Local Public Document Room Location: San Clemente Library, 242 Avenida Del Mar, San Clemente, California

Original signed by  
George W. Knighton

George W. Knighton, Chief  
Licensing Branch No. 3  
Division of Licensing

cc: H. Rood  
J. Lee  
P. Kreutzer

\*See previous concurrence.  
DL:LB#3  
JLee/yt  
4/1/84

DL:LB#3\*  
HRood  
3/12/84

OELD\*  
LChandler  
3/12/84

DL:LB#3  
GWNighton  
4/5/84