

MAR 13 1984

Docket No.: 50-362

Mr. Kenneth P. Baskin
Vice President
Southern California Edison Company
2244 Walnut Grove Avenue
Post Office Box 800
Rosemead, California 91770

Mr. James C. Holcombe
Vice President - Power Supply
San Diego Gas & Electric Company
101 Ash Street
Post Office Box 1831
San Diego, California 92112

Gentlemen:

Subject: Issuance of Amendment No. 9 to Facility Operating License NPF-15
San Onofre Nuclear Generating Station, Unit 3

The Nuclear Regulatory Commission (the Commission) has issued the enclosed Amendment No. 9 to Facility Operating License NPF-15 for the San Onofre Nuclear Generating Station, Unit 3, located in San Diego County, California. The amendment temporarily modifies Technical Specification 3.6.1.7 to allow the 8-inch containment purge system to be operated up to 3000 hours per 365 days, prior to the third refueling outage. After the third refueling outage, the limit will revert to the previous value of 1000 hours per 365 days. The change is necessitated by the unexpectedly high leakage of fission gasses from the fuel, resulting in high noble gas activity levels in the containment building.

Although a permanent increase in the purge limit was requested in your letter of January 3, 1984, the staff has concluded that there is no basis for granting the increased limit beyond the third refueling outage, because at that time all of the fuel presently in the reactor will have been removed. Therefore, we are denying your request for a permanent increase, but are granting the increase until the third refueling outage. In your letter of February 16, 1984, you indicated that the temporary increase in the purge limit is acceptable.

Distribution

Document Control (50-362)

NRC PDR:

L PDR	EJordan
PRC System	LHarmon
NSIC	DBrinkman, SSPB
LB#3 Reading	TBarnhart (4)
JLee	
HRood	
JSaltzman, SAB	
Attorney, OELD	
CMiles	
HDenton	
JRutberg	
AToalston	
NGrace	

8404040266 840313
PDR ADOCK 05000362
P PDR

A copy of the Safety Evaluation supporting this amendment is also enclosed.

Sincerely,

Original signed by:
George W. Knighton

George W. Knighton, Chief
Licensing Branch No. 3
Division of Licensing

Enclosures:

1. Amendment No. 9 to NPF-15
2. Safety Evaluation

cc: See next page

W
DL:LB#3
HRood/yt
2/28/84

DL:LB#3
JLee
2/28/84

DL:LB#3
GWKnighton
3/12/84

WRIGHT

OEL
LChandler
2/28/84

DL:AD/L
TMNovak
3/13/84

San Onofre

Mr. Kenneth P. Baskin
Vice President
Southern California Edison Company
2244 Walnut Grove Avenue
P. O. Box 800
Rosemead, California 91770

Mr. James C. Holcombe
Vice President - Power Supply
San Diego Gas & Electric Company
101 Ash Street
Post Office Box 1831
San Diego, California 92112

Charles R. Kocher, Esq.
James A. Beoletto, Esq.
Southern California Edison Company
2244 Walnut Grove Avenue
P. O. Box 800
Rosemead, California 91770

Orrick, Herrington & Sutcliffe
ATTN: David R. Pigott, Esq.
600 Montgomery Street
San Francisco, California 94111

Alan R. Watts, Esq.
Rourke & Woodruff
Suite 1020
1055 North Main Street
San Clemente, California, 92701

Mr. V. C. Hall
Combustion Engineering, Inc.
1000 Prospect Hill Road
Windsor, Connecticut 06095

Mr. S. McClusky
1450 Maria Lane/Suite 210
Walnut Creek, California 94596

Mr. C. B. Brinkman
Combustion Engineering, Inc.
7910 Woodmont Avenue
Bethesda, Maryland 20814

Mr. Dennis F. Kirsh
U.S. Nuclear Regulatory Commission - Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596

Mr. Mark Medford
Southern California Edison Company
2244 Walnut Grove Avenue
P. O. Box 800
Rosemead, California 91770

Mr. Henry Peters
San Diego Gas & Electric Company
P. O. Box 1831
San Diego, California 92112

Richard J. Wharton, Esq.
University of San Diego School of
Law
Environmental Law Clinic
San Diego, California 92110

Charles E. McClung, Jr., Esq.
Attorney at Law
24012 Calle de la Plaza/Suite 330
Laguna Hills, California 92653

Region Administrator-Region V/NRC
1450 Maria Lane/Suite 210
Walnut Creek, California 92672

Resident Inspector, San Onofre NPS
c/o U. S. NRC
Post Office Box 4329
San Clemente, California 92672

California State Library
Government Publications Section
Library & Courts Building
Sacramento, CA 95841
ATTN: Ms. Mary Schnell

Director, Energy Facilities
Siting Division
Energy Resources Conservation &
Development Commission
1111 Howe Avenue
Sacramento, CA 95825

Mayor, City of San Clemente
San Clemente, CA 92672

Chairman, Board Supervisors
San Diego County
San Diego, CA 92412

California Dept. of Health
ATTN: Chief, Environmental
Radiation Control Unit
Radiological Health Section
714 P Street, Room 498
Sacramento, CA 95814

Mr. Joseph O. Ward, Chief
Radiological Health Branch
State Department of Health Services
714 P Street, Building #8
Sacramento, California 95814

SOUTHERN CALIFORNIA EDISON COMPANY

SAN DIEGO GAS AND ELECTRIC COMPANY

THE CITY OF RIVERSIDE, CALIFORNIA

THE CITY OF ANAHEIM, CALIFORNIA

DOCKET NO. 50-362

SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 9
License No. NPF-15

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment for the San Onofre Nuclear Generating Station, Unit 3 (the facility) filed by the Southern California Edison Company on behalf of itself and San Diego Gas and Electric Company, The City of Riverside and The City of Anaheim, California (licensees) dated January 3, 1984 and February 16, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public;
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8404040268 840313
PDR ADOCK 05000362
P PDR

2. Accordingly, the license is hereby amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-15 to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 9, are hereby incorporated in the license. SCE shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Original signed by:
George W. Knighton

George W. Knighton, Chief
Licensing Branch No. 3
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: **MAR 13 1984**

HR
DL:LB#3
HRood/yt
2/28/84

DL:LB#3
JLee
2/28/84

WRIGHT
OEL
LChandler
3/2/84

DL:LB#3
GWKnighton
3/12/84

SAFETY EVALUATION

AMENDMENT NO. 9 TO NPF-15

SAN ONOFRE GENERATING STATION, UNIT 3

DOCKET NO. 50-362

Introduction and Summary

By letter dated January 3, 1984, the licensees (Southern California Edison Company, San Diego Gas and Electric Company, the City of Anaheim, California, and the City of Riverside, California) requested that an amendment be issued to Facility Operating License NPF-15 for operation of the San Onofre Nuclear Generating Station, Unit 3. The licensees requested that the limit on operation of the 8-inch containment purge system (1000 hours per 365 days) be permanently changed to 3000 hours per 365 days.

Evaluation

Unexpectedly high noble gas activity levels in the San Onofre 3 containment building during 100% power operation have necessitated routine operation of the 8-inch purge system to prevent containment activity levels from exceeding the purge activity limit. If the purge activity limit is exceeded, the plant must be shut down and no purging done until the activity level decays to an acceptable level. Routine purging is also required to maintain the activity level sufficiently low to permit personnel access to system components inside containment for inspection and maintenance, and to maintain containment pressure within the Technical Specification limit.

Because of the unexpectedly high noble gas activity levels in the San Onofre 3 containment, the licensees requested that they be permitted to use the 8-inch purge system up to 3,000 hours per 365 days.

Inasmuch as the high noble gas activity levels are thought to be unique to the first core of Unit 3, and purge system usage will continue to be restricted to safety-related needs in accordance with staff guidelines and usage will be in compliance with the provisions of 10 CFR 50.36a so as to assure that releases are maintained as low as reasonably achievable, we conclude that using the 8-inch purge system for 3,000 hours per 365 days is acceptable for the life of the first core. Staff acceptance is also based on the fact that the proposed purge time and expected coolant activity levels are within the range considered in a previous staff safety evaluation (NUREG-0712), and the Technical Specifications include provisions for coping with levels of radioactivity in the primary coolant that are higher than expected.

B404040270 B40313
PDR ADDCK 05000362
P PDR

Therefore, in accordance with the SRP requirement that purge time should be minimized, we are granting the requested change for the life of the first core, i.e., until the third refueling outage. The licensees have agreed that their request can be limited to this period of time.

Contact With State Official

By copy of a letter dated January 30, 1984 to the licensees, the NRC staff advised the Chief of the Radiological Health Branch, State Department of Health Services, State of California, of its proposed determination of no significant hazards consideration. No comments were received.


Environmental Consideration


We have determined that these amendments do not authorize a change in effluent types or total amount nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that these amendments involve action which is insignificant from the standpoint of environmental impact and pursuant 10 CFR Section 51.5(d) (4), that an environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

Conclusion

Based upon our evaluation of the proposed changes to the San Onofre, Unit 3 Technical Specifications, we have concluded that: there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or the health and safety of the public. We, therefore, conclude that the proposed changes are acceptable, but are limiting the change to the time period from now until the third refueling outage. By letter dated February 16, 1984, the licensees agreed that this limiting of the change is acceptable.

Dated: MAR 13 1984


DL:LB #3
HRood/yt
3/12/84


DL:ME #3
GWK/hton
3/12/84