

December 2, 1997

Mr. Gregory M. Rueger, Senior Vice President
and General Manager
Pacific Gas and Electric Company
Nuclear Power Generation N9B
P.O. Box 770000
San Francisco, California 94177

SUBJECT: CORRECTION TO AMENDMENTS 119 AND 117 FOR DIABLO CANYON NUCLEAR
POWER PLANT, UNITS 1 (TAC NO. M95910) AND 2 (TAC NO. M95911)

Dear Mr. Rueger:

On April 14, 1997, the Commission issued Amendment No. 119 to Facility
Operating License No. DPR-80 and Amendment No. 117 to Facility Operating
License No. DPR-82 for Diablo Canyon Nuclear Power Plant, Unit Nos. 1 and 2
(DCPP), respectively. The amendments consisted of changes to the Technical
Specifications (TS) in response to your application dated May 31, 1996, as
supplemented by letter dated December 16, 1996. The amendments revised the
combined TS to revise 23 TS surveillance requirements to support
implementation of extended fuel cycles at DCPP.

Page 3/4 3-32 omitted prior amendment numbers for each unit and a correction
letter was issued on July 17, 1997. Due to an administrative error, the
previous revision to this page to extend a surveillance frequency from "R"
to "R24" was omitted. The corrected page 3/4 3-32 is enclosed. The
corresponding overleaf page is also provided to maintain document
completeness. We apologize for any inconvenience.

Sincerely,
Original Signed By
Steven D. Bloom, Project Manager
Project Directorate IV-2
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket Nos. 50-275
and 50-323

Enclosure: Page 3/4 3-32

cc w/encl: See next page

DISTRIBUTION:

Docket JKilcrease, RIV
PUBLIC LHurley, RIV
PDIV-2 Reading JBianchi, WCFO (2)
EAdensam (EGA1)
WBateman
SBloom
EPeyton
OGC
GHill (4)
WBeckner
ACRS
HWong, Region IV WCFO
KPerkins, Region IV WCFO

DF01/1

Document Name:DC95910.COR

OFC	PDIV-2	PDIV-2	
NAME	SBloom	EPeyton	
DATE	12/2/97	12/2/97	

OFFICIAL RECORD COPY

9712150318 971202
PDR ADOCK 05000275
P PDR



Mr. Gregory M. Rueger

- 2 -

December 2, 1997

cc w/encl:

NRC Resident Inspector
Diablo Canyon Nuclear Power Plant
c/o U.S. Nuclear Regulatory Commission
P. O. Box 369
Avila Beach, California 93424

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Harris Tower & Pavillion
611 Ryan Plaza Drive, Suite 400
Arlington, Texas 76011-8064

Dr. Richard Ferguson, Energy Chair
Sierra Club California
1100 11th Street, Suite 311
Sacramento, California 95814

Christopher J. Warner, Esq.
Pacific Gas & Electric Company
Post Office Box 7442
San Francisco, California 94120

Ms. Nancy Culver
San Luis Obispo
Mothers for Peace
P. O. Box 164
Pismo Beach, California 93448

Mr. Robert P. Powers
Vice President and Plant Manager
Diablo Canyon Nuclear Power Plant
P. O. Box 56
Avila Beach, California 93424

Chairman
San Luis Obispo County Board of
Supervisors
Room 370
County Government Center
San Luis Obispo, California 93408

Telegram-Tribune
ATTN: Managing Editor
1321 Johnson Avenue
P.O. Box 112
San Luis Obispo, California 93406

Mr. Truman Burns
Mr. Robert Kinosian
California Public Utilities Commission
505 Van Ness, Room 4102
San Francisco, California 94102

Mr. Steve Hsu
Radiologic Health Branch
State Department of Health Services
Post Office Box 942732
Sacramento, California 94232

Diablo Canyon Independent Safety
Committee
ATTN: Robert R. Wellington, Esq.
Legal Counsel
857 Cass Street, Suite D
Monterey, California 93940

TABLE 3.3-5 (Continued)

TABLE NOTATIONS

- (1) Diesel generator starting delay not included because offsite power available.
- (2) Notation deleted.
- (3) Diesel generator starting and loading delays included.
- (4) Diesel generator starting delay not included because offsite power is available. Response time limit includes opening of valves to establish SI path and attainment of discharge pressure for centrifugal charging pumps (where applicable). Sequential transfer of charging pump suction from the VCT to the R&ST (R&ST valves open, then VCT valves close) is included.
- (5) Diesel generator starting and sequence loading delays included. Offsite power is not available. Response time limit includes opening of valves to establish SI path and attainment of discharge pressure for centrifugal charging pumps. Sequential transfer of charging pump suction from the VCT to the R&ST (R&ST valves open, then VCT valves close) is included.
- (6) The maximum response time of 48.5 seconds is the time from when the containment pressure exceeds the High-High Setpoint until the spray pump is started and the discharge valve travels to the fully open position assuming off-site power is not available. The time of 48.5 seconds includes the 28-second maximum delay related to ESF loading sequence. Spray riser piping fill time is not included. The 80-second maximum spray delay time does not include the time from LOCA start to "P" signal.
- (7) Diesel generator starting and sequence loading delays included. Sequential transfer of charging pump suction from the VCT to the R&ST (R&ST valves open, then VCT valves close) is not included. Response time limit includes opening of valves to establish SI flow path and attainment of discharge pressure for centrifugal charging pumps, SI, and RHR pumps (where applicable).
- (8) Does not include Trip Time Delays. Response times include the transmitters, Eagle-21 Process Protection cabinets, Solid State Protection System cabinets and actuation devices only. This reflects the response times necessary for THERMAL POWER in excess of 50% RTP.

TABLE 4.3-2

ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION
SURVEILLANCE REQUIREMENTS

DIABLO CANYON - UNITS 1 & 2	FUNCTIONAL UNIT	CHANNEL CHECK	CHANNEL CALI-BRATION	CHANNEL OPERA-TIONAL TEST	TRIP ACTUATING DEVICE OPERA-TIONAL TEST	ACTUATION LOGIC TEST	MASTER RELAY TEST	SLAVE RELAY TEST	MODES FOR WHICH SURVEILLANCE IS REQUIRED
	1. Safety Injection. (Reactor Trip Feedwater Isolation, Start Diesel Generators, Containment Fan Cooler Units, and Component Cooling Water)								
3/4 3-32	a. Manual Initiation	N.A.	N.A.	N.A.	R24	N.A.	N.A.	N.A.	1, 2, 3, 4
	b. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	N.A.	N.A.	M(1)	M(1)	R	1, 2, 3, 4
	c. Containment Pressure-High	S	R	Q	N.A.	N.A.	N.A.	N.A.	1, 2, 3, 4
	d. Pressurizer Pressure-Low	S	R	Q	N.A.	N.A.	N.A.	N.A.	1, 2, 3
	e. DELETED								
	f. Steam Line Pressure-Low	S	R	Q	N.A.	N.A.	N.A.	N.A.	1, 2, 3
	2. Containment Spray (coincident with SI signal)								
	a. Manual Initiation	N.A.	N.A.	N.A.	R24	N.A.	N.A.	N.A.	1, 2, 3, 4
	b. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	N.A.	N.A.	M(1)	M(1)	R	1, 2, 3, 4
	c. Containment Pressure-High-High	S	R	Q	N.A.	N.A.	N.A.	N.A.	1, 2, 3, 4

Unit 1 - Amendment 61, 84, 87, 89, 114, 115, 118, 119
Unit 2 - Amendment 60, 83, 86, 88, 112, 113, 116, 117