

August 4, 1998

Mr. Gregory M. Rueger, Senior Vice President  
and General Manager  
Pacific Gas and Electric Company  
NPG - Mail Code A10D  
P.O. Box 770000  
San Francisco, California 94177

SUBJECT: ISSUANCE OF AMENDMENT NO. 126 FOR DIABLO CANYON NUCLEAR  
POWER PLANT, UNIT NO. 1 (TAC NO. M98094) AND AMENDMENT NO.  
124 FOR UNIT NO. 2 (TAC NO. M98095)

Dear Mr. Rueger:

On June 5, 1998, the Commission issued Amendment No. 126 to Facility Operating License No. DPR-80 and Amendment No. 124 to Facility Operating License No. DPR-82 for the Diablo Canyon Nuclear Power Plant, Unit Nos. 1 and 2, respectively. These amendments changed the combined Technical Specifications (TS) to revise the surveillance frequencies from at least once every 18 months to at least once per refueling interval (nominally 24 months) for the (1) eight slave relays, (2) 20 electrical system tests, (3) one electrical TS Bases change, and (4) five miscellaneous tests.

Due to an administrative error, the amendment numbers that appeared on page 3/4 3-34 were incorrect. Enclosed is a corrected page. The overleaf page is also provided to maintain document completeness. We apologize for any inconvenience this may have caused.

Sincerely,  
Original Signed By

Steven D. Bloom, Project Manager  
Project Directorate IV-2  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket Nos. 50-275  
and 50-323

Enclosure: Page 3/4 3-34

cc w/encl: See next page

DISTRIBUTION:

Docket File  
PUBLIC  
PDIV-2 Reading  
EGA1  
WBateman  
SBloom  
KPerkins, RIV WCFO  
EPeyton  
LHurley, Region IV

WBeckner  
JBianchi, WCFO (2)  
GHill (4)  
OGC  
ACRS  
HWong, RIV WCFO  
JKilcrease, RIV  
JCalvo

Document Name: DC98094.COR

OFC	PDIV-2	PDIV-2	OGC
NAME	SBloom	EPeyton	Comarco
DATE	7/10/98	7/8/98	7/29/98

OFFICIAL RECORD COPY

9808070301 980804  
PDR ADDCK 05000275  
P PDR

DFC 1/1

Mr. Gregory M. Rueger

- 2 -

August 4, 1998

cc w/encl:  
NRC Resident Inspector  
Diablo Canyon Nuclear Power Plant  
c/o U.S. Nuclear Regulatory Commission  
P. O. Box 369  
Avila Beach, California 93424

Dr. Richard Ferguson, Energy Chair  
Sierra Club California  
1100 11th Street, Suite 311  
Sacramento, California 95814

Ms. Nancy Culver  
San Luis Obispo  
Mothers for Peace  
P. O. Box 164  
Pismo Beach, California 93448

Chairman  
San Luis Obispo County Board of  
Supervisors  
Room 370  
County Government Center  
San Luis Obispo, California 93408

Mr. Truman Burns  
Mr. Robert Kinosian  
California Public Utilities Commission  
505 Van Ness, Room 4102  
San Francisco, California 94102

Mr. Steve Hsu  
Radiologic Health Branch  
State Department of Health Services  
Post Office Box 942732  
Sacramento, California 94232

Diablo Canyon Independent Safety  
Committee  
ATTN: Robert R. Wellington, Esq.  
Legal Counsel  
857 Cass Street, Suite D  
Monterey, California 93940

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
Harris Tower & Pavillion  
611 Ryan Plaza Drive, Suite 400  
Arlington, Texas 76011-8064

Christopher J. Warner, Esq.  
Pacific Gas & Electric Company  
Post Office Box 7442  
San Francisco, California 94120

Mr. Robert P. Powers  
Vice President and Plant Manager  
Diablo Canyon Nuclear Power Plant  
P. O. Box 56  
Avila Beach, California 93424

Telegram-Tribune  
ATTN: Managing Editor  
1321 Johnson Avenue  
P.O. Box 112  
San Luis Obispo, California 93406

TABLE 4.3-2 (Continued)

ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION  
SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALI- BRATION</u>	<u>CHANNEL OPERA- TIONAL TEST</u>	<u>TRIP ACTUATING DEVICE OPERA- TIONAL TEST</u>	<u>ACTUATION LOGIC TEST</u>	<u>MASTER RELAY TEST</u>	<u>SLAVE RELAY TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
<b>3. Containment Isolation</b>								
<b>a. Phase "A" Isolation</b>								
1) Manual	N.A.	N.A.	N.A.	R24	N.A.	N.A.	N.A.	1, 2, 3, 4
2) Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	N.A.	N.A.	M(1)	M(1)	R24	1, 2, 3, 4
3) Safety Injection	See Item 1. above for all Safety Injection Surveillance Requirements.							
<b>b. Phase "B" Isolation</b>								
1) Manual	N.A.	N.A.	N.A.	R24	N.A.	N.A.	N.A.	1, 2, 3, 4
2) Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	N.A.	N.A.	M(1)	M(1)	R24	1, 2, 3, 4
3) Containment Pressure-High-High	S	R24	Q	N.A.	N.A.	N.A.	N.A.	1, 2, 3, 4
<b>c. Containment Ventilation Isolation</b>								
1) Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	N.A.	N.A.	M(1)	M(1)	R24	1, 2, 3, 4
2) Deleted								
3) Safety Injection	See Item 1. above for all Safety Injection Surveillance Requirements.							
4) Containment Ventilation Exhaust Radiation-High (RM-44A and 44B)	S	R24	Q	N.A.	N.A.	N.A.	N.A.	1, 2, 3, 4

TABLE 4.3-2 (Continued)

ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION  
SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALI- BRATION</u>	<u>CHANNEL OPERA- TIONAL TEST</u>	<u>TRIP ACTUATING DEVICE OPERA- TIONAL TEST</u>	<u>ACTUATION LOGIC TEST</u>	<u>MASTER RELAY TEST</u>	<u>SLAVE RELAY TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
4. Steam Line Isolation								
a. Manual	N.A.	N.A.	N.A.	R24	N.A.	N.A.	N.A.	1, 2, 3
b. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	N.A.	N.A.	M <sup>(1)</sup>	M <sup>(1)</sup>	R24	1, 2, 3
c. Containment Pressure-High-High	S	R24	Q	N.A.	N.A.	N.A.	N.A.	1, 2, 3
d. Steam Line Pressure-Low	S	R24	Q	N.A.	N.A.	N.A.	N.A.	1, 2, 3
e. Negative Steam Line Pressure Rate-High	S	R24	Q	N.A.	N.A.	N.A.	N.A.	3 <sup>(3)</sup>
5. Turbine Trip and Feedwater Isolation								
a. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	N.A.	N.A.	M <sup>(1)</sup>	M <sup>(1)</sup>	R24	1, 2
b. Steam Generator Water Level-High-High	S	R24	Q	N.A.	N.A.	N.A.	N.A.	1, 2
6. Auxiliary Feedwater								
a. Manual	N.A.	N.A.	N.A.	R	N.A.	N.A.	N.A.	1, 2, 3
b. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	N.A.	N.A.	M <sup>(1)</sup>	M <sup>(1)</sup>	R24	1, 2, 3
c. Steam Generator Water Level-Low-Low								
1) Steam Generator Water Level-Low-Low	S	R24	Q	N.A.	N.A.	N.A.	N.A.	1, 2, 3 <sup>(5)</sup>
2) RCS Loop ΔT Equivalent to Power	N.A.	R24	Q	N.A.	N.A.	N.A.	N.A.	1, 2

DIABLO CANYON - UNITS 1 & 2 3/4 3-34 Unit 1 - Amendment 61, 84, 103, 114, 115, 118, 122, 126  
 Unit 2 - Amendment 60, 83, 102, 112, 113, 116, 120, 124