

April 14, 1989

Docket No.: 50-362

Mr. Kenneth P. Baskin
Vice President
Southern California Edison Company
2244 Walnut Grove Avenue
Post Office Box 800
Rosemead, California 91770

Mr. Gary D. Cotton
Senior Vice President
Engineering and Operations
San Diego Gas and Electric Company
101 Ash Street
Post Office Box 1831
San Diego, California 92112

Gentlemen:

SUBJECT: ISSUANCE OF NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT
SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 2 (TAC NO. 72710)

Enclosed for your information is a Notice of Consideration of Issuance of Amendment to Facility Operating License and Opportunity for Hearing. The notice relates to your request of March 10, 1989 to revise Technical Specification 3/4.10, "Special Test Exceptions," to include a new Specification 3/4.10.7, "18 Month Channel Calibrations," to the Unit 2 Technical Specifications to permit a one-time extension to the 18 month surveillance requirements for certain instrumentation included in Specifications 3/4.3.1, "Reactor Protection Instrumentation;" 3/4.3.2, "Engineered Safety Features Actuation System Instrumentation;" 3/4.3.3.5, "Remote Shutdown Instrumentation;" and 3/4.3.3.6, "Accident Monitoring Instrumentation." This request was designated by you as proposed change PCN-290.

The Notice has been sent to Office of the Federal Register for publication.

Sincerely,

original signed by

Donald E. Hickman, Project Manager
Project Directorate V
Division of Reactor Projects III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Enclosure:
Notice

cc w/enclosure:
See next page

DISTRIBUTION

Docket File	DHagan
NRC & LPDRs	ACRS (10)
PDV Reading	GPA/PA
GMHolahan	MVirgilio
JLee	DHickman
OGC	

DRSP/LA:PDV
JLee
4/13/89

DRSP/PA:PDV
DHickman:rw
4/12/89

DRSP/ID:PDV
GWrighton
4/14/89

DF01

LOG p3 4/11

8905030019 890414
PDR ADOCK 05000362
PDC

OPIN

Mr. Kenneth P. Baskin
Southern California Edison Company

San Onofre Nuclear Generating
Station, Units 2 and 3

cc:

Mr. Gary D. Cotton
Senior Vice President
Engineering and Operations
San Diego Gas & Electric Company
101 Ash Street
Post Office Box 1831
San Diego, California 92112

Charles R. Kocher, Esq.
James A. Beoletto, Esq.
Southern California Edison Company
2244 Walnut Grove Avenue
P. O. Box 800
Rosemead, California 91770

Orrick, Herrington & Sutcliffe
ATTN: David R. Pigott, Esq.
600 Montgomery Street
San Francisco, California 94111

Alan R. Watts, Esq.
Rourke & Woodruff
701 S. Parker St. No. 7000
Orange, California 92668-4702

Mr. S. McClusky
Bechtel Power Corporation
P. O. Box 60860, Terminal Annex
Los Angeles, California 90060

Mr. Charles B. Brinkman
Combustion Engineering, Inc.
12300 Twinbrook Parkway, Suite 330
Rockville, Maryland 20852

Mr. Dennis F. Kirsh
U.S. Nuclear Regulatory Commission
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596

Mr. Sherwin Harris
Resource Project Manager
Public Utilities Department
City of Riverside
City Hall
3900 Main Street
Riverside, California 92522

Mr. Hans Kaspar, Executive Director
Marine Review Committee, Inc.
531 Encinitas Boulevard, Suite 105
Encinitas, California 92024

Mr. Mark Medford
Southern California Edison Company
2244 Walnut Grove Avenue
P. O. Box 800
Rosemead, California 91770

Mr. Robert G. Lacy
Manager, Nuclear Department
San Diego Gas & Electric Company
P. O. Box 1831
San Diego, California 92112

Richard J. Wharton, Esq.
University of San Diego School of
Law
Environmental Law Clinic
San Diego, California 92110

Charles E. McClung, Jr., Esq.
Attorney at Law
24012 Calle de la Plaza/Suite 330
Laguna Hills, California 92653

Regional Administrator, Region V
U.S. Nuclear Regulatory Commission
1450 Maria Lane/Suite 210
Walnut Creek, California 94596

Resident Inspector, San Onofre NPS
c/o U. S. Nuclear Regulatory Commission
Post Office Box 4329
San Clemente, California 92672

UNITED STATES NUCLEAR REGULATORY COMMISSIONSOUTHERN CALIFORNIA EDISON COMPANY, ET ALDOCKET NO. 50-362NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO
FACILITY OPERATING LICENSE AND OPPORTUNITY FOR HEARING

The U. S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. NPF-10 issued to Southern California Edison Company (SCE), San Diego Gas and Electric Company, the City of Riverside, California and the City of Anaheim, California (the licensees), for operation of San Onofre Nuclear Generating Station, Unit 2 located in San Diego County, California. The request for amendment was submitted by letter dated March 10, 1989 and identified as Proposed Change PCN-290.

The proposed change would revise Technical Specification (TS) 3/4.10, "Special Test Exceptions," to include a new Specification 3/4.10.7, "18 Month Channel Calibrations," to the Unit 2 Technical Specifications. TS 3/4.10.7 would permit a one-time extension of the 18 month surveillance requirements for certain instrumentation included in TS 3/4.3.1, "Reactor Protective Instrumentation;" TS 3/4.3.2, "Engineered Safety Feature Actuation System Instrumentation;" TS 3/4.3.3.5, "Remote Shutdown Instrumentation;" and TS 3/4.3.3.6, "Accident Monitoring Instrumentation." This extension would terminate upon entry into the Cycle 5 refueling outage into a mode in which the operability of the instruments is no longer required or October 1, 1989, whichever occurs first.

Before issuance of the proposed license amendments, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

By May 24 , 1989 the licensees may file a request for a hearing with respect to issuance of the amendments to the subject facility operating licenses, and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for hearing and petition for leave to intervene. Requests for a hearing and petitions for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel will rule on the request and/or petition, and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR 2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) the nature of the petitioner's right under the Act to be made a party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may

be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to fifteen (15) days prior to the first pre-hearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

Not later than fifteen (15) days prior to the first pre-hearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be litigated in the matter, and the bases for each contention set forth with reasonable specificity. Contentions shall be limited to matters within the scope of the amendments under consideration. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

A request for a hearing or a petition for leave to intervene shall be filed with the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Docketing and Service Branch, or may be delivered to the Commission's Public Document Room, 2120 L Street, NW, Washington, DC, by the above date. Where petitions are filed during the last ten (10) days of the notice period, it is requested that the petitioner or representative for the petitioner promptly inform the Commission by a toll-free

telephone call to Western Union at 1-(800)325-6000 (in Missouri 1-(800)342-6700). The Western Union operator should be given Datagram Identification Number 3737 and the following message addressed to George W. Knighton: petitioner's name and telephone number; date petition was mailed; plant name; and publication date and page number of this FEDERAL REGISTER notice. A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555, and to Mr. Charles R. Kocher, Esq., Southern California Edison Company, 2244 Walnut Grove Avenue, P.O. Box 800, Rosemead, California 91770 and Orrick, Herrington and Sutcliffe, Attention: David R. Pigott, Esq., 600 Montgomery Street, San Francisco, California 94111, attorneys for the licensees.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board, that the petition and/or request should be granted based upon a balancing of the factors specified in the 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

If a request for hearing is received, the Commission's staff may issue the amendment after it completes its technical review and prior to the completion of any required hearing if it publishes a further notice for public comment of its proposed finding of no significant hazards consideration in accordance with 10 CFR 50.91 and 50.92.

For further details with respect to this action, see the application for amendments which is available for public inspection at the Commission's Public Document Room, 2120 L Street NW, Washington, DC, and at the General Library, University of California at Irvine, Irvine, California 92713.

Dated at Rockville, Maryland, this 14th day of April , 1989.

FOR THE NUCLEAR REGULATORY COMMISSION



George W. Knighton, Director
Project Directorate V
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation