

May 28, 1996

Mr. Gregory M. Rueger
Pacific Gas and Electric Company
NPG - Mail Code A10D
P. O. Box 770000
San Francisco, California 94177

SUBJECT: ISSUANCE OF AMENDMENTS FOR DIABLO CANYON NUCLEAR POWER PLANT,
UNIT NO. 1 (TAC NO. M95066) AND UNIT NO. 2 (TAC NO. M95067)

Dear Mr. Rueger:

The Commission has issued the enclosed Amendment No. 112 to Facility Operating License No. DPR-80 and Amendment No. 110 to Facility Operating License No. DPR-82 for the Diablo Canyon Nuclear Power Plant, Unit Nos. 1 and 2, respectively. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated March 13, 1995.

These amendments delete the requirement in TS 4.0.5a for NRC written approval prior to implementation of relief from ASME Code requirements by deleting "...(g), except where specific written relief has been granted by the Commission pursuant to 10 CFR 50.55a(g)(6)(i)." Also the amendments would add ASME Section XI definition of "Biennially or every 2 years - At least once per 731 days," in TS 4.0.5b.

A copy of the related Safety Evaluation is enclosed. The Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

Original Signed By

Steven D. Bloom, Project Manager
Project Directorate IV-2
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket Nos. 50-275
and 50-323

- Enclosures: 1. Amendment No. 112 to DPR-80
- 2. Amendment No. 110 to DPR-82
- 3. Safety Evaluation

cc w/encls: See next page

DISTRIBUTION

Docket File	CGrimes, 011E22
PUBLIC	JBianchi, WCFO (2)
PDIV-2 Reading	GHill (4), T5C3
EGA1	OGC, 015B18
LHurley, RIV	ACRS, T2E26
WBateman	DChamberlain, RIV
KPerkins, WCFO	CMH2 (SE)
SBloom	EPeyton
JKilcrease	RWessman

DOCUMENT NAME: DC95066.AMD

OFC	PDIV-2	PDIV-2	EMEB	OGC	EGG3
NAME	EPeyton	SBloom:ye	RWessman	EHOLLER	GBoguchi
DATE	4/30/96	4/30/96	5/1/96	5/6/96	5/1/96

OFFICIAL RECORD COPY

DFD 1/1

9605310087 960528
PDR ADOCK 05000275
P PDR

NRC FILE CENTER COPY

May 28, 1996

Mr. Gregory M. Rueger
Pacific Gas and Electric Company
NPG - Mail Code A10D
P. O. Box 770000
San Francisco, California 94177

SUBJECT: ISSUANCE OF AMENDMENTS FOR DIABLO CANYON NUCLEAR POWER PLANT,
UNIT NO. 1 (TAC NO. M95066) AND UNIT NO. 2 (TAC NO. M95067)

Dear Mr. Rueger:

The Commission has issued the enclosed Amendment No. 112 to Facility Operating License No. DPR-80 and Amendment No. 110 to Facility Operating License No. DPR-82 for the Diablo Canyon Nuclear Power Plant, Unit Nos. 1 and 2, respectively. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated March 13, 1995.

These amendments delete the requirement in TS 4.0.5a for NRC written approval prior to implementation of relief from ASME Code requirements by deleting "...(g), except where specific written relief has been granted by the Commission pursuant to 10 CFR 50.55a(g)(6)(i)." Also the amendments would add ASME Section XI definition of "Biennially or every 2 years - At least once per 731 days," in TS 4.0.5b.

A copy of the related Safety Evaluation is enclosed. The Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

Original Signed By

Steven D. Bloom, Project Manager
Project Directorate IV-2
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket Nos. 50-275
and 50-323

- Enclosures: 1. Amendment No. 112 to DPR-80
- 2. Amendment No. 110 to DPR-82
- 3. Safety Evaluation

cc w/encls: See next page

DISTRIBUTION

Docket File
PUBLIC
PDIV-2 Reading
EGAI
LHurley, RIV
Wbateman
KPerkins, WCFO
SBloom
JKilcrease

CGrimes, 011E22
JBianchi, WCFO (2)
GHill (4), T5C3
OGC, 015B18
ACRS, T2E26
DChamberlain, RIV
CMH2 (SE)
EPeyton
RWessman

DOCUMENT NAME: DC95066.AMD

OFC	PDIV-2	PDIV-2	EMEB	OGC	ECG
NAME	EPeyton	SBloom:ye	RWessman	EHoller	GBogchi
DATE	4/30/96	4/30/96	5/1/96	5/6/96	5/1/96

OFFICIAL RECORD COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

May 28, 1996

Mr. Gregory M. Rueger
Pacific Gas and Electric Company
NPG - Mail Code A10D
P. O. Box 770000
San Francisco, California 94177

SUBJECT: ISSUANCE OF AMENDMENTS FOR DIABLO CANYON NUCLEAR POWER PLANT,
UNIT NO. 1 (TAC NO. M95066) AND UNIT NO. 2 (TAC NO. M95067)

Dear Mr. Rueger:

The Commission has issued the enclosed Amendment No. 112 to Facility Operating License No. DPR-80 and Amendment No. 110 to Facility Operating License No. DPR-82 for the Diablo Canyon Nuclear Power Plant, Unit Nos. 1 and 2, respectively. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated March 13, 1995.

These amendments delete the requirement in TS 4.0.5a for NRC written approval prior to implementation of relief from ASME Code requirements by deleting "... (g), except where specific written relief has been granted by the Commission pursuant to 10 CFR 50.55a(g)(6)(i)." Also the amendments would add ASME Section XI definition of "Biennially or every 2 years - At least once per 731 days," in TS 4.0.5b.

A copy of the related Safety Evaluation is enclosed. The Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

A handwritten signature in black ink, appearing to read "Steven D. Bloom".

Steven D. Bloom, Project Manager
Project Directorate IV-2
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket Nos. 50-275
and 50-323

Enclosures: 1. Amendment No. 112 to DPR-80
2. Amendment No. 110 to DPR-82
3. Safety Evaluation

cc w/encls: See next page

cc w/encls:

NRC Resident Inspector
Diablo Canyon Nuclear Power Plant
c/o U.S. Nuclear Regulatory Commission
P. O. Box 369
Avila Beach, California 93424

Dr. Richard Ferguson, Energy Chair
Sierra Club California
1100 11th Street, Suite 311
Sacramento, California 95814

Ms. Nancy Culver
San Luis Obispo
Mothers for Peace
P. O. Box 164
Pismo Beach, California 93448

Ms. Jacquelyn C. Wheeler
P. O. Box 164
Pismo Beach, California 93448

Managing Editor
The County Telegram Tribune
1321 Johnson Avenue
P. O. Box 112
San Luis Obispo, California 93406

Chairman
San Luis Obispo County Board of
Supervisors
Room 370
County Government Center
San Luis Obispo, California 93408

Mr. Truman Burns
Mr. Robert Kinosian
California Public Utilities Commission
505 Van Ness, Room 4102
San Francisco, California 94102

Mr. Steve Hsu
Radiologic Health Branch
State Department of Health Services
Post Office Box 942732
Sacramento, California 94232

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Harris Tower & Pavillion
611 Ryan Plaza Drive, Suite 400
Arlington, Texas 76011-8064

Christopher J. Warner, Esq.
Pacific Gas & Electric Company
Post Office Box 7442
San Francisco, California 94120

Mr. Warren H. Fujimoto
Vice President and Plant Manager
Diablo Canyon Nuclear Power Plant
P. O. Box 56
Avila Beach, California 93424

Diablo Canyon Independent Safety
Committee
ATTN: Robert R. Wellington, Esq.
Legal Counsel
857 Cass Street, Suite D
Monterey, California 93940



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

PACIFIC GAS AND ELECTRIC COMPANY

DOCKET NO. 50-275

DIABLO CANYON NUCLEAR POWER PLANT, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 112
License No. DPR-80


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Pacific Gas and Electric Company (the licensee) dated March 13, 1996, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-80 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 112, are hereby incorporated in the license. Pacific Gas and Electric Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan, except where otherwise stated in specific license conditions.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Steven D. Bloom, Project Manager
Project Directorate IV-2
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: May 28, 1996



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

PACIFIC GAS AND ELECTRIC COMPANY

DOCKET NO. 50-323

DIABLO CANYON NUCLEAR POWER PLANT, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 110
License No. DPR-82


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Pacific Gas and Electric Company (the licensee) dated March 13, 1996, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-82 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 110, are hereby incorporated in the license. Pacific Gas and Electric Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan, except where otherwise stated in specific license conditions.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Steven D. Bloom, Project Manager
Project Directorate IV-2
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: May 28, 1996

ATTACHMENT TO LICENSE AMENDMENTS

AMENDMENT NO. 112 TO FACILITY OPERATING LICENSE NO. DPR-80

AND AMENDMENT NO. 110 TO FACILITY OPERATING LICENSE NO. DPR-82

DOCKET NOS. 50-275 AND 50-323

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by Amendment number and contain marginal lines indicating the areas of change. The corresponding overleaf pages are also provided to maintain document completeness.

REMOVE

3/4 0-2
B 3/4 0-3

INSERT

3/4 0-2
B 3/4 0-3

3/4 LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

3/4.0 APPLICABILITY

LIMITING CONDITION FOR OPERATION

3.0.1 Compliance with the Limiting Conditions for Operation contained in the succeeding specifications is required during the OPERATIONAL MODES or other conditions specified therein; except that upon failure to meet the Limiting Conditions for Operation, the associated ACTION requirements shall be met.

3.0.2 Noncompliance with a specification shall exist when the requirements of the Limiting Condition for Operation and associated ACTION requirements are not met within the specified time intervals. If the Limiting Condition for Operation is restored prior to expiration of the specified time intervals, completion of the ACTION requirements is not required.

3.0.3 When a Limiting Condition for Operation is not met, except as provided in the associated ACTION requirements, within 1 hour action shall be initiated to place the unit in a MODE in which the specification does not apply by placing it, as applicable, in:

- a. At least HOT STANDBY within the next 6 hours,
- b. At least HOT SHUTDOWN within the following 6 hours, and
- c. At least COLD SHUTDOWN within the subsequent 24 hours.

Where corrective measures are completed that permit operation under the ACTION requirements, the action may be taken in accordance with the specified time limits as measured from the time of failure to meet the Limiting Condition for Operation. Exceptions of these requirements are stated in the individual specifications.

This specification is not applicable in MODE 5 or 6.

3.0.4 Entry into an OPERATIONAL MODE or other specified condition shall not be made when the conditions for the Limiting Conditions for Operation are not met and the associated ACTION requires a shutdown if they are not met within a specified time interval. Entry into an OPERATIONAL MODE or specified condition may be made in accordance with ACTION requirements when conformance to them permits continued operation of the facility for an unlimited period of time. This provision shall not prevent passage through or to OPERATIONAL MODES as required to comply with ACTION statements. Exceptions to these requirements are stated in the individual specifications.

3.0.5 Limiting Conditions for Operation including the associated ACTION requirements shall apply to each unit individually unless otherwise indicated as follows:

- a. Whenever the Limiting Conditions for Operation refers to systems or components which are shared by both units, the ACTION requirements will apply to both units simultaneously. This will be indicated in the ACTION section;
- b. Whenever the Limiting Conditions for Operation applies to only one unit, this will be identified in the APPLICABILITY section of the specification; and
- c. Whenever certain portions of a specification contain operating parameters, Setpoints, etc., which are different for each unit, this will be identified in parentheses, footnotes or body of the requirement.

APPLICABILITY

SURVEILLANCE REQUIREMENTS

4.0.1 Surveillance Requirements shall be met during the OPERATIONAL MODES or other conditions specified for individual Limiting Conditions for Operation unless otherwise stated in an individual Surveillance Requirement.

4.0.2 Each Surveillance Requirement shall be performed within the specified surveillance interval with a maximum allowable extension not to exceed 25 percent of the specified surveillance interval.

4.0.3 Failure to perform a Surveillance Requirement within the allowed surveillance interval defined by Specification 4.0.2 shall constitute non-compliance with the OPERABILITY requirements for a Limiting Condition for Operation. The time limits of the ACTION requirements are applicable at the time it is identified that a Surveillance Requirement has not been performed. The ACTION requirements may be delayed for up to 24 hours to permit the completion of the surveillance when the allowable outage time limits of the ACTION requirements are less than 24 hours. Exceptions to these requirements are stated in the individual specifications. Surveillance Requirements do not have to be performed on inoperable equipment.

4.0.4 Entry into an OPERATIONAL MODE or other specified condition shall not be made unless the Surveillance Requirement(s) associated with the Limiting Condition for Operation has been performed within the stated surveillance interval or as otherwise specified. This provision shall not prevent passage through or to OPERATIONAL MODES as required to comply with ACTION requirements.

4.0.5 Surveillance Requirements for inservice inspection and testing of ASME Code Class 1, 2 and 3 components shall be applicable as follows:

- a. Inservice inspection of ASME Code Class 1, 2 and 3 components and inservice testing of ASME Code Class 1, 2 and 3 pumps, valves, and snubbers shall be performed in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as required by 10 CFR 50, Section 50.55a;
- b. Surveillance intervals specified in Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda for the inservice inspection and testing activities required by the ASME Boiler and Pressure Vessel Code and applicable Addenda shall be applicable as follows in these Technical Specifications:

**ASME BOILER AND PRESSURE VESSEL
CODE AND APPLICABLE ADDENDA
TERMINOLOGY FOR INSERVICE
INSPECTION AND TESTING ACTIVITIES**

**REQUIRED FREQUENCIES FOR
PERFORMING INSERVICE
INSPECTION AND TESTING
ACTIVITIES**

Weekly
Monthly
Quarterly or every 3 months
Semiannually or every 6 months
Every 9 months
Yearly or annually
Biennially or every 2 years

At least once per 7 days
At least once per 31 days
At least once per 92 days
At least once per 184 days
At least once per 276 days
At least once per 366 days
At least once per 731 days

APPLICABILITY**BASES**

surveillance interval was exceeded. Completion of the Surveillance Requirement within the allowable outage time limits of the ACTION requirements restores compliance with the requirements of Specification 4.0.3.

If the allowable outage time limits of the ACTION requirements are less than 24 hours or a shutdown is required to comply with ACTION requirements, e.g., Specification 3.0.3, a 24-hour allowance is provided to permit a delay in implementing the ACTION requirements. This provides an adequate time limit to complete Surveillance Requirements that have not been performed. The purpose of this allowance is to permit the completion of a surveillance before a shutdown is required to comply with ACTION requirements or before other remedial measures would be required that may preclude completion of a surveillance. The basis for this allowance includes consideration for plant conditions, adequate planning, availability of personnel, the time required to perform the surveillance, and the safety significance of the delay in completing the required surveillance. This provision also provides a time limit for the completion of Surveillance Requirements that become applicable as a consequence of MODE changes imposed by ACTION requirements and for completing Surveillance Requirements that are applicable when an exception to the requirements of Specification 4.0.4 is allowed. If a surveillance is not completed within the 24-hour allowance, the time limits of the ACTION requirements are applicable at that time. When a surveillance is performed within the 24-hour allowance and the Surveillance Requirements are not met, the time limits of the ACTION requirements are applicable at the time that the surveillance is terminated.

Surveillance Requirements do not have to be performed on inoperable equipment because the ACTION requirements define the remedial measures that apply. However, the Surveillance Requirements have to be met to demonstrate that inoperable equipment has been restored to OPERABLE status.

APPLICABILITY

BASES

4.0.4 This specification establishes the requirement that all applicable surveillances must be met before entry into an OPERATIONAL MODE or other condition of operation specified in the Applicability statement. The purpose of this specification is to ensure that system and component OPERABILITY requirements or parameter limits are met before entry into a MODE or condition for which these systems and components ensure safe operation of the facility. This provision applies to changes in OPERATIONAL MODES or other specified conditions associated with plant shutdown as well as startup.

Under the provisions of this specification, the applicable Surveillance Requirements must be performed within the specified surveillance interval to ensure that the Limiting Conditions for Operation are met during initial plant startup or following a plant outage.

When a shutdown is required to comply with ACTION requirements, the provisions of Specification 4.0.4 do not apply because this would delay placing the facility in a lower MODE of operation.

4.0.5 This specification establishes the requirement that inservice inspection of ASME code Class 1, 2, and 3 components and inservice testing of ASME Code Class 1, 2, and 3 pumps, valves, and snubbers shall be performed in accordance with a periodically updated version of Section XI of the ASME Boiler and Pressure Vessel Code and Addenda as required by 10 CFR 50.55a.

This specification includes a clarification of the frequencies for performing the inservice inspection and testing activities required by Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda. This clarification is provided to ensure consistency in surveillance intervals throughout the Technical Specifications and to remove any ambiguities relative to the frequencies for performing the required inservice inspection and testing activities.

Under the terms of this specification, the more restrictive requirements of the Technical Specifications take precedence over the ASME Boiler and Pressure Vessel Code and applicable Addenda. The requirements of Specification 4.0.4 to perform surveillance activities before entry into an OPERATIONAL MODE or other specified condition takes precedence over the ASME Boiler and Pressure Vessel Code provision which allows pumps and valves to be tested up to one week after return to normal operation. The Technical Specification definition of OPERABLE does not allow a grace period before a component, that is not capable of performing its specified function, is declared inoperable and takes precedence over the ASME Boiler and Pressure Vessel Code provision which allows a valve to be incapable of performing its specified function for up to 24 hours before being declared inoperable.

4.0.6 This specification delineates the applicability of the surveillance activities to Unit 1 and Unit 2 operations.



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 112 TO FACILITY OPERATING LICENSE NO. DPR-80
AND AMENDMENT NO. 110 TO FACILITY OPERATING LICENSE NO. DPR-82
PACIFIC GAS AND ELECTRIC COMPANY
DIABLO CANYON NUCLEAR POWER PLANT, UNITS 1 AND 2
DOCKET NOS. 50-275 AND 50-323

1.0 INTRODUCTION

By application dated March 13, 1996, Pacific Gas and Electric Company (or the licensee) requested changes to the Technical Specifications (Appendix A to Facility Operating License Nos. DPR-80 and DPR-82) for the Diablo Canyon Nuclear Power Plant, Units 1 and 2. The proposed changes would revise TS 4.0.5a to delete the requirement for NRC written approval prior to implementation of relief from ASME Code requirements by deleting "... (g), except where specific written relief has been granted by the Commission pursuant to 10 CFR 50.55a(g)(6)(i)." Also the amendments would add ASME Section XI definition of "Biennially or every 2 years - At least once per 731 days," in TS 4.0.5b.

2.0 BACKGROUND

The Commission's final policy statement on technical specifications improvements defines the scope of the technical specifications (TS) and provides a criterion for technical design items to be included in, or relocated out of the TS document. On July 19, 1995 (60 FR 36953), the NRC published the final rule governing the implementation of this policy via a revision of 10 CFR 50.36, "Technical Specifications," which became effective August 18, 1995. The April 7, 1995, revised version of the Standard Technical Specifications (STS) (NUREG-1431, Rev. 1), relocates the inservice testing (IST) requirements to the administrative controls section of the TS and deletes a portion of the inservice inspection (ISI) requirements, retaining the reactor coolant pump (RCP) flywheel inspections in the administrative controls section. NUREG-1482, "Guidelines for Inservice Testing Programs at Nuclear Power Plants," Chapter 6, recommends that licensees revise their TSs to incorporate the revised STS for IST programs.

The 10-year interval for the Diablo Canyon Unit 1 IST and ISI programs began January 1, 1996, and Unit 2 IST and ISI programs begins on June 1, 1996. The TS change will allow the licensee a period of 12 months from the beginning of the interval to identify, submit, and obtain approval of relief requests for impractical code requirements in accordance with 10 CFR 50.55a, paragraphs (f)(5) and (g)(5), for IST and ISI respectively.

3.0 EVALUATION

The licensee has made a revision to TS 4.0.5a and its Bases deleting the clause requiring written relief from the Commission under all ISI and IST testing deviations. Diablo Canyon Power Plant based these revisions on the guidance of NUREG-1482; NUREG 1431, Revision 0; Generic Letter (GL) 89-04, Supplement 1, "Guidance on Developing Acceptable Inservice Testing Programs;" and 10 CFR 50.55a. If an impracticality is determined within the initial interval or within the first 12 months of a new interval, the licensee follows the requirements in 10 CFR 50.55a(f)(5)(iii) and (iv) or (g)(5)(iii) and (iv). If an impractical requirement is identified during subsequent intervals and not within the first 12 months, the licensee must meet the requirements of 10 CFR 50.55a(f)(5)(iii) or (g)(5)(iii), notify the Commission, submit the information supporting the determination of impracticality, and obtain NRC's approval pursuant to (f)(6)(i) or (g)(6)(i), prior to the time that the next test or inspection is required. However, the specification does not allow the licensee to implement alternative testing under paragraphs 50.55a(a)(3)(i) and (ii) until authorized by the Director of the Office of Nuclear Reactor Regulation.

The licensee further proposes to add the ASME Code Section XI definition of biennial in TS 4.0.5b to be consistent with NUREG-1482 recommendations.

These changes to the licensee's TS are consistent with the intent of the revised STS and the regulatory guidance in NUREG-1482. The ISI and IST requirements are given in 10 CFR 50.55a, which the licensee documents via its 10-year interval program requirements. The change is acceptable since the regulatory requirements are delineated in 10 CFR 50.55a, and the change eliminates inconsistencies between the TS and the regulations.

4.0 STATE CONSULTATION

In accordance with the Commission's regulations, the California State official was notified of the proposed issuance of the amendments. The State official had no comments.

5.0 ENVIRONMENTAL CONSIDERATION

These amendments change a surveillance requirement. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (61 FR 18173). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: S. Bloom

Date: May 28, 1996