

(16)

10/3 Davis-Beese phone call

post inspection

100% inspection of head

bovic acid interferences on some nozzles → 5-6 nozzles
looked at base of nozzles

future inspection

qualified visual - have measured
end of next week to get the SIA report

Fracture - modified Peter Scott

00 in it flaw

180° around

3½ year through wall, 4 years for another, 90°

environment is not much different from PW

- prior inspection results
- video?
- qualified head



by 10/25

MRP

meeting ends today -- should have something raised
next week