

22

From: Allen Hiser
To: Bill Bateman; Farouk Eltawila; Jack Strosnider; Keith Wichman
Date: 10/12/01 1:53PM
Subject: RELEVANT CRDM NUMBERS

Oconee EFPYs (as of 2/2001):

Unit 1 = 20.4
Unit 2 = 20.3
Unit 3 = 20.1

EFPYs from Oconee Unit 3 for B&W Plants(as of 2/2001)

ONS 1 to 3 = -0.3 to 0.0 --- 2 plants had CRDM leakers with circumferential cracks, all plants w/ leakers
ANO1 = 2.1 --- 1 leaker

Davis-Besse = 3.1 --- HASN'T LOOKED

TMI-1 = 4.1 --- 2 possible CRDM leakers (+ 8/8 thermocouple nozzles) -- PRELIMINARY INFO.

Crystal River 3 = 5.9 --- 1 CRDM leaker with a circumferential crack

Bottom Line: 6 B&W plants have looked in last 12 months and all 6 have found leakers -- only Davis-Besse remains to examine their nozzles