

**From:** F. Mark Reinhart  
**To:** Allen Hiser  
**Date:** 10/17/01 3:16PM  
**Subject:** Re: RAIs FOR DAVIS-BESSE

Allen,

It appears as if what Davis-Besse did was very parallel to what Oconee did. It would seem that our interests in additional information would also be parallel: We likely need to see the Framatome report, and we likely need to see their actual risk calculations.

Thanks,

Mark

>>> Allen Hiser 10/17/01 09:49AM >>>

EMCB has reviewed two submittals from Davis-Besse provided by the licensee last Friday. These are an analysis by SAI on nozzle annulus gaps and a Framatome report on "RV Head Nozzle and Weld Safety Assessment." The Framatome report is the same basis used by Oconee in their Bulletin response, and we identified many issues with the Oconee material (e.g., at the September 7 public meeting).

We are completing preparation of RAIs on these two reports, to be sent to the licensee later this morning or early afternoon, as preparation for a telecon this afternoon.

Do you have any items that we should add to our list?

Thanks,

Allen

**CC:** Ian Jung; Jin Chung; Richard Barrett; Steven Long

B-57