(39)

11/9/01

Davis Besse

next inspection

CR3/TMI crawler used at AN01

complete NDE on the 4 non-qualified nozzles

10% expansion per leaker found

new head, service structure + equip hatch
probably 2004 replacement

10/9/01 - ACRS
Raj Bhatanic?? - EPRI Trends data
comparison of measurements of residual stresses (strain gages)

(W) used tube ovality measurements + calculations

Material full sub-comm. in Feb-2001

- initial crack size + impact
- CGR in the crack environment
  - fluid dynamically

Lawson
301-249-2643

B-124