

49

11/28

Davis-Besse

- have authorized new head order

additional info

- (a) compensatory measures & human error impact on risk
- (b) COF 95% percentile plant, no ISI credit
- (c) page 18, inspection data for heats in other plants
- (d) basis for COF reduction of factor of 30, referring back to page 7 of their prior submittal

eventually docketed in a Bulletin response supplement

---

briefings

- LOCA is high; for a short time
- question of RB parameters met
- issues on IE, no answers until inspection
- borderline on RI guidelines
  - ↳ It can make it go slightly higher or lower
  - <sup>staff finds</sup> 45 days acceptable

B-172