



Florida Power & Light Company, 6501 South Ocean Drive, Jensen Beach, FL 34957

August 26, 2002

L-2002-176  
10 CFR 54

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555

Re: St. Lucie Units 1 and 2  
Docket Nos. 50-335 and 50-389  
Supplemental Response to NRC Request for Additional Information Related to the  
Staff's Review of Severe Accident Mitigation Alternatives for St. Lucie Units 1 and 2

By letter dated June 25, 2002, FPL provided its response to the NRC Requests for Additional Information (RAIs) regarding the St. Lucie Units 1 and 2 License Renewal Application (LRA) Environmental Report Severe Accident Management Alternatives. Due to an administrative error in Table 1-1, "Breakdown in Internal CDF Sorted by Initiating Events," FPL's response to Question 1.c has been revised. Attachment 1 to this letter contains the revised response to Question 1.c. FPL has evaluated the revision to Table 1-1 and determined that there was no impact on the validity of the SAMA studies.

Should you have any further questions, please contact S. T. Hale at (772) 467-7430.

Very truly yours,

D. E. Jernigan  
Vice President  
St. Lucie Plant

DEJ/STH/hlo  
Attachment (1)

A089

St. Lucie Units 1 and 2  
Docket Nos. 50-335 and 50-389


Supplemental Response to NRC Request for Additional Information Related to the Staff's  
Review of Severe Accident Mitigation Alternatives for St. Lucie Units 1 and 2

STATE OF FLORIDA                    )  
  ) ss  
COUNTY OF ST. LUCIE            )

D. E. Jernigan being first duly sworn, deposes and says:

That he is Vice President – St. Lucie of Florida Power and Light Company, the Licensee  
herein;

That he has executed the foregoing document; that the statements made in this document  
are true and correct to the best of his knowledge, information and belief, and that he is  
authorized to execute the document on behalf of said Licensee.

  
D. E. Jernigan

Subscribed and sworn to before me this

26 day of August, 2002.

Leslie J. Whitwell

Leslie J. Whitwell  
Name of Notary Public (Type or Print)

D. E. Jernigan is personally known to me.



Leslie J. Whitwell  
MY COMMISSION # DD020212 EXPIRES  
May 12, 2005  
BONDED THRU TROY FAIR INSURANCE, INC.

cc: U.S. Nuclear Regulatory Commission, Washington, D.C.

Program Director, License Renewal and Environmental Impacts  
Project Manager – St. Lucie License Renewal  
Project Manager - St. Lucie

U.S. Nuclear Regulatory Commission, Region II  
Regional Administrator, Region II, USNRC  
Senior Resident Inspector, USNRC, Turkey Point Plant

Other

Mr. Robert Butterworth  
Attorney General  
Department of Legal Affairs  
The Capitol  
Tallahassee, FL 32399-1050

Mr. William A. Passetti, Chief  
Department of Health  
Bureau of Radiation Control  
2020 Capital Circle, SE, Bin #C21  
Tallahassee, FL 32399-1741

Mr. Craig Fugate, Director  
Division of Emergency Preparedness  
Department of Community Affairs  
2740 Centerview Drive  
Tallahassee, FL 32399-2100

Mr. Douglas Anderson  
County Administrator  
St. Lucie County  
2300 Virginia Avenue  
Fort Pierce, FL 34982

Mr. Jim Kammel  
Radiological Emergency Planning Administrator  
Department of Public Safety  
6000 SE Tower Drive  
Stuart, FL 34997

Mr. Alan Nelson  
Nuclear Energy Institute  
1776 I Street NW  
Suite 400  
Washington, D.C. 20006

**ST. LUCIE UNITS 1 AND 2  
DOCKET NOS. 50-335 AND 50-389  
ATTACHMENT 1  
SUPPLEMENTAL RESPONSE TO NRC REQUEST FOR ADDITIONAL INFORMATION  
TO THE STAFF'S REVIEW OF THE SEVERE ACCIDENT MANAGEMENT  
ALTERNATIVES (SAMA) FOR ST. LUCIE UNITS 1 AND 2**

**QUESTION 1.c**

The SAMA analysis appears to be based on the current version of the "living" PSA model for internal events, which is a modification to the original Individual Plant Examination (IPE) that was reviewed by the U. S. Nuclear Regulatory Commission (NRC). Please provide the following:

- c. a breakdown of the internal event CDF for each unit by initiating event, specifically, Loss of Offsite Power (LOOP), General Transients, Station Blackout, ATWS, Loss-of-Coolant Accidents (LOCAs), Interfacing System LOCA (ISLOCA), and Steam Generator Tube Rupture (SGTR), and other internal events initiators (please specify). Also, confirm the total of  $2.99 \times 10^{-5}$  per reactor year for Unit 1 and  $2.44 \times 10^{-5}$  per reactor year, for Unit 2, respectively.

**Response to Question 1.c**

This response supercedes the response to Question 1.c provided in FPL Letter L-2002-124 dated June 25 in its entirety.

- c. Individual sequences associated with various Plant Damage States (PDSs) were quantified separately and then totaled, yielding frequencies of  $2.99 \times 10^{-5}$  per reactor year and  $2.44 \times 10^{-5}$  per reactor year (including ISLOCA) for Unit 1 and Unit 2, respectively. An alternate quantification based on an "OR" gate containing all PDS sequences produced frequencies of  $2.86 \times 10^{-5}$  per reactor year and  $2.43 \times 10^{-5}$  per reactor year, respectively. The following is based on the one-top PDS results. The individual sequence for various PDSs were used for Level 3 analysis.

**Table 1-1  
Breakdown of Internal CDF Sorted by Initiating Events**

Initiating Event	Frequency (per Year)	
	Unit 1	Unit 2
Loss of Offsite Power/Station Blackout <sup>1</sup>	4.63E-06	2.67E-06
Transients <sup>2</sup>	4.55E-06	1.84E-06
Anticipated Transient Without Scram	8.23E-07	3.31E-07
Loss-of-Coolant Accident	8.22E-06	7.82E-06
ISLOCA	2.89E-06	5.64E-06
SGTR	9.58E-07	2.78E-07
Internal floods	5.00E-07	5.00E-07
Others <sup>3</sup>	6.03E-06	5.22E-06
<b>Total CDF</b>	<b>2.86E-05</b>	<b>2.43E-05</b>

**Notes:**

1. Loss of Offsite Power sequences are predominantly Station Blackout sequences.
2. General Transients include Reactor Trip, Loss of Main Feedwater, and Excessive Feedwater.
3. See list of other initiators below.

Other initiators include:

Loss of 4KV Bus 1A2  
Loss of 4KV Bus 1B2  
Loss of 6.9KV Bus 1A1 As Initiator  
Loss of 6.9KV 1B1 As Initiator  
Loss of Component Cooling Water (CCW)  
Loss of DC Bus 1A  
Loss of DC Bus 1B  
Loss of Instrument Air  
Loss of Intake Cooling Water (ICW)  
Loss of 120VAC Instrument Bus 1MA  
Loss of 120VAC Instrument Bus 1MB  
Loss of 120VAC Instrument Bus 1MC  
Loss of 120VAC Instrument Bus 1MD  
Seal LOCA Initiating Event (IE) (Loss of CCW Not Related to LOCCWIE or LOICWIE) - All RCPs  
Seal LOCA IE (Loss of CCW Not Related to LOCCWIE or LOICWIE) - One RCP  
Steamline Break Upstream of SG A Main Steam Isolation Valve (MSIV)  
Steamline Break Upstream of SG B MSIV  
Steamline Break Downstream of the MSIVs  
Spurious Main Steam Isolation Signal  
Spurious Safety Injection Actuation Signal  
Transient Induced by Power Operated Relief Valve (PORV) Opening with Pressurizer (PRZR) Transmitter (XMTR) Failing Hi PORV 1404  
Transient Induced by PORV Opening with PRZR XMTR Failing Hi PORV 1402  
Loss of Turbine Cooling Water (TCW)