

Region I NMSS Licensee Event Report

Licensee	AGILENT TECHNOLOGIES
Event Description	Notice of General License Device w/High Removable Activity

License #	07-28762-02G	Docket #	0300 2988	MLER-RI	2002-049
Event Date	2002	Report Date	7/31/02		

1. REPORTING REQUIREMENT

<input type="checkbox"/> 10 CFR 20.2201 Theft or Loss	<input type="checkbox"/> 10 CFR 35.33 Misadministration
<input type="checkbox"/> 10 CFR 20.2203 30 Day Report	<input type="checkbox"/> License Condition
<input type="checkbox"/> 10 CFR 30.50 Report	
<input checked="" type="checkbox"/> Other 10 CFR 31.5	

2. REGION I RESPONSE

<input type="checkbox"/> Immediate Site Inspection	Inspector/Date	<input type="text"/>
<input type="checkbox"/> Special Inspection	Inspector/Date	<input type="text"/>
<input type="checkbox"/> Telephone Inquiry	Inspector/Date	<input type="text"/>
<input type="checkbox"/> Preliminary Report	<input type="checkbox"/> Daily Report	
<input checked="" type="checkbox"/> Information Entered in RI Log	<input checked="" type="checkbox"/> Review at next inspection	
<input type="checkbox"/> Report referred to: _____		

3. REPORT EVALUATION

<input type="checkbox"/> Description of Event	<input type="checkbox"/> Corrective Actions
<input type="checkbox"/> Levels of RAM Involved	<input type="checkbox"/> Calculations Adequate
<input type="checkbox"/> Cause of Event	<input type="checkbox"/> Additional Information Requested from Licensee

4. SPECIAL INSTRUCTIONS OR COMMENTS

Public Non-Public

	Initials/Date		Initials/Date
Completed by:	<i>Betsy Ullring</i>	Date	8/28/02
Reviewed by:	<i>[Signature]</i>	Date	8/22/2002

 **Agilent Technologies**
2850 Centerville Road
Wilmington, DE 19808

RECEIVED
REGION I

2002 JUL 31 PM 1:41

Division of Nuclear Materials Safety
U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road,
King of Prussia, PA 19406

Re: Notice of General License device with high removable activity (NRC License 07-28762-02G)

July 30, 2002

Dear Sir or Madam,

Per the requirements of 10 CFR 31.5, I am notifying your office of a general license device returned to our site by an overseas customer from which we have obtained a removable activity wipe in excess of 0.005 μCi . The cell was evaluated by support engineering and its disposition is identified below. I will notify the cell supplier of the high wipe.

<u>Serial #</u>	<u>Model #</u>	<u>Activity (μCi)</u>	<u>Disposition</u>
F1284	19233	0.009	Refurbished and re-sold

Comments:

The cell is 11 years old.

Please contact me at 302-633-8262 if there are any questions.

Thank you,



David S. Bennett
Radiation Safety Officer