

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.20.1	Verify SG tube integrity satisfies the structural integrity and accident induced LEAKAGE performance criteria in accordance with the Steam Generator Program.	In accordance with the Steam Generator Program
SR 3.4.20.2	Verify that each inspected SG tube that exceeds the tube repair criteria is plugged or repaired in accordance with the Steam Generator Program.	Prior to entering MODE 4 following a SG inspection